



Jon S. Corzine
Governor

State of New Jersey
Department of Community Affairs
Division of Codes and Standards
PO Box 802
Trenton, New Jersey 08625-0802



Joseph V. Doria, Jr.
Commissioner

BULLETIN NO.

93-3

Date: **December 1993** Subject: **Cathodic Protection of Gas**
Code Ref. Update: **December 2005** **Piping**
Revised: **June 2008**

Reference: **N.J.A.C. 5:23-3.22, Fuel
Gas Subcode, Section
404; N.J.A.C. 5:23-3.21,
One- and Two-Family
Dwelling Subcode, Section
G2415**

Underground natural gas systems that use steel, cast iron, ductile iron, copper, or aluminum tubing or piping are subject to external corrosion. External corrosion can slowly turn what was once a safe, pressure-tested, leak-proof, natural-gas piping system into a leaking, life- and property-threatening hazard.

All piping beyond the outlet of the natural gas meter comes under the jurisdiction of the Uniform Construction Code. Underground piping systems and their protection from corrosion is addressed under Section 404.8 of the Fuel Gas Subcode and Section G2415.8 of the One- and Two-Family Dwelling Subcode, as applicable; however, the code provisions are not very specific on how corrosion protection is provided. Rather, the code simply states that the piping be protected in an approved manner.

This bulletin provides the methods to protect underground natural gas piping systems either through cathodic protection methods or the use of alternative materials, such as plastic pipe or tubing. Therefore, the Department of Community Affairs is recommending that the attached details be followed to ensure adequate corrosion protection is provided to underground piping systems.

BULLETIN



