

SUBCHAPTER 5. GENERAL OPERATING REQUIREMENTS

7:14B-5.1 Spill and overflow control

(a) The owner or operator of an underground storage tank system shall ensure the following:

1. There shall be no release of hazardous substance due to spills or overfills at an underground storage tank facility;
2. The available volume in an underground storage tank shall always be greater than the volume of hazardous substance being transferred to the tank; and
3. The transfer operation is monitored constantly to avoid spilling and overfilling.

(b) The transfer procedures described in National Fire Protection Association Publication 385, and American Petroleum Institute Publication 1621, "Recommended Practice for Bulk Liquid Stock Control at Retail Outlets," and National Fire Protection Association Standard 30, "Flammable and Combustible Liquids Code," incorporated herein by reference, as amended and supplemented, shall be used to comply with (a)1 and 2 above.

(c) The owner and operator shall report, investigate, and remediate any spills and overfills in accordance with N.J.A.C. 7:14B-8.

(d) In order to ensure proper operation of spill containment equipment, the owner and operator shall:

1. Keep spill catchment basins, dispenser sumps and piping sumps clean of product, water and debris;
2. Visually inspect spill catchment basins before every delivery and visually inspect spill catchment basins, dispenser sumps and piping sumps once every 30 days, and properly dispose of any accumulation of debris and liquid collected. The visual inspection shall include a check for evidence of cracks, holes, loose fittings or any other deficiency which may compromise the integrity of the spill containment equipment.
3. Ensure deficient equipment is repaired or replaced. Repairs and installation of new equipment shall be in compliance with N.J.A.C. 7:14B-4.1(a)3i, 4.1 (n), 4.2(d), and 5.4; and
4. Not accept product delivery to any tank if the spill catchment basin contains product, water or debris.

7:14B-5.2 Operation and maintenance of corrosion protection

(a) All owners and operators of metallic underground storage tank systems with corrosion protection shall comply with the following requirements to ensure that releases due to corrosion are prevented for as long as the underground storage tank system is used to store regulated substances:

1. All corrosion protection systems shall be operated and maintained in accordance with (a)2 and 3 below to continuously provide corrosion protection to the metal components of that portion of the tank and piping that routinely contain regulated substances and are in contact with the ground.

2. All underground storage tank systems equipped with cathodic protection systems shall be inspected for proper operation by a Cathodic Protection Tester or Cathodic Protection Specialist certified pursuant to N.J.A.C. 7:14B-13 in accordance with the following requirements:

i. All cathodic protection systems shall be tested within six months of installation and at least every three years thereafter by an individual certified in accordance with N.J.A.C. 7:14B-13; and

ii. The criteria that are used to determine that cathodic protection is adequate as required by this section shall be in accordance with a code of practice developed by a nationally recognized association. For example, NACE International Standard RP-02-95 RP0285-2002, "Corrosion Control of Underground Storage Tank Systems by Cathodic Protection" may be used to comply with this requirement.

3. Underground storage tank systems with impressed current cathodic protection systems shall be inspected every 60 calendar days to ensure the equipment is running properly.

4. For underground storage tank systems using cathodic protection, records of the operation of the cathodic protection shall be maintained in accordance with N.J.A.C. 7:14B-5.6 to demonstrate compliance with the operation and maintenance standards in this section. These records shall provide the following:

i. The results of testing from all inspections required in (a)2 above; and

ii. The results of all inspections required in (a)3 above.

7:14B-5.3 Compatibility

(a) Owners and operators shall use an underground storage tank system made of or lined with materials that are compatible with the substance stored in the underground storage tank system.

(b) Owners and operators storing alcohol blends shall use the following codes, incorporated herein by reference, as amended and supplemented, to comply with the requirements of (a) above:

1. American Petroleum Institute Publication 1626, "Storing and Handling Ethanol and Gasoline-Ethanol Blends at Distribution Terminals and Service Stations"; and

2. American Petroleum Institute Publication 1627, "Storage and Handling of Gasoline-Methanol/Cosolvent Blends at Distribution Terminals and Service Stations."

(c) All compartmentalized tanks shall hold, in each compartment, hazardous substances compatible with one another to prevent safety hazards such as a fire or explosion or corrosion of the underground storage tank system in case of breaches in the compartment walls.

7:14B-5.4 Repairs

(a) Owners and operators of underground storage tank systems shall obtain a permit from the Department in accordance with N.J.A.C. 7:14B-10 and meet the following requirements to ensure that repairs shall prevent releases due to structural failure or corrosion as long as the underground storage tank system is used to store hazardous substances:

1. Repairs to underground storage tank systems shall be properly conducted in accordance with a code of practice developed by a nationally recognized association as listed in N.J.A.C. 7:14B-5.4(c), or an independent testing laboratory.

2. Repairs to fiberglass-reinforced plastic tanks shall be made in accordance with the manufacturer's specifications or in accordance with a code of practice developed by a nationally recognized association as listed in N.J.A.C. 7:14B-5.4(c) or an independent testing laboratory.

3. Metal pipe sections and fittings that have released product as a result of corrosion or other damage shall be replaced. Fiberglass pipes and fittings shall be repaired or replaced in accordance with the manufacturer's specifications.

4. Repaired tanks and piping shall be tightness tested in accordance with N.J.A.C. 7:14B-6.5(a)3 and 6.6(a)2 within 30 calendar days following the date of the completion of the repair except when:

i. The repaired tank is internally inspected in accordance with a code of practice developed by a nationally recognized association as listed in N.J.A.C. 7:14B-5.4(c) or an independent testing laboratory; or

ii. The repaired portion of the underground storage tank system is monitored monthly for releases in accordance with a method specified in N.J.A.C. 7:14B-6.5(a)4 through 8.

5. Within six months following the repair of any cathodically protected underground storage tank system, the cathodic protection system shall be tested in accordance with N.J.A.C. 7:14B-5.2(a)2 and 3 to ensure that it is operating properly.

6. Underground storage tank system owners and operators shall maintain records of each repair and associated tightness test for the remaining operating life of the underground storage tank system that demonstrate compliance with the requirements of this section. When an underground storage tank system is closed, an owner or operator may make a written request to the Department to discard any such documents. Such a request shall be accompanied by a description of the documents involved. Upon written approval by the Department, the owner or operator may discard only those documents that are not required to be preserved for a longer time period.

(b) The owner and operator of an underground storage tank system shall obtain a permit from the Department pursuant to N.J.A.C. 7:14B-10.1(a), prior to performing repairs which constitute a substantial modification under N.J.A.C. 7:14B-10.

(c) The following codes and standards, incorporated herein by reference, as amended and supplemented, shall be used to comply with the requirements of (a) above:

1. National Fire Protection Association Standard 30, "Flammable and Combustible Liquids Code";

2. American Petroleum Institute Publication 2200, "Repairing Crude Oil, Liquefied Petroleum Gas, and Product Pipelines";

3. American Petroleum Institute Publication 1631, "Interior Lining and Periodic Inspection of Underground Storage Tanks"; or

4. National Leak Prevention Association Standard 631, "Spill Prevention, Minimum 10 Year Life Extension of Existing Steel Underground Tanks by Lining Without the Addition of Cathodic Protection."

7:14B-5.5 Release response plan

(a) The owner or operator of an underground storage tank system shall prepare a release response plan which includes the following information:

1. The emergency telephone numbers of the local fire department, local health department, Department of Environmental Protection Hotline 877 WARN DEP or 877-927-6337, and any other appropriate local or State agencies;

2. The name and telephone number(s) of the person responsible for the operation of the facility during an emergency;

3. The name and telephone number of any retained corrective action contractor; and

4. The procedures to be followed pursuant to N.J.A.C. 7:14B-8 in the event of a leak or discharge of a hazardous substance from the facility and N.J.A.C. 7:14B-9 if the underground storage tank system must be closed.

(b) The release response plan shall be available for on site inspection.

(c) Any release response plan which is required by and is in compliance with the New Jersey Spill Compensation and Control Act, N.J.S.A. 58:10-23.11 et seq., shall suffice for this requirement.

7:14B-5.6 Recordkeeping

(a) Owners and operators shall maintain the following information until the owner or operator receives the Department's written permission to discard the records pursuant to (c) below:

1. For underground storage tank systems susceptible to corrosion:

i. A corrosion expert's analysis of site corrosion potential if corrosion protection equipment is not used in accordance with N.J.A.C. 7:14B-4.1(a)1iv and 2iii; and

ii. Documentation of operation of corrosion protection equipment pursuant to N.J.A.C. 7:14B-5.2;

2. Documentation of underground storage tank system repairs made in accordance with N.J.A.C. 7:14B-5.4;

3. Recent compliance with release detection requirements pursuant to N.J.A.C. 7:14B-6.7;

4. Results of all site investigations and remedial investigations conducted pursuant to N.J.A.C. 7:14B-8 and 9;

5. An installation checklist as required by N.J.A.C. 7:14B-4.1(a)5; and

6. Documentation of compliance with N.J.A.C. 7:14B-5.1(d).

(b) Owners and operators shall keep the records required either:

1. At the underground storage tank site and immediately available for inspection by the implementing agency; or

2. At a readily available alternative site and be provided for inspection to the implementing agency upon request.

(c) After a site is no longer operational, an owner or operator may make a written request to discard any such documents. Such a request shall be accompanied by a description of the documents involved. Upon written approval by the Department, the owner or operator may discard only those documents that are not required to be preserved for a longer time period.

(d) A request for written approval to discard documents shall be sent to:

New Jersey Department of Environmental Protection
Division of Remediation Management and Response
Bureau of Southern Case Management
PO Box 433
401 East State Street
Trenton, NJ 08625-0433

7:14B-5.7 Right of entry

(a) The owner or operator of any property or place of business where an underground storage tank system is or might be located shall allow the Department, or an authorized representative, upon the presentation of credentials, to:

1. Enter upon any property or place of business where an underground storage tank is or might be located or in which monitoring equipment or records required by this chapter are kept, for purposes of inspection, sampling, copying or photographing. Photographing shall be allowed only as related to the underground storage tank system;

2. Have access to and copy any records that must be kept pursuant to this chapter;

3. Inspect all facilities or equipment (including monitoring and control equipment);

4. Observe practices or operations regulated or required under this chapter; and
5. Sample soil, ground water, surface water and/or air.

7:14B-5.8 Fill port markings

The owner or operator of an underground storage tank system shall permanently mark all fill ports to identify product inside the underground storage tank system. The markings shall be consistent with the colors and symbol codes established by the American Petroleum Institute Publication #1637, "Using the API Color-Symbol System to Mark Equipment and Vehicles for Product Identification at Service Station and Distribution Terminals" and the American Petroleum Institute Publication #1542, "Airport Equipment Marking for Fuel Identification," incorporated herein by reference, as amended and supplemented.

7:14B-5.9 Use of regulated underground storage tank systems

(a) No person or business firm shall introduce hazardous substances into an underground storage tank system which is known to be or suspected to be leaking or discharging hazardous substances except in accordance with N.J.A.C. 7:14B-8.1(a)2ii.

(b) No person or business firm shall introduce hazardous substances into a regulated underground storage tank which is not properly registered with the Department pursuant to N.J.A.C. 7:14B-2.1.