

<b>Table 1</b> <b>South Hunterdon Regional Middle and High School</b>		
1. Existing or proposed facility:	Proposed Middle School; Existing High School	
2. New Jersey Pollutant Discharge Elimination System Permit Number:	Middle School (TBD); High School NJG 0131261*	
3. Discharge to ground water (DGW) or surface water (DSW):	Discharge to groundwater	
4. Receiving water or aquifer:	Newark Group Aquifer	
5. Classification of receiving water or aquifer:	II-A	
6. Owner of facility:	South Hunterdon Regional School District	
7. Operator of facility:	South Hunterdon Regional School District	
8. Co-Permittee of facility ( <i>where applicable</i> ):		
9. Location of facility:	West Amwell Township, Hunterdon County	
a. Municipality & County		
b. Street address	301 Mt Airy-Harbourton Rd"	
c. Block(s) and Lot(s)	Block 11, Lot 16	
10. Location of discharge (i.e. degrees, minutes, seconds):	a. Longitude <u>74°53'41.32"</u>	
	b. Latitude <u>40°23'07.64"</u> or	
	c. State Plane Coordinates <u>E382148.7226    N565566.9961</u>	
11. Present permitted flow or permit condition (DSW) or daily maximum (DGW):	N/A*	
*12. Summary of population served/to be served (including major seasonal fluctuations if applicable):	Current (Year 2023) Population	Build-out
High School (Grades 7-12)	444 students	444 students
Middle School	0	250 students
*13. Summary of wastewater flow received/to be received as a daily maximum flow for DGW:	Current (Year 2023) Flow (in MGD)	Build-out (in MGD)
High School	0.00888**	0.00888**
Middle School		0.005***
<b>Facility Total</b>	0.00888**	0.01388

\* The existing High School ISSDS (septic system) is regulated under a T1 General Permit. The existing T1 permit will be revoked and the discharge regulated pursuant to the new individual permit to be issued for the Middle School.

\*\* The existing High School ISSDS T1 General Permit does not have a permitted flow. The existing flow is unmetered. The above identified existing flow is calculated flow based on the existing uses and N.J.A.C. 7:9A design criteria.

\*\*\* The proposed Middle School projected flow is calculated pursuant to N.J.A.C. 7:9A design criteria: Private Restroom: 10 GPD; Showers: 5 GPD; Food Service: 5 GPD; Total per student: 20 GPD. Per student design criteria is inclusive of teachers and staff.