

DOCKET NO. D-1973-191 CP-5

DELAWARE RIVER BASIN COMMISSION

**Abington Township
Wastewater Treatment Plant
Upper Dublin Township, Montgomery County, Pennsylvania**

PROCEEDINGS

This docket is issued in response to an Application submitted to the Delaware River Basin Commission (DRBC or Commission) by the Township of Abington (docket holder) on July 8, 2014 (Application) for a renewal of the docket holder's existing wastewater treatment plant (WWTP) and its related discharge. Draft National Pollutant Discharge Elimination System (NPDES) Permit No. PA0026867 for this facility was issued by the Pennsylvania Department of Environmental Protection (PADEP) on November 5, 2015.

The Application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact (Compact)*. The Montgomery County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on February 10, 2016.

A. DESCRIPTION

- 1. Purpose.** The purpose of this docket is to renew approval of the docket holder's existing 3.91 million gallon per day (mgd) WWTP and its discharge. No modifications to the WWTP are proposed.
- 2. Location.** The project WWTP is located on Fitzwatertown Road in Upper Dublin Township, Montgomery County, Pennsylvania. The WWTP will continue to discharge to Sandy Run, which is tributary to Wissahickon Creek, which is tributary to the Schuylkill River, at River Mile 92.47 – 12.8 – 11.2 – 4.4 (Delaware River – Schuylkill River – Wissahickon Creek – Sandy Run) via Outfall No. 001.

The project outfall is located in the Schuylkill River Watershed as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
001	40° 07' 48"	75° 09' 31"

- 3. Area Served.** The docket holder's WWTP will continue to serve portions of Abington, Cheltenham, Springfield, Upper Dublin and Upper Moreland Townships in Montgomery County, Pennsylvania.

For the purpose of defining the Area Served, Section B (Type of Discharge) and D

(Service Area) of the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in the DECISION Section of this docket.

4. Physical features.

a. Design criteria. The docket holder's WWTP will continue to utilize a conventional activated sludge treatment process. The WWTP is designed to treat an average annual design flow of 3.91 mgd. No modifications to the WWTP are proposed.

b. Facilities. The WWTP facilities consist of two (2) filter screens, a grit chamber, flow equalization, two (2) primary clarification tanks, an anaerobic reactor, anaerobic zones for three (3) aeration reactors with post-anoxic zones, chemical addition (alum) for phosphorous removal, three (3) final clarifiers, and ultraviolet light (UV) disinfection. Sludge handling facilities consist of a dissolved air flotation (DAF) thickener, three digesters, and centrifuge dewatering.

The project facilities are not located in the 100-year floodplain.

Wasted sludge will continue to be hauled off-site by a licensed hauler for disposal at a state approved facility.

c. Water withdrawals. The potable water supply in the project service area is provided by wells owned and operated by Aqua, Pennsylvania, as described in detail in DRBC Docket No. 1965-110 CP-1, approved on October 7, 1965, and by individually owned, private wells.

d. NPDES Permit / DRBC Docket. PADEP issued draft NPDES Permit No. PA0026867 for the project discharge on November 5, 2015, which includes final effluent limitations for the project discharge of 3.91 mgd to surface waters classified by the PADEP as trout stocking fishery (TSF). The following average monthly effluent limits are among those listed in the NPDES permit that meet or are more stringent than the effluent requirements of the DRBC.

EFFLUENT TABLE A-1: DRBC Parameters Included in NPDES permit

OUTFALL 001 (Sandy Run)		
PARAMETER	LIMIT	MONITORING
pH (Standard Units)	6.0 to 9.0	As required by NPDES permit
Total Suspended Solids	30 mg/l	As required by NPDES permit
CBOD (5-Day at 20° C) (5-1 to 10-31) (11-1 to 4-30)	7.5 mg/l (85% Minimum Removal) 15 mg/l (85% Minimum Removal)	As required by NPDES permit
Ammonia-Nitrogen 5/01-10/31 11/01-4/30	0.72 mg/l 2.16 mg/l	As required by NPDES permit
Fecal Coliform	200 colonies per 100 ml	As required by NPDES permit
Total Dissolved Solids *	1,000 mg/l	As required by NPDES permit

*See DECISION Conditions II.p.

e. **Relationship to the Comprehensive Plan.** The existing WWTP was added to the Comprehensive Plan by Resolution No. R-62-14 (Addendum No. 1, Pre-existing Projects) in July, 1962. The first WWTP upgrade was approved by Docket No. D-1973-191 CP-1 on February 26, 1975, but was never constructed. WWTP upgrades were approved by Docket Nos. D-1973-191 CP-REV and D-1973-191 CP-3 on January 24, 1979 and September 26, 2007, respectively, and the WWTP was renewed by Docket No. D-1973-191 CP-4 on September 13, 2010.

This docket (D-1973-191 CP-5) renews approval of the WWTP and continues the project in the Comprehensive Plan.

B. FINDINGS

This docket renews the approval of the docket holder's existing 3.91 mgd WWTP. No modifications to the WWTP are proposed.

At the project site, Sandy Run has an estimated seven-day low flow with a recurrence interval of ten years (Q_{7-10}) of 0.07 mgd (0.11 cfs). The ratio of this low flow to the hydraulic design capacity of the WWTP (3.91 mgd) is approximately 0.02 to 1.

The nearest downstream surface water intake of record for public water supply is located approximately 29 miles downstream of the docket holder's WWTP on the Schuylkill River, and is owned and operated by the City of Philadelphia.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit are in compliance with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge meeting the effluent requirements as set forth in the Commission's *Water Quality Regulations (WQR)*.

C. DECISION

I. Effective on the approval date for Docket No. D-1973-191 CP-5 below:

a. The project described in Docket No. D-1973-191 CP-4 is removed from the Comprehensive Plan to the extent it is not included in Docket No. 1973-191 CP-5; and

b. Docket No. D-1973-191 CP-4 is terminated and replaced by Docket No. D-1973-191 CP-5.

c. The project and the appurtenant facilities described in the Section A “Physical Features” of this docket shall be continued in the Comprehensive Plan.

II. The project and appurtenant facilities as described in the Section A “Physical features” of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

a. Docket approval is subject to all conditions, requirements, and limitations imposed by the PADEP in its NPDES permit, and such conditions, requirements, and limitations are incorporated herein, unless they are less stringent than the Commission’s.

b. The facility and operational records shall be available at all times for inspection by the DRBC.

c. The facility shall be operated at all times to comply with the requirements of the Commission’s *WQR* and *Flood Plain Regulations (FPR)*.

d. The docket holder shall comply with the requirements contained in the EFFLUENT TABLE in Section A.4.d. of this docket. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email **aemr@drbc.nj.gov** on the **Annual Effluent Monitoring Report Form** located at this web address: <http://www.state.nj.us/drbc/programs/project/application/index.html>. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations.

e. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.

f. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.

g. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.

h. The docket holder is permitted to treat and discharge wastewaters as set forth in the Area Served Section of this docket, which incorporates by reference Sections B

(Type of Discharge) and D (Service Area) of the docket holder's Application to the extent consistent with all other conditions of this DECISION Section.

i. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.

j. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).

k. Nothing in this docket approval shall be construed as limiting the authority of DRBC to adopt and apply charges or other fees to this discharge or project.

l. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, in order to ensure proper control, use and management of the water resources of the Basin.

m. Unless an extension is requested and approved by the Commission in advance, in accordance with paragraph 11 of the Commission's Project Review Fee schedule (Resolution No. 2009-2), the docket holder is responsible for timely submittal of a docket renewal application on the appropriate DRBC application form at least 12 months in advance of the docket expiration date set forth below. The docket holder will be subject to late charges in the event of untimely submittal of its renewal application, whether or not DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. In the event that a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below (or the later date established by an extension that has been timely requested and approved), the terms and conditions of the current docket will remain fully effective and enforceable against the docket holder pending the grant or denial of the application for docket approval.

n. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.

o. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the Rules of Practice and Procedure. In accordance with Section 15.1(p) of the Delaware River Basin Compact, cases and controversies arising under the Compact are reviewable in the United States district courts.

p. The Docket holder may submit a written request to substitute specific conductance for TDS. The request should include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow the substitution of specific conductance for TDS monitoring.

q. The docket holder is prohibited from treating/pre-treating any hydraulic fracturing wastewater from sources in or out of the Basin at this time. Should the docket holder wish to treat/pre-treat hydraulic fracturing wastewater in the future, the docket holder will need to first apply to the Commission to renew this docket and be issued a revised docket allowing such treatment and an expanded service area. Failure to obtain this approval prior to treatment/pre-treatment will result in action by the Commission.

BY THE COMMISSION

DATE APPROVED: March 16, 2016

EXPIRATION DATE: December 31, 2020