

DOCKET NO. D-1994-042 CP-2

DELAWARE RIVER BASIN COMMISSION

**Washington Township
Wastewater Treatment Plant
Washington Township, Berks County, Pennsylvania**

PROCEEDINGS

This docket is issued in response to an Application submitted to the Delaware River Basin Commission (DRBC or Commission) by Gilmore and Associates, Inc., on behalf of the Washington Township (docket holder) on October 23, 2014 (Application) for a renewal of the docket holder's existing wastewater treatment plant (WWTP) and its related discharge. National Pollutant Discharge Elimination System (NPDES) Permit No. PA0086142 A-1 for this facility was issued by the Pennsylvania Department of Environmental Protection (PADEP) on April 15, 2010.

The Application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact (Compact)*. The Berks County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on February 10, 2016.

A. DESCRIPTION

- 1. Purpose.** The purpose of this docket is to renew approval of the docket holder's existing 0.25 million gallon per day (mgd) WWTP and its discharge. No modifications to the WWTP are proposed.
- 2. Location.** The project WWTP is located on Niantic Road in Washington Township, Berks County, Pennsylvania. The WWTP will continue to discharge to West Branch Perkiomen Creek, which is tributary to Perkiomen Creek, which is tributary to the Schuylkill River, at River Mile 92.47 – 32.3 – 23.7 – 6.8 (Delaware River – Schuylkill River – Perkiomen Creek – West Branch Perkiomen Creek) via Outfall No. 001.

The project outfall is located in the Schuylkill River Watershed as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
001	40° 23' 10"	75° 35' 43"

3. **Area Served.** The docket holder’s WWTP will continue to serve a portion of Washington Township in Berks County, Pennsylvania.

For the purpose of defining the Area Served, Section B (Type of Discharge) and D (Service Area) of the docket holder’s Application are incorporated herein by reference, to the extent consistent with all other conditions contained in the DECISION Section of this docket.

4. **Physical features.**

a. **Design criteria.** The docket holder’s WWTP will continue to utilize a sequencing batch reactor (SBR) treatment process. The WWTP is designed to treat an average annual design flow of 0.25 mgd. No modifications to the WWTP are proposed.

b. **Facilities.** The WWTP facilities consist of a comminutor, bypass bar screen, and two (2) SBR tanks each equipped with a decanter, a waste sludge pump, and a stainless steel coarse bubble diffuser system. Aluminum chloride is added for phosphorous removal and disinfection is provided by two (2) chlorine contact tanks, followed by de-chlorination. Sludge handling is provided via two (2) aerated sludge holding tanks.

The project facilities are not located in the 100-year floodplain.

Wasted sludge will continue to be hauled off-site by a licensed hauler for disposal at a state approved facility.

c. **Water withdrawals.** The potable water supply in the project service area is provided by groundwater wells owned and operated by the Borough of Bally, as described in detail in DRBC Docket No. D-1978-019 CP-2, approved on December 10, 2008, and by private, individually-owned wells and several small systems operated at flow rates below the DRBC review threshold.

d. **NPDES Permit / DRBC Docket.** PADEP issued NPDES Permit No. PA0086142 A-1 for the project discharge on April 15, 2010, which includes final effluent limitations for the project discharge of 0.25 mgd to surface waters classified by the PADEP as cold water fishery (CWF) and migratory fishery (MF). The following average monthly effluent limits are among those listed in the NPDES permit that meet or are more stringent than the effluent requirements of the DRBC.

EFFLUENT TABLE A-1: DRBC Parameters Included in NPDES permit

OUTFALL 001 (West Branch Perkiomen Creek)		
PARAMETER	LIMIT	MONITORING
pH (Standard Units)	6.0 to 9.0	As required by NPDES permit
Total Suspended Solids	30 mg/l (85% Minimum Removal)	As required by NPDES permit
CBOD (5-Day at 20° C)	25 mg/l (85% Minimum Removal)	As required by NPDES permit
Ammonia-Nitrogen		As required by NPDES permit
5/01-10/31	7.5 mg/l	
11/01-4/30	20 mg/l	

OUTFALL 001 (West Branch Perkiomen Creek)		
PARAMETER	LIMIT	MONITORING
Fecal Coliform 5/01-9/30	200 colonies per 100 ml	As required by NPDES permit
10/01-4/30	2,000 colonies per 100 ml	

EFFLUENT TABLE A-2: DRBC Parameters Not Included in NPDES permit

OUTFALL 001 (West Branch Perkiomen Creek)		
PARAMETER	LIMIT	MONITORING
Total Dissolved Solids *	Monitor & Report	Quarterly

*See DECISION Conditions II.p.

e. **Relationship to the Comprehensive Plan.** The existing WWTP was added to the Comprehensive Plan by Docket No. D-1992-042 CP-1 on October 26, 1994. This docket (D-1994-042 CP-2) renews approval of the WWTP and continues the project in the Comprehensive Plan.

B. FINDINGS

This docket renews the approval of the docket holder’s existing 0.25 mgd WWTP. No modifications to the WWTP are proposed.

Docket Transfer of Ownership

This docket also approves the transfer of ownership from Washington Township Municipal Authority to Washington Township. The transfer occurred on September 30, 2013.

At the project site, the West Branch Perkiomen Creek has an estimated seven-day low flow with a recurrence interval of ten years (Q₇₋₁₀) of 2.1 mgd (3.24 cfs). The ratio of this low flow to the hydraulic design capacity of the WWTP (0.25 mgd) is approximately 8 to 1.

The nearest downstream surface water intake of record for public water supply is located approximately 30 miles downstream of the docket holder’s WWTP on the Perkiomen Creek, and is owned and operated by Aqua, Pennsylvania.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit are in compliance with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge meeting the effluent requirements as set forth in the Commission’s *Water Quality Regulations (WQR)*.

C. DECISION

- I. Effective on the approval date for Docket No. D-1994-042 CP-2 below:
- a. The project described in Docket No. D-1994-042 CP-1 is removed from the Comprehensive Plan to the extent it is not included in Docket No. D-1994-042 CP-2 and
 - b. Docket No. D-1994-042 CP-1 is terminated and replaced by Docket No. D-1994-042 CP-2.
 - c. The project and the appurtenant facilities described in the Section A “Physical Features” of this docket shall be continued in the Comprehensive Plan.
- II. The project and appurtenant facilities as described in the Section A “Physical features” of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:
- a. Docket approval is subject to all conditions, requirements, and limitations imposed by the PADEP in its NPDES permit, and such conditions, requirements, and limitations are incorporated herein, unless they are less stringent than the Commission’s.
 - b. The facility and operational records shall be available at all times for inspection by the DRBC.
 - c. The facility shall be operated at all times to comply with the requirements of the Commission’s *WQR* and *Flood Plain Regulations (FPR)*.
 - d. The docket holder shall comply with the requirements contained in the EFFLUENT TABLES in Section A.4.d. of this docket. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email aemr@drbc.nj.gov on the **Annual Effluent Monitoring Report Form** located at this web address: <http://www.state.nj.us/drbc/programs/project/application/index.html>. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations.
 - e. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.
 - f. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.

g. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.

h. The docket holder is permitted to treat and discharge wastewaters as set forth in the Area Served Section of this docket, which incorporates by reference Sections B (Type of Discharge) and D (Service Area) of the docket holder's Application to the extent consistent with all other conditions of this DECISION Section.

i. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.

j. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).

k. Nothing in this docket approval shall be construed as limiting the authority of DRBC to adopt and apply charges or other fees to this discharge or project.

l. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, in order to ensure proper control, use and management of the water resources of the Basin.

m. Unless an extension is requested and approved by the Commission in advance, in accordance with paragraph 11 of the Commission's Project Review Fee schedule (Resolution No. 2009-2), the docket holder is responsible for timely submittal of a docket renewal application on the appropriate DRBC application form at least 12 months in advance of the docket expiration date set forth below. The docket holder will be subject to late charges in the event of untimely submittal of its renewal application, whether or not DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. In the event that a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below (or the later date established by an extension that has been timely requested and approved), the terms and conditions of the current docket will remain fully effective and enforceable against the docket holder pending the grant or denial of the application for docket approval.

n. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.

o. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the Rules of Practice and Procedure. In accordance with Section 15.1(p) of the Delaware River Basin Compact, cases and controversies arising under the Compact are reviewable in the United States district courts.

p. The docket holder is required to perform quarterly TDS effluent sampling in accordance with EFFLUENT TABLE A-2 in Section A.4.d. of this docket. The Docket holder may also submit a written request to substitute specific conductance for TDS. The request should include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow the substitution of specific conductance for TDS monitoring.

q. The docket holder is prohibited from treating/pre-treating any hydraulic fracturing wastewater from sources in or out of the Basin at this time. Should the docket holder wish to treat/pre-treat hydraulic fracturing wastewater in the future, the docket holder will need to first apply to the Commission to renew this docket and be issued a revised docket allowing such treatment and an expanded service area. Failure to obtain this approval prior to treatment/pre-treatment will result in action by the Commission.

BY THE COMMISSION

DATE APPROVED: March 16, 2016

EXPIRATION DATE: March 16, 2021