

DOCKET NO. D-2006-005 CP-3

DELAWARE RIVER BASIN COMMISSION

**Alsace Township
Wastewater Treatment Plant
Alsace Township, Berks County, Pennsylvania**

PROCEEDINGS

This docket is issued in response to an Application submitted to the Delaware River Basin Commission (DRBC or Commission) by Ebert Engineering, Inc. on behalf of the Alsace Township on March 27, 2015 (Application), for approval of a wastewater treatment plant (WWTP) and its related discharge. National Pollutant Discharge Elimination System (NPDES) Permit No. PA0246956 for this project was issued by the Pennsylvania Department of Environmental Protection (PADEP) on April 1, 2011. An renewal application was submitted to the PADEP on September 30, 2015 for this permit and is awaiting approval

The Application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Berks County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on February 10, 2016.

A. DESCRIPTION

- 1. Purpose.** The purpose of this docket is to renew the approval of the docket holder's existing 0.071 million gallons per day (mgd) Alsace Township WWTP and its related discharge. There is no modification to the Alsace Township WWTP proposed.
- 2. Location.** The project will continue to discharge treated effluent to an unnamed tributary of the Little Manatawny Creek at River Mile 92.47 – 54.15 – 16.7 – 4.7 – 0.23 (Delaware River – Schuylkill River – Manatawny Creek – Little Manatawny Creek – UNT of the Little Manatawny Creek), via Outfall No. 001, in Alsace Township, Berks County, Pennsylvania as follows:

The project outfall is located in the Schuylkill River Watershed as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
001	40° 23' 58"	75° 50' 44"

- 3. Area Served.** The WWTP will continue to serve a predominantly residential portion of Alsace Township, Berks County, Pennsylvania. The users of the system consist of approximately 199 residential units and 13 commercial users.

For the purpose of defining the Area Served, sections B (Type of Discharge) and D (Service Area) of the docket holder’s Application are incorporated herein by reference, to the extent consistent with all other conditions contained in the DECISION Section of this docket.

4. Physical Features.

a. Design Criteria. The docket holder’s 0.071 mgd WWTP treats domestic and commercial wastewater. All wastewater treated at the Alsace Township WWTP facility is discharged to an unnamed tributary of the Little Manatawny Creek.

b. Facilities. The existing Alsace Township WWTP uses a Purestream, Inc. dual-train extended aeration package treatment system with a hydraulic design of 0.071 mgd. The wastewater is pumped from the influent pump station into the equalization tank where it is aerated by coarse bubble diffusers before being pumped to one of the two treatment trains of the WWTP. Currently due to the low influent flows, only one of the two treatment trains is operational. The wastewater is then treated by the activated sludge biological treatment process and conveyed to the final clarifier in the same tank. The treated effluent then flows by gravity to the ultraviolet disinfection unit for disinfection.

The project facilities are above the 100-year flood elevation.

Emergency power is provided by a standby on-site diesel generator.

Wasted sludge will continue to be hauled off-site by a licensed hauler for disposal at a state approved facility.

c. Water Withdrawals. The potable water supply in the project service area is provided by individual, privately-owned wells.

d. NPDES Permit / DRBC Docket. The NPDES Permit No. PA0246956 issued by PADEP on April 1, 2011, includes effluent limitations for the project discharge of 0.071 mgd to surface waters classified by the PADEP as a Cold Water Fishes (WWF) and Migratory Fishes (MF). The following average monthly effluent limits are among those listed in the NPDES permit and meet or are more stringent than the effluent requirements of the DRBC.

EFFLUENT TABLE A-1: DRBC Parameters Included in NPDES Permit

OUTFALL 001 (Discharge to an UNT of the Little Manatawny Creek)		
PARAMETER	LIMIT	MONITORING
pH (Standard Units)	6 to 9 at all times	As required in NPDES permit
Total Suspended Solids	30 mg/l	As required in NPDES permit
CBOD5 (5-Day at 20 °C)	25 mg/l (85% minimum removal)	As required in NPDES permit
Dissolved Oxygen	5.0 mg/l (minimum at all times)	As required in NPDES permit
Ammonia Nitrogen (5-1 to 10-31) (11-1 to 4-30)	4.0 mg/l 12.0 mg/l	As required in NPDES permit
Fecal Coliform (5-1 to 9-30) (10-1 to 4-30)	200 colonies per 100 ml 2,000 colonies per 100 ml	As required in NPDES permit

EFFLUENT TABLE A-2: DRBC Parameters Not Included in NPDES Permit

OUTFALL 001 (Discharge to an UNT of the Little Manatawny Creek)		
PARAMETER	LIMIT	MONITORING
Total Dissolved Solids*	1,000 mg/l	Quarterly

* See Decision Condition II.p.

e. **Relationship to the Comprehensive Plan.** The existing Alsace Township WWTP was included in the Comprehensive Plan via DRBC Docket No. D-2006-005 CP-1 and renewed via Docket No. D-2006-005 CP-2, issued on September 27, 2006 and September 12, 2013. Issuance of this docket will continue the WWTP in the Comprehensive Plan.

B. FINDINGS

The purpose of this docket is to renew the approval of the docket holder's existing 0.071 mgd Alsace Township WWTP. No modifications to the WWTP are proposed.

At the project site, UNT to Little Manatawny Creek has an estimated seven-day low flow with a recurrence interval of ten years (Q_{7-10}) of less than 0.1 cubic feet per second (cfs) and therefore is classified by the Commission as an intermittent stream.

The nearest public water supply surface water intake of record is located on the Schuylkill River approximately 32 river miles downstream of the project discharge and is operated by the Pennsylvania American Water Company.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The limits in the NPDES Permit are in compliance with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge meeting the effluent requirements as set forth in the *Water Quality Regulations (WQR)* of the DRBC.

C. DECISION

I. Effective on the approval date for Docket No. D-2006-005 CP-3 below:

a. The project described in Docket No. D-2006-005 CP-2 is removed from the Comprehensive Plan to the extent that it is not included in Docket No. D-2006-005 CP-3; and

b. Docket No. D-2006-005 CP-2 is terminated and replaced by Docket No. D-2006-005 CP-3; and

c. The project and the appurtenant facilities described in Section A “Physical Features” of this docket shall be continued in the Comprehensive Plan.

II. The project and appurtenant facilities as described in Section A “Physical Features” of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

a. Docket approval is subject to all conditions, requirements, and limitations imposed by the PADEP in its NPDES permit and such conditions, requirements, and limitations are incorporated herein, unless they are less stringent than the Commission’s.

b. The facility and operational records shall be available at all times for inspection by the DRBC.

c. The facility shall be operated at all times to comply with the requirements of the Commission’s *WQR*.

d. The docket holder shall comply with the requirements contained in the EFFLUENT TABLES in Section A.4.d. of this docket. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email aemr@drbc.nj.gov on the **Annual Effluent Monitoring Report Form** located at this web address: <http://www.state.nj.us/drbc/programs/project/application/index.html>. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations.

e. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.

f. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.

g. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.

h. The docket holder is permitted to treat and discharge wastewaters as set forth in the Area Served section of this docket, which incorporates by reference sections B (Type of Discharge) and D (Service Area) of the docket holder’s Application to the extent consistent with all other conditions of this DECISION section.

i. The docket holder shall make wastewater discharge in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.

j. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).

k. Nothing in this docket approval shall be construed as limiting the authority of DRBC to adopt and apply charges or other fees to this discharge or project.

l. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, in order to ensure proper control, use and management of the water resources of the Basin.

m. Unless an extension is requested and approved by the Commission in advance, in accordance with paragraph 11 of the Commission's Project Review Fee schedule (Resolution No. 2009-2), the docket holder is responsible for timely submittal of a docket renewal application on the appropriate DRBC application form at least 12 months in advance of the docket expiration date set forth below. The docket holder will be subject to late charges in the event of untimely submittal of its renewal application, whether or not DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. In the event that a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below (or the later date established by an extension that has been timely requested and approved), the terms and conditions of the current docket will remain fully effective and enforceable against the docket holder pending the grant or denial of the application for docket approval.

n. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.

o. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the Rules of Practice and Procedure. In accordance with Section 15.1(p) of the Delaware River Basin Compact, cases and controversies arising under the Compact are reviewable in the United States district courts.

p. The docket holder may request of the Executive Director in writing the substitution of specific conductance for TDS. The request should include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow the substitution of specific conductance for TDS monitoring.

q. Nothing in this docket constitutes a defense to any penalty action for past conduct of the docket holder or ongoing activity not authorized by this approval. In particular,

renewal of this docket does not resolve violations – whether in the past or continuing – of provisions of the Delaware River Basin Compact (“Compact”) or any rule, regulation, order or approval duly issued by the Commission or the Executive Director pursuant to the Compact. The Commission reserves its right to take appropriate enforcement action against the docket holder, including but not limited to recovery of financial penalties consistent with Section 14.17 of the Compact, for any and all such prior or continuing violations.

r. The docket holder is prohibited from treating/pre-treating any hydraulic fracturing wastewater from sources in or out of the Basin at this time. Should the docket holder wish to treat/pre-treat hydraulic fracturing wastewater in the future, the docket holder will need to first apply to the Commission to renew this docket and be issued a revised docket allowing such treatment and an expanded service area. Failure to obtain this approval prior to treatment/pre-treatment will result in action by the Commission.

BY THE COMMISSION

DATE APPROVED: March 16, 2016

EXPIRATION DATE: March 31, 2021