DOCKET NO. D-2014-015 CP-1

DELAWARE RIVER BASIN COMMISSION

Discharge to the Drainage Area of Special Protection Waters

Manchester Township Sewer and Water Authority, Inc. Reflection Lakes Wastewater Treatment Plant Manchester Township, Wayne County, Pennsylvania

PROCEEDINGS

This docket is issued in response to an Application submitted to the Delaware River Basin Commission (DRBC or Commission) by Reilly Associates on behalf of Manchester Township Sewer and Water Authority, Inc. (MTSWA or docket holder) on August 20, 2014 (Application), for approval of the docket holder's existing Reflection Lakes wastewater treatment plant (WWTP) and its discharge. Water Quality Management (WQM) Permit No. 6494402 for this facility was issued by the Pennsylvania Department of Environmental Resources (PADER), now Pennsylvania Department of Environmental Protection (PADEP), on June 24, 1994.

The Application was reviewed for inclusion of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Wayne County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on March 10, 2015.

A. DESCRIPTION

- 1. <u>Purpose</u>. The purpose of this docket is to approve the docket holder's existing 0.045 million gallons per day (mgd) WWTP and its discharge.
- **Location**. The WWTP will continue to land discharge treated effluent via a spray field in the Equinunk Creek Watershed, within the drainage area to the Upper Delaware Special Protection Waters (SPW), in the Manchester Township, Wayne County, Pennsylvania as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
Spray Field	41° 48' 14"	75° 12' 57"

3. <u>Area Served</u>. The docket holder's WWTP will continue to serve a portion of Manchester Township, Wayne County, Pennsylvania. For the purpose of defining the Area Served, Section B (Type of Discharge) and D (Service Area) of the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in the DECISION Section of this docket.

4. Physical Features.

- **a.** <u>Design Criteria</u>. The docket holder will continue to operate its existing 0.045 mgd WWTP. The treatment plant is a no discharge system utilizing spray irrigation of the effluent onto forestland. The permitted spray season is May 1 to October 31. Effluent generated from November through April is stored in a 2.67 million gallon effluent storage pond and sprayed during the appropriate season.
- **b.** <u>Facilities</u>. The WWTP consists of an influent pump station, an aerated lagoon, a chlorine contact tank, an effluent storage pond, and a spray irrigation system.

The docket holder's wastewater treatment facility discharges to waters classified as SPW and is required to have available emergency power. The existing WWTP has a generator installed capable of providing emergency power.

The docket holder's wastewater treatment facility is not staffed 24 hours per day, and shall have a remote alarm system that continuously monitors plant operations in accordance with the Commission's SPW requirements. The existing WWTP has a remote alarm system installed that continuously monitors plant operations.

The docket holder's existing wastewater treatment facility has prepared and implemented an emergency management plan (EMP) in accordance with Commission SPW requirements.

The project facilities are not located in the 100-year floodplain.

Wasted sludge will continue to be hauled off-site by a licensed hauler for disposal at a state-approved facility.

- **c.** <u>Water withdrawals</u>. The potable water supply in the project service area is supplied by on-lot wells. The total withdraw of water is less than 100,000 gallons per day as a 30-day average and is not required to have Commission approval.
- **d.** <u>WQM Permit / DRBC Docket</u>. WQM Permit No. 6494402 was issued by the PADER (now PADEP) on June 24, 1994 and includes final effluent limitations for the project discharge of 0.045 mgd to a spray field. The following average monthly effluent limits are among those listed in the WQM Permit and meet or are more stringent than the effluent requirements of the DRBC.

Spray Field			
PARAMETER	LIMIT	MONITORING	
pH (Standard Units)	6 to 9	As required by WQM Permit	
Total Suspended Solids	30 mg/l	As required by WQM Permit	
CBOD ₅ (at 20° C)	25 mg/l	As required by WQM Permit	
Fecal Coliform	200 colonies per 100 ml as a geo.	As required by WQM Permit	
	avg.		

EFFLUENT TABLE A-1: DRBC Parameters Included in WQM Permit

- e. <u>Cost</u>. There are no construction costs associated with this existing WWTP.
- **f.** Relationship to the Comprehensive Plan. Issuance of this docket will include the docket holder's 0.045 mgd WWTP in the Comprehensive Plan (See DECISION Condition I.c.).

B. <u>FINDINGS</u>

The purpose of this docket is to approve the docket holder's existing 0.045 mgd WWTP and its discharge.

In 1992, the DRBC adopted SPW requirements, as part of the DRBC *Water Quality Regulations* (*WQR*), designed to protect existing high water quality in applicable areas of the Delaware River Basin. One hundred twenty miles of the Delaware River from Hancock, New York downstream to the Delaware Water Gap has been classified by the DRBC as SPW. This stretch includes the sections of the river federally designated as "Wild and Scenic" in 1978 -- the Upper Delaware Scenic and Recreational River and the Delaware Water Gap National Recreation Area -- as well as an eight-mile reach between Milrift and Milford, Pennsylvania which is not federally designated. The SPW regulations apply to this 120-mile stretch of the river and its drainage area.

On July 16, 2008, the DRBC approved amendments to its *WQR* that provide increased protection for waters that the Commission classifies as SPW. The portion of the Delaware River and its tributaries within the boundary of the Lower Delaware River Management Plan Area was approved for SPW designation and clarity on definitions and terms were updated for the entire program.

Article 3.10.3A.2.e.1). and 2). of the Commission's WQR states that projects subject to review under Section 3.8 of the Compact that are located in the drainage area of SPW must submit for approval a Non-Point Source Pollution Control Plan (NPSPCP) that controls the new or increased non-point source loads generated within the portion of the docket holder's service area which is also located within the drainage area of SPW. The service area of the docket holder is located within in the drainage area to the SPW. Since this project does not entail additional construction and expansion of facilities/service area (i.e., there are not any new or increased non-point source loads associated with this approval), the NPSPCP requirement is not

applicable at this time. Accordingly, DECISION Conditions II.m. and II.r. have been included in this docket.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the WQM Permit are in compliance with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge meeting the effluent requirements as set forth in the Commission's WQR.

C. DECISION

- I. Effective on the approval date for Docket No. D-2014-015 CP-1 below, the project and the appurtenant facilities described in Section A "Physical Features" of this docket shall be added to the Comprehensive Plan.
- II. The project and appurtenant facilities as described in Section A "Physical Features" of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:
- a. Docket approval is subject to all conditions, requirements, and limitations imposed by the PADEP in its WQM Permit, and such conditions, requirements, and limitations are incorporated herein, unless they are less stringent than the Commission's.
- b. The facility and operational records shall be available at all times for inspection by the DRBC.
- c. The facility shall be operated at all times to comply with the requirements of the Commission's WQR.
- d. The docket holder shall comply with the requirements contained in the EFFLUENT TABLE in Section A.4.d. of this docket. The docket holder shall submit the required monitoring results <u>electronically</u> to the DRBC Project Review Section via email <u>aemr@drbc.state.nj.us</u> on the **Annual Effluent Monitoring Report Form** located at this web address: http://www.state.nj.us/drbc/programs/project/application/index.html. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations.
- e. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a

docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.

- f. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.
- g. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.
- h. The docket holder is permitted to treat and discharge wastewaters as set forth in the Area Served Section of this docket, which incorporates by reference Sections B (Type of Discharge) and D (Service Area) of the docket holder's Application to the extent consistent with all other conditions of this DECISION Section.
- i. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.
- j. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).
- k. Nothing in this docket approval shall be construed as limiting the authority of DRBC to adopt and apply charges or other fees to this discharge or project.
- 1. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, in order to ensure proper control, use and management of the water resources of the Basin.
- m. Prior to allowing connections from any new service areas or any new developments, the docket holder shall either submit and have approved by the Executive Director of the DRBC a NPSPCP in accordance with Section 3.10.3.A.2.e, or receive written confirmation from the Executive Director of the DRBC that the new service area is in compliance with a DRBC approved NPSPCP.
- n. Unless an extension is requested and approved by the Commission in advance, in accordance with paragraph 11 of the Commission's Project Review Fee schedule (Resolution No. 2009-2), the docket holder is responsible for timely submittal of a docket renewal application on the appropriate DRBC application form at least 12 months in advance of the docket expiration date set forth below. The docket holder will be subject to late charges in the event of untimely submittal of its renewal application, whether or not DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. In the event that a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below (or the later date established by an extension that has been timely requested and

approved), the terms and conditions of the current docket will remain fully effective and enforceable against the docket holder pending the grant or denial of the application for docket approval.

- o. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.
- p. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the Rules of Practice and Procedure. In accordance with Section 15.1(p) of the Delaware River Basin Compact, cases and controversies arising under the Compact are reviewable in the United States district courts.
- q. The docket holder is prohibited from treating/pre-treating any hydraulic fracturing wastewater from sources in or out of the Basin at this time. Should the docket holder wish to treat/pre-treat hydraulic fracturing wastewater in the future, the docket holder will need to first apply to the Commission to renew this docket and be issued a revised docket allowing such treatment and an expanded service area. Failure to obtain this approval prior to treatment/pre-treatment will result in action by the Commission.
- r. Prior to the docket holder initiating any substantial alterations or additions to the existing WWTP as defined in Section 3.10.3A2.a.16) of the Commission's WQR, an application must be submitted and approved by the Commission. Such an application shall be submitted prior to final design to ensure that the Commission can provide the docket holder with draft effluent limitations for SPW specific parameters as guidance for design as to not require duplication of work or cause a substantial expenditure of public funds without Commission approval. The docket holder is encouraged to contact the Commission staff during the planning stages to identify the potential effluent limitations required to meet the no measurable change parameters under SPW.

BY THE COMMISSION

DATE APPROVED: March 11, 2015

EXPIRATION DATE: March 11, 2025