

DOCKET NO. D-2009-027 CP-2

DELAWARE RIVER BASIN COMMISSION

Discharge to a Tributary of Special Protection Waters

**Wallenpaupack Area School District
Wastewater Treatment Plant Renewal
Dreher Township, Wayne County, Pennsylvania**

PROCEEDINGS

This docket is issued in response to an Application submitted to the Delaware River Basin Commission (DRBC or Commission) by Prosser Laboratories on behalf of Wallenpaupack Area School District (WASD or docket holder) on February 27, 2013 (Application), for renewal of the docket holder's existing wastewater treatment plant (WWTP) and its related discharge. National Pollutant Discharge Elimination System (NPDES) Permit No. PA0061654 for this facility was issued by the Pennsylvania Department of Environmental Protection (PADEP) on February 10, 2009, effective March 1, 2009.

The Application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact (Compact)*. The Wayne County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on March 11, 2014.

A. DESCRIPTION

1. Purpose. The purpose of this docket is to renew approval of the docket holder's existing Newfoundland WWTP and its related discharge. The permitted flow rate from the previous DRBC approval for the facility (D-2009-027 CP-1) is being reduced from 0.1 million gallon per day (mgd) to 0.01 mgd as a result of the docket holder indicating in the Application that the facility is hydraulically designed for a flow rate is 0.01 mgd. There are no modifications to the existing WWTP proposed.

2. Location. The project WWTP is located off of Main Street just north of its intersection with Crestmont Drive in Dreher Township, Wayne County, Pennsylvania. The WWTP will continue to discharge to Wallenpaupack Creek upstream of Lake Wallenpaupack, which is tributary to the Lackawaxen River, at River Mile 277.7– 15.8 – 1.4 – 12.7 – 7.8 (Delaware River – Lackawaxen River – Wallenpaupack Creek – Lake Wallenpaupack – Wallenpaupack Creek) in the drainage area to the Upper Delaware Special Protection Waters (SPW) area.

The project outfall is located in Lackawaxen River Watershed as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
001	41° 18' 32"	75° 18' 56"

3. **Area Served.** The docket holder's WWTP will continue to serve the WASD Newfoundland Elementary School and a local bank, located in Dreher Township, Wayne County, Pennsylvania.

For the purpose of defining the Area Served, Section B (Type of Discharge) and D (Service Area) of the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in the DECISION Section of this docket.

4. **Physical features.**

a. **Design criteria.** The docket holder's existing WWTP will continue to utilize an extended aeration activated sludge treatment process with tertiary sand filtration, chlorine disinfection, and post aeration. The docket indicated in the Application that the WWTP is hydraulically designed to treat 0.01 mgd. NPDES Permit No. PA0061654 indicates that the effluent limits included in the permit were determined using a discharge rate of 0.10 mgd. According to PADEP, this is because docket holder has PADEP planning approval up to 0.1 mgd. However, the docket holder submitted a DRBC docket renewal application and a NPDES permit renewal application indicating a hydraulic design flow of 0.01 mgd. Therefore, this docket approves a flow up to 0.01 mgd.

b. **Facilities.** The existing WWTP facilities consist of a flow equalization tank, flow splitter, aeration tank and clarifier, sand filter, chlorine contact and post aeration tank, and effluent pumping. The WWTP also features a sludge holding tank.

The docket holder's WWTP discharges to waters classified as SPW and is required to have available emergency power. The existing WWTP has an emergency generator installed capable of providing emergency power. (SPW)

The docket holder's wastewater treatment facility is not staffed 24 hours per day, and shall have a remote alarm system that continuously monitors plant operations in accordance with the Commission's SPW requirements. The existing WWTP has a remote alarm system installed that continuously monitors plant operations. (SPW)

The docket holder's existing wastewater treatment facility has not prepared and implemented an emergency management plan (EMP) in accordance with Commission SPW requirements. The docket holder is required as part of this docket approval to prepare and implement an EMP within three (3) months of approval of this docket (See DECISION Condition II.m.) (SPW)

The docket holder's existing wastewater treatment facility does not discharge to Outstanding Basin Waters (OBW), and is not required to have a nonvisible discharge plume. (SPW)

The project facilities are not located in the 100-year floodplain.

Wasted sludge will continue to be hauled off-site by a licensed hauler for disposal at a (State-approved) facility.

c. **Water withdrawals.** The potable water supply in the project service area is provided by: 1) one well for the Newfoundland School owned by WASD and 2) one well owned by the local bank. Both wells are operated at withdrawal rates below the DRBC review threshold, and as such, do not require Commission approval.

d. **NPDES Permit / DRBC Docket.** PADEP issued NPDES Permit No. PA0061654 for the project discharge on February 10, 2009, which includes final effluent limitations for the project discharge to surface waters classified by the PADEP as High Quality – Cold Water Fishery (HQ-CWF). The following average monthly effluent limits are among those listed in the NPDES permit that meet or are more stringent than the effluent requirements of the DRBC. The NPDES permit indicates that these effluent limits were determined using a discharge rate of 0.10 mgd, however, the docket holder submitted a docket renewal application and a NPDES permit renewal application indicating a hydraulic design flow of 0.01 mgd.

EFFLUENT TABLE A-1: DRBC Parameters Included in NPDES permit

OUTFALL 001 (Wallenpaupack Creek)		
PARAMETER	LIMIT	MONITORING
pH (Standard Units)	6 to 9 at all times	As required by NPDES permit
Total Suspended Solids	30 mg/l	As required by NPDES permit
CBOD (5-Day at 20° C)	(5/1 to 10/31) 20 mg/l (85% minimum removal*)	As required by NPDES permit
	(11/1 to 4/30) 25 mg/l (85% minimum removal*)	
Ammonia-Nitrogen	(5/1 to 10/31) 3 mg/l	As required by NPDES permit
	(11/1 to 4/30) 9 mg/l	
Fecal Coliform	(5/1 to 9/30) 200 colonies per 100 ml as a geo. avg.	As required by NPDES permit
	(10/1 to 4/30) 2000 colonies per 100 ml as a geo. avg.	
Dissolved Oxygen	5.0 mg/l (minimum at all times)	As required by NPDES permit
Total Phosphorous	0.5 mg/l	As required by NPDES permit

* DRBC Requirement

EFFLUENT TABLE A-2: DRBC Parameters Not Included in NPDES permit

OUTFALL 001 (Wallenpaupack Creek)		
PARAMETER	LIMIT	MONITORING
Total Dissolved Solids *	1,000 mg/l	One Per quarter

* See Condition II.q.

e. **Relationship to the Comprehensive Plan.** The existing WWTP was included in the Comprehensive Plan by Docket No. D-2009-027 CP-1 on July 14, 2010.

B. FINDINGS

The purpose of this docket is to renew the approval of the existing WASD Newfoundland WWTP. The permitted flow rate from the previous DRBC approval for the facility (D-2009-027 CP-1) is being reduced from 0.1 mgd to 0.01 mgd as a result of the docket holder indicating in the Application that the design flow rate is 0.01 mgd. Docket No. D-2009-027 CP-1 approved a flow rate of 0.1 mgd since NPDES Permit No. PA0061654 indicates that the effluent limits included in the permit were determined using a discharge rate of 0.10 mgd. According to PADEP, this is because docket holder has PADEP planning approval up to 0.1 mgd. However, the docket holder submitted a DRBC docket renewal application and a NPDES permit renewal application indicating a hydraulic design flow of 0.01 mgd. Therefore, this docket approves a flow up to 0.01 mgd.

There are no modifications to the existing WWTP proposed.

In 1992, the DRBC adopted SPW requirements, as part of the DRBC *Water Quality Regulations (WQR)*, designed to protect existing high water quality in applicable areas of the Delaware River Basin. One hundred twenty miles of the Delaware River from Hancock, New York downstream to the Delaware Water Gap has been classified by the DRBC as SPW. This stretch includes the sections of the river federally designated as "Wild and Scenic" in 1978 -- the Upper Delaware Scenic and Recreational River and the Delaware Water Gap National Recreation Area -- as well as an eight-mile reach between Milrift and Milford, Pennsylvania which is not federally designated. The SPW regulations apply to this 120-mile stretch of the river and its drainage area. (Upper/Middle SPW)

On July 16, 2008, the DRBC approved amendments to its *WQR* that provide increased protection for waters that the Commission classifies as SPW. The portion of the Delaware River and its tributaries within the boundary of the Lower Delaware River Management Plan Area was approved for SPW designation and clarity on definitions and terms were updated for the entire program. (Upper/Middle SPW)

Section 3.10.3A.2.e. of the *WQR* states that projects subject to review under Section 3.8 of the Compact that are located in the drainage area of Special Protection Waters must submit for approval a Non-Point Source Pollution Control Plan (NPSPCP) that controls the new or increased non-point source loads generated within the portion of the applicant's service area which is also located within the drainage area of Special Protection Waters. The service area of the WASD Newfoundland WWTP is located within in the drainage area to the Special Protection Waters. However, in accordance with Section 3.10.3A.2.e.1)(c), projects located above major surface water impoundments listed in Section 3.10.3A.2.g.5) are not required to meet the NPSPCP requirement because the time of travel and relevant hydraulic and limnological factors preclude a direct impact on Special Protection Waters. Lake Wallenpaupack is designated as a

major surface water impoundment in Section 3.10.3A.2.g.5), and therefore a NPSPCP is not required.

At the project site, the Wallenpaupack Creek has an estimated seven-day low flow with a recurrence interval of ten years of 1.5 mgd (2.3 cfs). The ratio of this low flow to the design wastewater discharge (0.01 mgd) from the project WWTP is approximately 150 to 1.

The nearest surface water intake of record for public water supply downstream of the project discharge is owned and operated by the City of Easton, which is located approximately 130 miles downstream from the docket holder's WWTP discharge.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit are in compliance with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge meeting the effluent requirements as set forth in the Commission's WQR.

C. DECISION

I. Effective on the approval date for Docket No. D-2009-027 CP-2 below:

a. The project described in Docket No. D-2009-027 CP-1 is removed from the Comprehensive Plan to the extent that it is not included in Docket No. D-2009-027 CP-2; and

b. Docket No. D-2009-027 CP-1 is terminated and replaced by Docket No. D-2009-027 CP-2.

c. The project and the appurtenant facilities described in the Section A "Physical Features" of this docket shall be continued in the Comprehensive Plan.

II. The project and appurtenant facilities as described in the Section A "Physical features" of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

a. Docket approval is subject to all conditions, requirements, and limitations imposed by the PADEP in its NPDES permit, and such conditions, requirements, and limitations are incorporated herein, unless they are less stringent than the Commission's.

b. The facility and operational records shall be available at all times for inspection by the DRBC.

c. The facility shall be operated at all times to comply with the requirements of the Commission's *WQR*.

d. The docket holder shall comply with the requirements contained in Effluent Tables in Section A.4.d. of this docket. The docket holder shall submit the required monitoring results directly to the DRBC Project Review Section. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations.

e. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.

f. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.

g. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.

h. The docket holder is permitted to treat and discharge wastewaters as set forth in the Area Served Section of this docket, which incorporates by reference Sections B (Type of Discharge) and D (Service Area) of the docket holder's Application to the extent consistent with all other conditions of this DECISION Section.

i. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.

j. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).

k. Nothing in this docket approval shall be construed as limiting the authority of DRBC to adopt and apply charges or other fees to this discharge or project.

l. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, in order to ensure proper control, use and management of the water resources of the Basin.

m. The docket holder shall submit an emergency management plan (EMP) within three (3) months of docket approval. The docket holder shall submit the EMP and certify in writing to the Commission that it has complied with this condition by June 12, 2014.

n. Unless an extension is requested and approved by the Commission in advance, in accordance with paragraph 11 of the Commission's Project Review Fee schedule (Resolution No. 2009-2), the docket holder is responsible for timely submittal of a docket renewal application on the appropriate DRBC application form at least 12 months in advance of the docket expiration date set forth below. The docket holder will be subject to late charges in the event of untimely submittal of its renewal application, whether or not DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. In the event that a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below (or the later date established by an extension that has been timely requested and approved), the terms and conditions of the current docket will remain fully effective and enforceable against the docket holder pending the grant or denial of the application for docket approval.

o. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.

p. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the Rules of Practice and Procedure. In accordance with Section 15.1(p) of the Delaware River Basin Compact, cases and controversies arising under the Compact are reviewable in the United States district courts.

q. The docket holder may request of the Executive Director in writing the substitution of specific conductance for TDS. The request should include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow the substitution of specific conductance for TDS monitoring.

r. Nothing in this docket constitutes a defense to any penalty action for past conduct of the docket holder or ongoing activity not authorized by this approval. In particular, renewal of this docket does not resolve violations – whether in the past or continuing – of provisions of the Delaware River Basin Compact ("Compact") or any rule, regulation, order or approval duly issued by the Commission or the Executive Director pursuant to the Compact. The Commission reserves its right to take appropriate enforcement action against the docket holder, including but not limited to recovery of financial penalties consistent with Section 14.17 of the Compact, for any and all such prior or continuing violations.

s. The docket holder is prohibited from treating/pre-treating any hydraulic fracturing wastewater from sources in or out of the Basin at this time. Should the docket holder wish to treat/pre-treat hydraulic fracturing wastewater in the future, the docket holder will need to first apply to the Commission to renew this docket and be issued a revised docket allowing

such treatment and an expanded service area. Failure to obtain this approval prior to treatment/pre-treatment will result in action by the Commission.

BY THE COMMISSION

DATE APPROVED: March 12, 2014

EXPIRATION DATE: March 12, 2019