

DOCKET NO. D-2013-010 CP-1

DELAWARE RIVER BASIN COMMISSION

Discharge to a Tributary of Special Protection Waters

**Pine Forest Camp, Inc.
Wastewater Treatment Plant
Lackawaxen Township, Pike County, Pennsylvania**

PROCEEDINGS

This docket is issued in response to an Application submitted to the Delaware River Basin Commission (DRBC or Commission) by Environmental Engineering & Management Associates, Inc. on behalf of Pine Forest Camp, Inc. (PFC or docket holder) on August 2, 2013 (Application), for approval of the docket holder's existing wastewater treatment plant (WWTP) and its related discharge. National Pollutant Discharge Elimination System (NPDES) Permit No. PA0029050 for this facility was issued by the Pennsylvania Department of Environmental protection (PADEP) on December 4, 2008, effective January 1, 2009. Renewal of the NPDES Permit is expected shortly.

The Application was reviewed for inclusion of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Pike County Planning Board has been notified of pending action. A public hearing on this project was held by the DRBC on March 11, 2014.

A. DESCRIPTION

- Purpose.** The purpose of this docket is to approve the docket holder's existing 0.025 million gallons per day (mgd) WWTP and its related discharge.
- Location.** The WWTP will continue to discharge treated effluent to an unnamed tributary (UNT) of Lake Greeley at River Mile 226.9 – 0.8 – 13.3 – 0.1 – 0.1 (Delaware River – Bush Kill – Little Bush Kill – Lake Greeley – UNT) via Outfall No. 001, within the drainage area to the Middle Delaware Special Protection Waters (SPW), in Lackawaxen Township, Pike County, Pennsylvania as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
001	41° 15' 00"	75° 00' 00"

3. **Area Served.** The docket holder's WWTP will continue to serve Pine Forest Camp located in Lackawaxen Township, Pike County, Pennsylvania. For the purpose of defining the Area Served, Section B (Type of Discharge) and D (Service Area) of the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in the DECISION Section of this docket.

4. **Physical Features.**

a. **Design Criteria.** The docket holder will continue to operate its existing 0.025 mgd WWTP.

b. **Facilities.** The WWTP consists of three (3) septic tanks, a first stage aeration lagoon, a second stage aeration lagoon, a chlorine contact tank, and a post aeration dechlorinator. Baking soda and ferric chloride are added to the wastestream before entering the first and second stage lagoons, respectively.

The docket holder's wastewater treatment facility discharges to waters classified as SPW and is required to have available emergency power. The docket holder is required as part of the continued discharge to install a generator capable of providing emergency power (See DECISION Condition II.n.).

The docket holder's wastewater treatment facility is not staffed 24 hours per day, and shall have a remote alarm system that continuously monitors plant operations. The docket holder is required as part of the continued discharge to install remote alarm systems (See DECISION Condition II.n.).

The docket holder's existing wastewater treatment facility has prepared an emergency management plan (EMP) in accordance with Commission requirements. However, the plan does not account for emergency power and remote alarm conditions/contacts and will need to be updated after these have been installed. The docket holder is required as part of this docket approval to prepare and implement a revised EMP within three (3) months of the installation of the emergency generator and remote alarm system (See DECISION Condition II.o.).

The project facilities are not located in the 100-year floodplain.

Wasted sludge will continue to be hauled off-site by a licensed hauler for disposal at a (State-approved) facility.

c. **Water withdrawals.** The potable water supply in the project service area is supplied by an on-site well that withdrawals less than an average of 100,000 gallons per day as a 30-day average and therefore does not require Commission approval.

d. **NPDES Permit / DRBC Docket.** NPDES Permit No. PA0029050 was issued by the PADEP on December 4, 2008 (effective January 1, 2009) and includes final effluent limitations for the project discharge of 0.025 mgd to surface waters classified by the PADEP as a

high quality, cold water fishery (HQ-CWF). Renewal of the NPDES Permit is expected shortly. The following average monthly effluent limits are among those listed in the NPDES Permit and meet or are more stringent than the effluent requirements of the DRBC.

EFFLUENT TABLE A-1: DRBC Parameters Included in NPDES Permit

OUTFALL 001 (WWTP)		
PARAMETER	LIMIT	MONITORING
pH (Standard Units)	6 to 9 at all times	As required by NPDES Permit
Total Suspended Solids	30 mg/l	As required by NPDES Permit
Dissolved Oxygen	7.0 mg/l (minimum at all times)	As required by NPDES Permit
CBOD ₅ (at 20° C)	10 mg/l	As required by NPDES Permit
Fecal Coliform (5-1 to 9-30)	200 colonies per 100 ml as a geo. avg.	As required by NPDES Permit
(10-1 to 4-30)	2000 colonies per 100 ml as a geo. avg.	
Phosphorus	1.0 mg/l	As required by NPDES Permit

The requirements in EFFLUENT TABLE A-2 are not listed in the NPDES Permit, but are Commission basin-wide and/or SPW specific parameters that must be met as a condition of this docket approval. Commission staff have requested PADEP include these parameters in their renewed Permit. Monitoring shall begin April 1, 2014 for each parameter (See DECISION Condition II.d.).

EFFLUENT TABLE A-2: DRBC Parameters Not Included in NPDES Permit

OUTFALL 001 (WWTP)		
PARAMETER	LIMIT	MONITORING
Total Dissolved Solids*	Monitor & Report	Quarterly *
CBOD ₅ (at 20° C)	85% minimum removal	Same as CBOD ₅ frequency in the NPDES Permit
Nitrate + Nitrite as N	Monitor & Report	Monthly
Total Kjeldahl Nitrogen	Monitor & Report	Monthly
Ammonia Nitrogen	Monitor & Report	Monthly

* See DECISION Condition II.s.

- e. **Cost.** There are no construction costs associated with this existing WWTP.
- f. **Relationship to the Comprehensive Plan.** Issuance of this docket will include the docket holder's existing 0.025 mgd WWTP in the Comprehensive Plan (See DECISION Condition I.).

B. FINDINGS

The purpose of this docket is to approve the docket holder's existing 0.025 mgd WWTP and its related discharge.

In 1992, the DRBC adopted SPW requirements, as part of the DRBC *Water Quality Regulations (WQR)*, designed to protect existing high water quality in applicable areas of the Delaware River Basin. One hundred twenty miles of the Delaware River from Hancock, New York downstream to the Delaware Water Gap has been classified by the DRBC as SPW. This stretch includes the sections of the river federally designated as "Wild and Scenic" in 1978 -- the Upper Delaware Scenic and Recreational River and the Delaware Water Gap National Recreation Area -- as well as an eight-mile reach between Milrift and Milford, Pennsylvania which is not federally designated. The SPW regulations apply to this 120-mile stretch of the river and its drainage area.

On July 16, 2008, the DRBC approved amendments to its *WQR* that provide increased protection for waters that the Commission classifies as SPW. The portion of the Delaware River and its tributaries within the boundary of the Lower Delaware River Management Plan Area was approved for SPW designation and clarity on definitions and terms were updated for the entire program.

Article 3.10.3A.2.e.1). and 2). of the Commission's *WQR* states that projects subject to review under Section 3.8 of the Compact that are located in the drainage area of SPW must submit for approval a Non-Point Source Pollution Control Plan (NPSPCP) that controls the new or increased non-point source loads generated within the portion of the docket holder's service area which is also located within the drainage area of SPW. The service area of the docket holder is located within in the drainage area to the SPW. Since this project does not entail additional construction and expansion of facilities/service area (i.e., there are not any new or increased non-point source loads associated with this approval), the NPSPCP requirement is not applicable at this time. Accordingly, DECISION Conditions II.m. and II.u. have been included in this docket.

Near the docket holder's WWTP discharge, the Little Bush Kill has an estimated seven-day low flow with a recurrence interval of ten years (Q_{7-10}) of 0.142 mgd (0.22 cfs). The ratio of this low flow to the hydraulic design wastewater discharge from the 0.025 mgd WWTP is 5.5 to 1.

The nearest surface water intake of record for public water supply is located approximately 47.5 River Miles downstream of the docket holder's WWTP on the Delaware River and is operated by the City of Easton.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit are in compliance with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge meeting the effluent requirements as set forth in the Commission's *Water Quality Regulations (WQR)*.

C. DECISION

I. Effective on the approval date for Docket No. D-2013-010 CP-1 below, the project and the appurtenant facilities described in Section A “Physical Features” of this docket shall be added to the Comprehensive Plan.

II. The project and appurtenant facilities as described in Section A “Physical Features” of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

a. Docket approval is subject to all conditions, requirements, and limitations imposed by the PADEP in its NPDES Permit, and such conditions, requirements, and limitations are incorporated herein, unless they are less stringent than the Commission’s.

b. The facility and operational records shall be available at all times for inspection by the DRBC.

c. The facility shall be operated at all times to comply with the requirements of the Commission’s *WQR*.

d. The docket holder shall comply with the requirements contained in the Effluent Tables in Section A.4.d. of this docket. The docket holder shall submit the required monitoring results directly to the DRBC Project Review Section. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations.

e. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.

f. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.

g. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.

h. The docket holder is permitted to treat and discharge wastewaters as set forth in the Area Served Section of this docket, which incorporates by reference Sections B (Type of Discharge) and D (Service Area) of the docket holder’s Application to the extent consistent with all other conditions of this DECISION Section.

i. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.

j. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).

k. Nothing in this docket approval shall be construed as limiting the authority of DRBC to adopt and apply charges or other fees to this discharge or project.

l. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, in order to ensure proper control, use and management of the water resources of the Basin.

m. Prior to allowing connections from any new service areas or any new developments, the docket holder shall either submit and have approved by the Executive Director of the DRBC a NPSPCP in accordance with Section 3.10.3.A.2.e, or receive written confirmation from the Executive Director of the DRBC that the new service area is in compliance with a DRBC approved NPSPCP.

n. The docket holder shall provide for emergency power and install remote alarm controls within twelve (12) months of docket approval (by March 12, 2015). Written verification shall be submitted to the Executive Director within thirty (30) days of completion informing the Commission when these two provisions have been met (by April 11, 2015).

o. The docket holder shall prepare and implement a revised EMP following the installation of an emergency generator and remote alarm controls. The docket holder shall submit the revised EMP to the Executive Director and certify in writing to the Commission that it has complied with this condition within three (3) months of the completed work (by June 12, 2015).

p. Unless an extension is requested and approved by the Commission in advance, in accordance with paragraph 11 of the Commission's Project Review Fee schedule (Resolution No. 2009-2), the docket holder is responsible for timely submittal of a docket renewal application on the appropriate DRBC application form at least 12 months in advance of the docket expiration date set forth below. The docket holder will be subject to late charges in the event of untimely submittal of its renewal application, whether or not DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. In the event that a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below (or the later date established by an extension that has been timely requested and approved), the terms and conditions of the current docket will remain fully effective and enforceable against the docket holder pending the grant or denial of the application for docket approval.

q. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive

Director's judgment such modification or suspension is required to protect the water resources of the Basin.

r. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the Rules of Practice and Procedure. In accordance with Section 15.1(p) of the Delaware River Basin Compact, cases and controversies arising under the Compact are reviewable in the United States district courts.

s. The docket holder may request of the Executive Director in writing the substitution of specific conductance for TDS. The request should include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow the substitution of specific conductance for TDS monitoring.

t. The docket holder is prohibited from treating/pre-treating any hydraulic fracturing wastewater from sources in or out of the Basin at this time. Should the docket holder wish to treat/pre-treat hydraulic fracturing wastewater in the future, the docket holder will need to first apply to the Commission to renew this docket and be issued a revised docket allowing such treatment and an expanded service area. Failure to obtain this approval prior to treatment/pre-treatment will result in action by the Commission.

u. Prior to the docket holder initiating any substantial alterations or additions to the existing WWTP as defined in Section 3.10.3A2.a.16) of the Commission's *WQR*, an application must be submitted and approved by the Commission. Such an application shall be submitted prior to final design to ensure that the Commission can provide the docket holder with draft effluent limitations for SPW specific parameters as guidance for design as to not require duplication of work or cause a substantial expenditure of public funds without Commission approval. The docket holder is encouraged to contact the Commission staff during the planning stages to identify the potential effluent limitations required to meet the no measurable change parameters under SPW.

BY THE COMMISSION

DATE APPROVED: March 12, 2014

EXPIRATION DATE: January 31, 2019