

**DOCKET NO. D- D-1974-057 CP-4**

**DELAWARE RIVER BASIN COMMISSION**

**Discharge to a Tributary of Special Protection Waters**

**Village of Deposit**

**Wastewater Treatment Plant**

**Village of Deposit, Broome and Delaware Counties, New York**

**PROCEEDINGS**

This docket is issued in response to an Application submitted to the Delaware River Basin Commission (DRBC or Commission) by the Village of Deposit (docket holder) on April 29, 2015 (Application), for renewal of the docket holder's existing wastewater treatment plant (WWTP) and its discharge. State Pollutant Discharge Elimination System (SPDES) Permit No. NY0029211 for this project was issued by the New York State Department of Environmental Conservation (NYSDEC) on January 7, 2016.

The Application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Broome and Delaware County Planning Boards have been notified of pending action. A public hearing on this project was held by the DRBC on May 11, 2016.

**A. DESCRIPTION**

- 1. Purpose.** The purpose of this docket is to renew approval of the docket holder's existing 0.7 million gallons per day (mgd) WWTP and its discharge.
- 2. Location.** The WWTP discharge will continue to discharge treated effluent to the West Branch Delaware River at River Mile 330.71 – 14.5 (Delaware River – West Branch Delaware River) via Outfall No. 001, within the drainage area to the Upper Delaware Special Protection Waters (SPW), in the Village of Deposit, Broome County, New York as follows:

<b>OUTFALL NO.</b>	<b>LATITUDE (N)</b>	<b>LONGITUDE (W)</b>
001	42° 03' 26"	75° 25' 26"

- 3. Area Served.** The docket holder's WWTP will continue to serve the Village of Deposit and a portion of the Town of Deposit, located in Broome and Delaware Counties, New York.

The WWTP also accepts domestic septage from haulers from both within and outside of the Service Area. For the purpose of defining the Area Served, Section B (Type of Discharge) and D (Service Area) of the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in the DECISION Section of this docket.

#### 4. Physical Features.

a. Design Criteria. The docket holder will continue to operate its existing 0.7 mgd WWTP.

b. Facilities. The existing WWTP consists of a spiral screen, comminutors, an aerated grit chamber, two (2) multi-zone aeration/clarification tanks, two (2) secondary clarifiers, an aerobic digester, belt filter press, a sludge processing tank, and an ultraviolet disinfection unit.

The docket holder's wastewater treatment facility discharges to waters classified as SPW and is required to have available standby power. The existing WWTP has a generator installed capable of providing standby power.

The docket holder's wastewater treatment facility is not staffed 24 hours per day, and shall have a remote alarm system that continuously monitors plant operations in accordance with the Commission's SPW requirements. The existing WWTP has a remote alarm system installed that continuously monitors plant operations.

The docket holder's existing wastewater treatment facility has prepared and implemented an emergency management plan (EMP) in accordance with Commission SPW requirements.

Portions of the project facilities are located in the 100-year floodplain. The docket holder has flood-proofed the facilities at least one (1) foot above the 100-year flood elevation.

Wasted sludge will continue to be hauled off-site by a licensed hauler for disposal at a state approved facility.

c. Water withdrawals. The potable water supply in the project service area is provided by the docket holder's distribution system. The groundwater wells associated with this system are described in detail in Docket No. D-1999-064 CP-2, which was approved by the Commission on March 7, 2012.

d. SPDES Permit / DRBC Docket. SPDES Permit No. NY0029211 was issued by the NYSDEC on January 7, 2016 (effective May 1, 2016) and includes effluent limitations for the project discharge of 0.7 mgd to surface waters classified by the NYSDEC as a Trout Maintenance and Propagation Stream [B(T)]. The following average monthly effluent limits are among those listed in the SPDES Permit and meet or are more stringent than the effluent requirements of the DRBC.

**EFFLUENT TABLE A-1: DRBC Parameters Included in SPDES Permit**

<b>OUTFALL 001 (WWTP)</b>		
<b>PARAMETER</b>	<b>LIMIT</b>	<b>MONITORING</b>
pH (Standard Units)	6 to 9 at all times	As required by SPDES Permit
Total Suspended Solids	30 mg/l	As required by SPDES Permit
Dissolved Oxygen	4.0 mg/l (minimum at all times)	As required by SPDES Permit
CBOD <sub>5</sub> (at 20° C)	30 mg/l (85% minimum removal*)	As required by SPDES Permit
Ammonia Nitrogen	12 mg/l	As required by SPDES Permit
Fecal Coliform	200 colonies per 100 ml as a geometric mean.	As required by SPDES Permit

\* DRBC Requirement

The requirements in EFFLUENT TABLE A-2 are not listed in the SPDES Permit, but are Commission basin-wide and/or SPW specific parameters that must be met as a condition of this docket approval.

**EFFLUENT TABLE A-2: DRBC Parameters Not Included in SPDES Permit**

<b>OUTFALL 001 (WWTP)</b>		
<b>PARAMETER</b>	<b>LIMIT</b>	<b>MONITORING</b>
Total Dissolved Solids*	1,000 mg/l *	One Per Quarter **
Phosphorous*	Monitor & Report *	Monthly*
Nitrate + Nitrite as Nitrogen*	Monitor & Report *	Monthly*
Total Kjeldahl Nitrogen (TKN)*	Monitor & Report *	Monthly*

\* DRBC Requirement

\*\* See DECISION Condition II.s.

e. **Cost.** There are no construction costs associated with this WWTP renewal.

f. **Relationship to the Comprehensive Plan.** The 0.4 mgd Village of Deposit WWTP was originally included in the Comprehensive Plan on October 30, 1974 via DRBC Docket No. D-74-57 CP. The expansion to 0.7 mgd was included in the Comprehensive Plan upon approval of Docket No. D-74-57 CP-2 on December 12, 2006. Approval of this docket will continue the 0.7 mgd Village of Deposit WWTP in the Comprehensive Plan (See DECISION Condition I.c.).

## **B. FINDINGS**

The purpose of this docket is to renew approval of the docket holder's existing 0.7 million gallons per day (mgd) WWTP and its discharge.

In 1992, the DRBC adopted SPW requirements, as part of the DRBC *Water Quality Regulations (WQR)*, designed to protect existing high water quality in applicable areas of the Delaware River Basin. One hundred twenty miles of the Delaware River from Hancock, New York downstream to the Delaware Water Gap has been classified by the DRBC as SPW. This stretch includes the sections of the river federally designated as "Wild and Scenic" in 1978 -- the Upper Delaware Scenic and Recreational River and the Delaware Water Gap National Recreation Area -- as well as an eight-mile reach between Milrift and Milford, Pennsylvania which is not federally designated. The SPW regulations apply to this 120-mile stretch of the river and its drainage area. (Upper/Middle SPW)

On July 16, 2008, the DRBC approved amendments to its *WQR* that provide increased protection for waters that the Commission classifies as SPW. The portion of the Delaware River and its tributaries within the boundary of the Lower Delaware River Management Plan Area was approved for SPW designation and clarity on definitions and terms were updated for the entire program. (Upper/Middle SPW)

Article 3.10.3A.2.e.1). and 2). of the Commission's *WQR* states that projects subject to review under Section 3.8 of the Compact that are located in the drainage area of SPW must submit for approval a Non-Point Source Pollution Control Plan (NPSPCP) that controls the new or increased non-point source loads generated within the portion of the docket holder's service area which is also located within the drainage area of SPW. The service area of the docket holder is located within in the drainage area to the SPW. Since this project does not entail additional construction and expansion of facilities/service area and there are not any new or increased non-point source loads associated with this approval, the NPSPCP requirement is not applicable at this time. Accordingly, DECISION Condition II.o. has been included in this docket.

Near the docket holder's WWTP discharge, the West Branch Delaware River has an estimated seven-day low flow with a recurrence interval of ten years ( $Q_{7-10}$ ) of 34.3 mgd (53.1 cfs). The ratio of this low flow to the hydraulic design wastewater discharge from the 0.7 mgd WWTP is 49 to 1.

The nearest surface water intake of record for public water supply is located on the Delaware River approximately 160 River Miles downstream of the docket holder's WWTP, and is operated by the City of Easton.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the SPDES Permit are in compliance with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge meeting the effluent requirements as set forth in the Commission's *Water Quality Regulations (WQR)* and *Flood Plain Regulations (FPR)*.

**C. DECISION**

I. Effective on the approval date for Docket No. D-1974-057 CP-4 below:

a. The project described in Docket No. D-1974-057 CP-3 is removed from the Comprehensive Plan to the extent that it is not included in Docket No. D-1974-057 CP-4; and

b. Docket No. D-1974-057 CP-3 is terminated and replaced by Docket No. D-1974-057 CP-4; and

c. The project and the appurtenant facilities described in Section A “Physical Features” of this docket shall be continued in the Comprehensive Plan.

II. The project and appurtenant facilities as described in Section A “Physical Features” of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

a. Docket approval is subject to all conditions, requirements, and limitations imposed by the NYSDEC in its SPDES Permit, and such conditions, requirements, and limitations are incorporated herein, unless they are less stringent than the Commission’s.

b. The facility and operational records shall be available at all times for inspection by the DRBC.

c. The facility shall be operated at all times to comply with the requirements of the Commission’s *WQR* and Flood Plain Regulations (*FPR*).

d. The docket holder shall comply with the requirements contained in the EFFLUENT TABLES in Section A.4.d. of this docket. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email [aemr@drbc.state.nj.us](mailto:aemr@drbc.state.nj.us) on the **Annual Effluent Monitoring Report Form** located at this web address: <http://www.state.nj.us/drbc/programs/project/pr/info.html>. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations.

e. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.

f. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.

g. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.

h. The discharge of wastewater shall not increase the ambient temperatures of the receiving waters by more than 5°F until stream temperatures reach 50°F, nor by more than 2°F when stream temperatures are between 50°F and 58°F, nor shall such discharge result in stream temperatures exceeding 58°F. (Trout Waters only)

i. Sound practices of excavation, backfill and reseedling shall be followed to minimize erosion and deposition of sediment in streams.

j. The docket holder is permitted to treat and discharge wastewaters as set forth in the Area Served Section of this docket, which incorporates by reference Sections B (Type of Discharge) and D (Service Area) of the docket holder's Application to the extent consistent with all other conditions of this DECISION Section.

k. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.

l. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).

m. Nothing in this docket approval shall be construed as limiting the authority of DRBC to adopt and apply charges or other fees to this discharge or project.

n. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, in order to ensure proper control, use and management of the water resources of the Basin.

o. Prior to allowing connections from any new service areas or any new developments, the docket holder shall either submit and have approved by the Executive Director of the DRBC a NPSPCP in accordance with Section 3.10.3.A.2.e, or receive written confirmation from the Executive Director of the DRBC that the new service area is in compliance with a DRBC approved NPSPCP.

p. Unless an extension is requested and approved by the Commission in advance, in accordance with paragraph 11 of the Commission's Project Review Fee schedule (Resolution No. 2009-2), the docket holder is responsible for timely submittal of a docket renewal application on the appropriate DRBC application form at least 12 months in advance of the docket expiration date set forth below. The docket holder will be subject to late charges in

the event of untimely submittal of its renewal application, whether or not DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. In the event that a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below (or the later date established by an extension that has been timely requested and approved), the terms and conditions of the current docket will remain fully effective and enforceable against the docket holder pending the grant or denial of the application for docket approval.

q. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.

r. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the Rules of Practice and Procedure. In accordance with Section 15.1(p) of the Delaware River Basin Compact, cases and controversies arising under the Compact are reviewable in the United States district courts.

s. The docket holder may request of the Executive Director in writing the substitution of specific conductance for TDS. The request should include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow the substitution of specific conductance for TDS monitoring.

t. Nothing in this docket constitutes a defense to any penalty action for past conduct of the docket holder or ongoing activity not authorized by this approval. In particular, renewal of this docket does not resolve violations – whether in the past or continuing – of provisions of the Delaware River Basin Compact (“Compact”) or any rule, regulation, order or approval duly issued by the Commission or the Executive Director pursuant to the Compact. The Commission reserves its right to take appropriate enforcement action against the docket holder, including but not limited to recovery of financial penalties consistent with Section 14.17 of the Compact, for any and all such prior or continuing violations.

u. The docket holder is prohibited from treating/pre-treating any hydraulic fracturing wastewater from sources in or out of the Basin at this time. Should the docket holder wish to treat/pre-treat hydraulic fracturing wastewater in the future, the docket holder will need to first apply to the Commission to renew this docket and be issued a revised docket allowing such treatment and an expanded service area. Failure to obtain this approval prior to treatment/pre-treatment will result in action by the Commission.

v. Prior to the docket holder initiating any substantial alterations or additions to the existing WWTP as defined in Section 3.10.3A2.a.16) of the Commission's *WQR*, an application must be submitted and approved by the Commission. Such an application shall be submitted prior to final design to ensure that the Commission can provide the docket holder with draft effluent limitations for SPW specific parameters as guidance for design as to not require duplication of work or cause a substantial expenditure of public funds without Commission approval. The docket holder is encouraged to contact the Commission staff during the planning

stages to identify the potential effluent limitations required to meet the no measurable change parameters under SPW.

**BY THE COMMISSION**

**DATE APPROVED: June 15, 2016**

**EXPIRATION DATE: April 30, 2021**