#### DOCKET NO. D-2015-007 CP-1

#### **DELAWARE RIVER BASIN COMMISSION**

## **Discharge to Special Protection Waters**

Pennsylvania Historical & Museum Commission Washington Crossing Historic Park Upper Wastewater Treatment Plant Solebury Township, Bucks County, Pennsylvania

#### **PROCEEDINGS**

This docket is issued in response to an Application submitted to the Delaware River Basin Commission (DRBC or Commission) by SSM Group, Inc. on behalf of the Pennsylvania Historical & Museum Commission (PHMC or docket holder) on April 13, 2015 (Application), for approval of the docket holder's existing Washington Crossing Historic Park Upper wastewater treatment plant (WWTP) and its discharge. National Pollutant Discharge Elimination System (NPDES) Permit No. PA0042978 for this facility was issued by the Pennsylvania Department of Environmental Protection (PADEP) on June 11, 2014, effective July 1, 2014.

The Application was reviewed for inclusion of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Bucks County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on September 15, 2015.

## A. <u>DESCRIPTION</u>

- 1. <u>Purpose</u>. The purpose of this docket is to approve the docket holder's existing 0.025 million gallons per day (mgd) WWTP and its discharge.
- **Location**. The WWTP will continue to discharge treated effluent to Water Quality Zone 1E of the Delaware River at River Mile 146.63 via Outfall No. 001, within the drainage area of the section of the main stem Delaware River known as the Lower Delaware Special Protection Waters (SPW), in the Solebury Township, Bucks County, Pennsylvania as follows:

| OUTFALI | NO. | LATITUDE (N) | LONGITUDE (W) |
|---------|-----|--------------|---------------|
| 001     |     | 40° 20' 7''  | 74° 56' 22"   |

3. <u>Area Served</u>. The docket holder's WWTP will continue to serve the Upper portion of the Washington Crossing Historic Park located in Solebury Township, Bucks County, Pennsylvania. For the purpose of defining the Area Served, Section B (Type of Discharge) and D (Service Area) of the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in the DECISION Section of this docket.

# 4. **Physical Features**.

- **a.** <u>Design Criteria</u>. The docket holder will continue to operate its existing 0.025 mgd WWTP.
- **b.** <u>Facilities</u>. The WWTP consists of an influent pump station, an equalization tank, two (2) aeration tanks, a clarifier, an alum feed system, a sludge holding tank, and a chlorine contact tank.

The docket holder's wastewater treatment facility discharges to waters classified as SPW and is required to have available emergency power. The existing WWTP has a generator installed capable of providing emergency power.

The docket holder's wastewater treatment facility is not staffed 24 hours per day, and shall have a remote alarm system that continuously monitors plant operations in accordance with the Commission's SPW requirements. The existing WWTP has a remote alarm system installed that continuously monitors plant operations.

The docket holder's existing wastewater treatment facility has not prepared and implemented an emergency management plan (EMP) in accordance with Commission SPW requirements. The docket holder is required as part of this docket approval to prepare and implement an EMP within 6 months of approval of this docket (See DECISION Condition II.1.).

The project facilities are not located in the 100-year floodplain.

Wasted sludge will continue to be hauled off-site by a licensed hauler for disposal at a state-approved facility.

- **c.** <u>Water withdrawals</u>. The potable water supply in the project service area is supplied by well water whose withdrawal quantity less than 100,000 gallons per day (gpd) and does not require Commission approval.
- d. <u>NPDES Permit / DRBC Docket</u>. NPDES Permit No. PA0042978 was issued by the PADEP on June 11, 2014 (effective July 1, 2014) and includes final effluent limitations for the project discharge of 0.025 mgd to surface waters classified by the PADEP as warm water fisheries (WWF). The following average monthly effluent limits are among those listed in the NPDES Permit and meet or are more stringent than the effluent requirements of the DRBC.

| OUTFALL 001 (WWTP)           |                                   |                             |  |  |
|------------------------------|-----------------------------------|-----------------------------|--|--|
| PARAMETER                    | LIMIT                             | MONITORING                  |  |  |
| pH (Standard Units)          | 6 to 9 at all times               | As required by NPDES Permit |  |  |
| Total Suspended Solids       | 30 mg/l                           | As required by NPDES Permit |  |  |
| Dissolved Oxygen             | 4.0 mg/l (minimum at all times)   | As required by NPDES Permit |  |  |
| CBOD <sub>5</sub> (at 20° C) | 25 mg/l                           | As required by NPDES Permit |  |  |
| Ammonia Nitrogen             | 20 mg/l                           | As required by NPDES Permit |  |  |
| Fecal Coliform               | 200 colonies per 100 ml as a geo. | As required by NPDES Permit |  |  |
|                              | avg.                              |                             |  |  |
| Phosphorus                   | 1.0 mg/l                          | As required by NPDES Permit |  |  |
| Total Dissolved Solids*      | Monitor & Report                  | As required by NPDES Permit |  |  |
| Nitrate as N                 | Monitor & Report                  | As required by NPDES Permit |  |  |
| Total Nitrogen               | Monitor & Report                  | As required by NPDES Permit |  |  |

**EFFLUENT TABLE A-1**: DRBC Parameters Included in NPDES Permit

The requirement in EFFLUENT TABLE A-2 is not listed in the NPDES Permit, but is a Commission basin-wide parameter that must be met as a condition of this docket approval. Commission staff have requested PADEP include this parameter in their next Permit. Monitoring shall begin October 1, 2015 for this parameter (See DECISION Condition II.d.).

EFFLUENT TABLE A-2: DRBC Parameter Not Included in NPDES Permit

| OUTFALL 001 (WWTP)                    |                  |  |  |  |
|---------------------------------------|------------------|--|--|--|
| PARAMETER                             | LIMIT            | MONITORING                                 |  |  |
| CBOD <sub>5</sub> (at 20° C) Influent | Monitor & Report | Same as CBOD <sub>5</sub> frequency in the |  |  |
|                                       |                  | NPDES Permit                               |  |  |

- **e. Cost**. There are no construction costs associated with this existing WWTP.
- **f.** Relationship to the Comprehensive Plan. Issuance of this docket will include the docket holder's WWTP in the Comprehensive Plan (See DECISION Condition I.).

## **B. FINDINGS**

The purpose of this docket is to approve the docket holder's existing 0.025 mgd WWTP and its discharge.

On July 16, 2008, the DRBC approved amendments to its *Water Quality Regulations* (*WQR*) that provide increased protection for waters that the Commission classifies as SPW. The portion of the Delaware River and its tributaries within the boundary of the Lower Delaware River Management Plan Area was approved for SPW designation.

<sup>\*</sup> See DECISION Condition II.p.

Article 3.10.3A.2.e.1). and 2). of the Commission's *WQR* states that projects subject to review under Section 3.8 of the Compact that are located in the drainage area of SPW must submit for approval a Non-Point Source Pollution Control Plan (NPSPCP) that controls the new or increased non-point source loads generated within the portion of the docket holder's service area which is also located within the drainage area of SPW. The service area of the docket holder is located within in the drainage area to the SPW. Since this project does not entail additional construction and expansion of facilities/service area (i.e., there are not any new or increased non-point source loads associated with this approval), the NPSPCP requirement is not applicable at this time. Accordingly, DECISION Conditions II.k. and II.r. have been included in this docket.

Due to Outfall No. 001's proximity to the Trenton Gage on the Delaware River, the estimated seven-day low flow with a recurrence interval of ten years  $(Q_{7-10})$  is of 1,939 mgd (3,000 cfs). The ratio of this low flow to the hydraulic design wastewater discharge from the 0.025 mgd WWTP is 77,560 to 1.

The nearest surface water intake of record for public water supply is located on the Delaware River approximately 10.86 River Miles downstream of the docket holder's WWTP, and is operated by the Pennsylvania American Water Company (PAWC).

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit are in compliance with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge meeting the effluent requirements as set forth in the Commission's *WOR*.

## C. <u>DECISION</u>

- I. Effective on the approval date for Docket No. D-2015-007 CP-1 below, the project and the appurtenant facilities described in Section A "Physical Features" of this docket shall be added to the Comprehensive Plan.
- II. The project and appurtenant facilities as described in Section A "Physical Features" of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:
- a. Docket approval is subject to all conditions, requirements, and limitations imposed by the PADEP in its NPDES Permit, and such conditions, requirements, and limitations are incorporated herein, unless they are less stringent than the Commission's.

- b. The facility and operational records shall be available at all times for inspection by the DRBC.
- c. The facility shall be operated at all times to comply with the requirements of the Commission's WQR.
- d. The docket holder shall comply with the requirements contained in the EFFLUENT TABLES in Section A.4.d. of this docket. The docket holder shall submit the required monitoring results <u>electronically</u> to the DRBC Project Review Section via email <u>aemr@drbc.state.nj.us</u> on the Annual Effluent Monitoring Report Form located at this web address: <a href="http://www.state.nj.us/drbc/programs/project/application/index.html">http://www.state.nj.us/drbc/programs/project/application/index.html</a>. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations.
- e. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.
- f. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.
- g. The docket holder is permitted to treat and discharge wastewaters as set forth in the Area Served Section of this docket, which incorporates by reference Sections B (Type of Discharge) and D (Service Area) of the docket holder's Application to the extent consistent with all other conditions of this DECISION Section.
- h. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.
- i. Nothing in this docket approval shall be construed as limiting the authority of DRBC to adopt and apply charges or other fees to this discharge or project.
- j. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, in order to ensure proper control, use and management of the water resources of the Basin.
- k. Prior to allowing connections from any new service areas or any new developments, the docket holder shall either submit and have approved by the Executive Director of the DRBC a NPSPCP in accordance with Section 3.10.3.A.2.e. or receive written

confirmation from the Executive Director of the DRBC that the new service area is in compliance with a DRBC approved NPSPCP.

- l. The docket holder shall prepare an EMP within six (6) months of docket approval. The docket holder shall submit the EMP and certify in writing to the Commission that it has complied with this condition by March 16, 2016.
- m. Unless an extension is requested and approved by the Commission in advance, in accordance with paragraph 11 of the Commission's Project Review Fee schedule (Resolution No. 2009-2), the docket holder is responsible for timely submittal of a docket renewal application on the appropriate DRBC application form at least 12 months in advance of the docket expiration date set forth below. The docket holder will be subject to late charges in the event of untimely submittal of its renewal application, whether or not DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. In the event that a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below (or the later date established by an extension that has been timely requested and approved), the terms and conditions of the current docket will remain fully effective and enforceable against the docket holder pending the grant or denial of the application for docket approval.
- n. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.
- o. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the Rules of Practice and Procedure. In accordance with Section 15.1(p) of the Delaware River Basin Compact, cases and controversies arising under the Compact are reviewable in the United States district courts.
- p. The docket holder may request of the Executive Director in writing the substitution of specific conductance for TDS. The request should include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow the substitution of specific conductance for TDS monitoring.
- q. The docket holder is prohibited from treating/pre-treating any hydraulic fracturing wastewater from sources in or out of the Basin at this time. Should the docket holder wish to treat/pre-treat hydraulic fracturing wastewater in the future, the docket holder will need to first apply to the Commission to renew this docket and be issued a revised docket allowing such treatment and an expanded service area. Failure to obtain this approval prior to treatment/pre-treatment will result in action by the Commission.
- r. Prior to the docket holder initiating any substantial alterations or additions to the existing WWTP as defined in Section 3.10.3A2.a.16) of the Commission's WQR, an

application must be submitted and approved by the Commission. Such an application shall be submitted prior to final design to ensure that the Commission can provide the docket holder with draft effluent limitations for SPW specific parameters as guidance for design as to not require duplication of work or cause a substantial expenditure of public funds without Commission approval. The docket holder is encouraged to contact the Commission staff during the planning stages to identify the potential effluent limitations required to meet the no measurable change parameters under SPW.

BY THE COMMISSION

DATE APPROVED: September 16, 2015

**EXPIRATION DATE:** June 30, 2019