

POWER CABLES			
DESIGNATION	CABLES (SEE NOTES)	FROM	TO
P1	(SEE NOTE 4)	METER CABINET	ITSS DISCONNECT\ITSS PANELBOARD
P2	(2) #2 AWG + #4 AWG GND	ITSS DISCONNECT	ITSS TRANSFORMER
P3	(3) #3/0 AWG + #4 AWG GND	ITSS TRANSFORMER	ITSS PANELBOARD
P4	(3) #2 AWG + #4 AWG GND	ITSS PANELBOARD	SCC DISCONNECT
P5	(3) #1/0 AWG + #4 AWG GND	ITSS PANELBOARD	SCC DISCONNECT
P6	(3) #2 AWG + #4 AWG GND	SCC DISCONNECT	SCC PANELBOARD
P7	(2) #8 AWG + #8 AWG GND	SCC PANELBOARD	UPS
P8	(3) #4 AWG + #6 AWG GND	SCC PANELBOARD	VMS
P9	(2) #8 AWG + #8 AWG GND	UPS	UPS PANELBOARD
P10	(2) #10 AWG + #10 AWG GND	UPS PANELBOARD	VLS
P11	(2) #14 AWG + #14 AWG GND	UPS PANELBOARD	CCTV REMOTE POWER UNIT
P12	(2) #14 AWG + #14 AWG GND	REMOTE POWER UNIT	CCTV CAMERA
P13	NOT USED		

COMMUNICATIONS CABLES			
DESIGNATION	CABLES (SEE NOTES)	FROM	TO
C1	(1) 4 TWISTED PAIR #24 AWG	SCC	WAP
C2	(1) 6-FIBER OPTIC MULTIMODE CABLE	SCC	VMS
C3	(1) 6-FIBER OPTIC MULTIMODE CABLE	SCC	VLS
C4	(1) 4 TWISTED PAIR #24 AWG	SCC	VMS
C5	(1) 4 TWISTED PAIR #24 AWG	SCC	VLS
C6	(1) 4 TWISTED PAIR #24 AWG	SCC	CCTV REMOTE POWER UNIT
C7	(1) 12-FIBER OPTIC CABLE	SCC	SCC
C8	(1) 12-FIBER OPTIC CABLE	ITSF MANHOLE	SCC
C9	(1) 12-FIBER OPTIC CABLE	SCC	SCC
C10	(1) COAXIAL CABLE	SCC	CCTV REMOTE POWER UNIT
C11	(1) 4 TWISTED PAIR #24 AWG	SCC	RADIO ANTENNA
C12	(1) 6-FIBER OPTIC MULTIMODE CABLE	SCC	POLE MOUNTED ITS ENCLOSURE
C13	(1) FIBER OPTIC MULTIMODE PATCH CORD	(VARIES)	NETWORK SWITCH
C14	(1) 4 TWISTED PAIR #24 AWG	ITSS OR POLE MOUNTED ITS ENCLOSURE	CCTV CAMERA
C15	(1) RG-6 COAXIAL CABLE	ITSS OR POLE MOUNTED ITS ENCLOSURE	CCTV CAMERA
C16	(1) ETHERNET #24 AWG PATCH CORD	(VARIES)	NETWORK SWITCH

CONDUITS		
DESIGNATION	SIZE AND TYPE	CABLES
①	3" RNM-40	P1
②	3" PCRC	P1
③	3" PCRC	P2
④	2 1/2" PCRC	P3
⑤	1 1/2" PCRC	P5
⑥	2 1/2" PCRC	P4
⑦	3" PCRC	P6
⑧	1 1/2" PCRC	P8 P10 P11
⑨	2 1/2" PCRC	P1 P5
⑩	3" PCRC	C1 C2 C3 C4 C5 C6 C10
⑪	3" RNM-80	C8
⑫	3" RNM-80	C7
⑬	3" RNM-80	C8
⑭	3" RNM-80	P5
⑮	3" RNM-80	SPARE
⑯	3" PCRC	P5
⑰	3" PCRC	P5
⑱	3" PCRC	P6
⑲	3" PCRC	C1 C2 C3 C4 C5 C6 C10 C11
⑳	3" PCRC	C1 C2 C3 C4 C5 C6 C10 C11
㉑	3" PCRC	P8 P10 P11
㉒	3" PCRC	P8 P10 P11
㉓	3" PCRC	P5
㉔	3" PCRC	P5
㉕	3" PCRC	SPARE
㉖	3" PCRC	SPARE
㉗	2" PCRC	C2 C3 C4 C5
㉘	1 1/2" FMC	C3 C4

CONDUITS CONTINUED		
DESIGNATION	SIZE AND TYPE	CABLES
㉙	2" PCRC	C2 C4
㉚	2" PCRC	P8 P10
㉛	1 1/2" FMC	P10
㉜	2" PCRC	P8
㉝	NOT USED	
㉞	NOT USED	
㉟	1" FMC	C14 C15 P12
㊱	3" RNM-40	C7 C8 C12 C13
㊲	3" RNM-40	C1 C2 C4 C6 C10 C11
㊳	3" RNM-40	P8 P11
㊴	3" RNM-40	P1 P6
㊵	3" RNM-40	P2 P3
㊶	NOT USED	
㊷	NOT USED	
㊸	NOT USED	
㊹	NOT USED	
㊺	NOT USED	

LEGEND:


 ITEMS SHOWN DASHED MAY VARY BY INSTALLATION. SEE CONTRACT PLANS FOR SPECIFIC CABLE INSTALLATION.


NOTES:

- SEE DETAILS ON THE FOLLOWING STANDARD DRAWINGS FOR LOCATING CONDUITS AND CABLES LISTED IN THE TABLES ON THIS DRAWING.
- SEE STANDARD DRAWING ITS-01 FOR A LIST OF ABBREVIATIONS IDENTIFYING THE TYPES OF CONDUITS AND CABLES LISTED ON THIS DRAWING.
- POWER AND COMMUNICATION CABLES SHALL BE OF THE MAKE AND MODEL AS DESCRIBED IN THE SPECIFICATIONS.
- SIZE AND QUANTITY OF INCOMING SERVICE WIRES SHALL BE AS SHOWN ON THE PLANS.
- CABLES SHALL BE SIZED AS SHOWN ON THIS DRAWING UNLESS NOTED OTHERWISE ON THE PLANS.
- REFER TO THE CONTRACT PLANS TO IDENTIFY WIRING REQUIRED TO BE FURNISHED AND INSTALLED FOR EQUIPMENT WHICH MAY NOT BE INCLUDED IN THESE STANDARD DRAWINGS.

HNTB, INC., 145 RT. 46 WEST, SUITE 400, WAYNE, NJ 07470 - COA# 24GA2800700
 CONTRACT NO. 09/2010 DATE 09/2010
 LAST DATED DATE: Sep 20, 2010 - 8:57 AM (engr)

	BY	DATE
MADE	EMG	09/2010
TRACED	MDC	09/2010
CHECKED	EMG	09/2010
SUPERVISED	ALB	09/2010



APP.	NO.	DATE	REVISION
	0	09/2010	ORIGINAL DRAWING

NEW JERSEY TURNPIKE AUTHORITY

NEW JERSEY TURNPIKE

ITSS GENERAL NOTES, LEGEND, AND ABBREVIATIONS - 2

HNTB 145 RT. 46 WEST, SUITE 400, WAYNE, NJ 07470 - COA# 24GA2800700

ANTHONY L. BARTELLO

New Jersey Professional Engineer License No. GE 48842

STANDARD DRAWING ITS-02