Table 2. Drinking Water Standards for Organic Contaminants (not including disinfectants or their by-products): USEPA, NJ and World Health Organization.

Contaminant	USEPA MCL (µg/L)	NJ MCL (µg/L)	WHO Guideline value (µg/L)
1,1,1-Trichloroethane	200	30	2000 [a]
1,1,2-Trichloroethane	5	3	
1,1-Dichloroethane		50	
1,1-Dichloroethylene	7	2	30
1,2-Dichlorobenzene (Ortho)	600	600	1000
1,2-Dichloroethane	5	2	30
1,2-Dichloroethylene, Cis	70	70	50
1,2-Dichloroethylene, Trans	100	100	
1,2-Dichloropropane	5	5	
1,2,4-Trichlorobenzenes	70	9	20
1,3-Dichlorobenzene (Meta)		600	
1,4-Dichlorobenzene (Para)	75	75	300
2,4,5-TP	50	50	
2,4-D	70	70	
Acrylaminde	Treatment	Treatment	0.5
Alachlor	2	2	
Atrazine	3	3	
Benzene	5	1	10
Benzo(a)pyrene	0.2	0.2	0.7
Carbofuran	40	40	
Carbon Tetrachloride	5	2	2
Chlordane	2	0.5	
Dalapon	200	200	
Di(2ethylhexyl)adipate	400	400	
Di(2-ethylhexyl)adipate	400	400	80
Di(2-ethylhexyl)phthalate	6	6	8
Di(2-ethylhexyl)phthalate	6	6	
Dialkyltins			

Dibromochloropropane	0.2	0.2	
Dichloromethane	5	3	20
Dinoseb	7	7	
Dioxin (2,3,7,8-TCDD)	0.00003	0.00003	
Diquat	20	20	
Edetic Acid (EDTA)			600
Eipchlorohydrin	Treatment	Treatment	0.4[a]
Enddrin	2	2	
Endothall	100	100	
Ethylbenzene	700	700	300
Ethylene Dibromide	0.05	0.05	
Glyphosate	700	700	
Heptachlor	0.4	0.4	
Heptachlor Epoxide	0.2	0.2	
Hexachlorobenzene	1	1	
Hexachlorobutadient			0.6
Hexachlorocyclopentadiene	50	50	
Lindane	0.2	0.2	
Methoxychlor	40	40	
Microcystin-Lr			1[a]
Monochlorobenzene	100	50	300
Nitrilotriacetic Acid			200
Oxamyl	200	200	
Polybrominated Biphenyls	0.5	0.5	
Pentachlorophenol	1	1	
Picloram	500	500	
Simazine	4	4	
Styrene	100	100	20
Tetrachloroethylene	5	1	40
Toluene	1000	1000	700
Toxaphene	3	3	
Tributyltin Oxide			2

Trichloroethylene	5	1	70[a]
Vinyl Chloride	2	2	5
Xylenes	10,000	1,000	500

[a] Provisional guideline value. This term is used for constituents for which there is some evidence of a potential hazard but where the available information on health effects is unavailable or for substances for which the calculated guideline value would be below the practical quantification level, or below the level that can be achieved through practical treatment methods.