



STATE OF NEW JERSEY
Board of Public Utilities
44 South Clinton Avenue, 1st Floor
Post Office Box 350
Trenton, New Jersey 08625-0350
www.nj.gov/bpu/

ENGINEERING

IN THE MATTER OF THE PETITION OF NEW JERSEY-	)	ORDER ADOPTING
AMERICAN WATER COMPANY, INC. FOR	)	STIPULATION
AUTHORIZATION TO IMPLEMENT A WASTEWATER	)	
SYSTEM IMPROVEMENT CHARGE	)	DOCKET NO. WR26030098

Parties of Record:

Teresa K. Harrold, Esq., Director, Corporate Counsel, for New Jersey American Water Company, Inc.

Brian O. Lipman, Esq., Director, New Jersey Division of Rate Counsel

BY THE BOARD:

On March 27, 2026, New Jersey-American Water Company, Inc. ("NJAWC" or "Company") filed a petition with the New Jersey Board of Public Utilities ("Board") pursuant to N.J.S.A. 48:2-21 and N.J.A.C. 14:9-11.1 et seq., seeking approval to file and implement an automatic adjustment clause tariff that would establish a Wastewater System Improvement Charge ("WSIC") for the rehabilitation and replacement of wastewater system assets for the period of 2026 through 2029 ("Foundational Filing"). By this Order, the Board considers a Stipulation of Settlement ("Stipulation") executed by NJAWC, the New Jersey Division of Rate Counsel ("Rate Counsel"), and Board Staff ("Staff") (collectively, "Parties") resolving all issues related to the Foundational Filing.

BACKGROUND AND PROCEDURAL HISTORY

NJAWC is engaged in the production, treatment and distribution of water and collection and treatment of wastewater within its defined service territory within the State of New Jersey. As of December 31, 2025, NJAWC was serving approximately 680,000 water and fire service customers and 70,000 wastewater customers. NJAWC provides water service in portions of the following counties: Atlantic, Burlington, Camden, Cape May, Essex, Gloucester, Hunterdon, Mercer, Middlesex, Monmouth, Morris, Ocean, Passaic, Salem, Somerset, Union, and Warren. NJAWC provides wastewater service in portions of the following counties: Atlantic, Bergen, Burlington, Camden, Cape May, Gloucester, Hunterdon, Monmouth, Morris, Ocean, Salem, Somerset, and Warren.

NJAWC filed its most recent base rate case on January 16, 2026.¹ Concurrently with the settlement in this matter, the Company has settled the 2026 Base Rate Case.

PETITION

By the Foundational Filing, pursuant to N.J.A.C. 14:9-11.1 et seq., NJAWC estimated that the proposed WSIC rates, if approved, would increase in increments occurring at approximately six (6)-month intervals, by no more than \$3.9 million, or five percent (5%) of NJAWC's total wastewater revenues as established in the Company's most recent base rate decision. According to the Foundational Filing, the Company's eligible capital spending above base spending would be approximately \$32 million over the effective time period of the Foundational Filing. According to the Company, the final cap number would be determined in accordance with the Board Order approving the settlement of the 2026 Base Rate Case.

As part of the Foundational Filing, the Company submitted an engineering evaluation report, pursuant to N.J.A.C. 14:9-11.4(b)(1), that identified the rationale for the WSIC-eligible work to be performed; demonstrated that the proposed plan is cost-effective; identified what mechanisms are causing wastewater infrastructure failures, to the extent that such elements are failing; and identified efforts to extend the life of NJAWC's wastewater infrastructure assets.

Following adequate and proper notice to the general public in newspapers of general circulation in the Company's service territory, the Board held two (2) virtual public hearings, presided over by a Board-appointed regulatory officer, on June 1, 2026, at 4:30 p.m. and 5:30 p.m. No members of the public participated in either hearing and no written comments were received by the Board.

STIPULATION

Following a complete review of the Foundational Filing, conducting discovery, and discussion, the Parties executed the Stipulation, which provides for the following:²

1. NJAWC's full base rate case is pending at BPU Docket No. WR26010010, OAL Docket No. PUC 03132-2026S.
2. The Parties agree that they will use their best efforts to ensure that this Stipulation is presented to the Board for approval concurrent with the Company's pending full base rate case and that should the Board Order approve the Stipulation, the previous WSIC rate approved in BPU Docket No. WR24030203 will be reset to zero.
3. The Parties agree that the first WSIC recovery period will be September 15, 2026, through March 31, 2027.

¹ In the Matter of the Petition of New Jersey-American Water Company, Inc. for Approval of Increased Tariff Rates and Charges for Water and Wastewater Service, and Other Tariff Modifications, BPU Docket No. WR26010010, OAL Docket No. PUC 03132-2026S ("2026 Base Rate Case") date approved on September 9, 2026.

² Although described in this Order at some length, should there be any conflict between this summary and the Stipulation, the terms of the Stipulation control, subject to the findings and conclusions in this Order. Paragraphs are numbered to coincide with the Stipulation.

4. The Parties agree that NJAWC's third WSIC Foundational Filing, including Appendix A – Project List attached to the Stipulation as Attachment A, satisfies the requirements of N.J.A.C. 14:9-11.4(b).
5. The Parties agree that the projects listed in Attachment A to the Stipulation that begin after the test year in NJAWC's last base rate case (June 30, 2026) have been reviewed and are WSIC-eligible projects within the scope and meaning of the definition set forth in N.J.A.C. 14:9-11.2 and N.J.A.C. 14:9-11.3(a) and are eligible to be included in NJAWC's semi-annual WSIC filings pursuant to N.J.A.C. 14:9-11.7.
6. The Parties agree that pursuant to N.J.A.C. 14:9-11.5(a)(1), NJAWC may include in its semi-annual WSIC filings for recovery under this Foundational Filing any and all projects approved and carried over from a prior WSIC period.
7. The Parties agree that the revenue requirement associated with the actual costs of the approved projects listed in Attachment A to the Stipulation shall be recovered through future "WSIC filings" made during the "WSIC period" as those terms are defined in N.J.A.C. 14:9-11.2 at intervals and in a manner consistent with the requirements of N.J.A.C. 14:9-11.5.
8. The Parties agree that the annual "base spending" as defined in N.J.A.C. 14:9-11.2 is \$2,331,523, based on the information filed in the Company's most recent report to the Board at the time the Foundational Filing was submitted (the 2024 Annual Report).
9. The Parties agree that the maximum amount of annual WSIC revenue that may be collected by NJAWC is five percent (5%) of the total sum of wastewater revenues that will be set in the Company's base rate case at BPU Docket No. WR26010010 and OAL Docket No. PUC 03132-2026S and the purchased wastewater treatment revenues in effect on April 1, 2026, at BPU Docket No. WR25110596. The average customer has a 5/8-inch meter which will be subject to a monthly WSIC surcharge of \$4.83³ per month at the maximum amount of annual revenue authorized.

DISCUSSION AND FINDINGS

Having reviewed the record in this matter, including the Foundational Filing and the Stipulation, the Board **HEREBY FINDS** the Stipulation to be reasonable, in the public interest, and in accordance with the law. Accordingly, the Board **HEREBY ADOPTS** the Stipulation, attached hereto, including all attachments and schedules, as its own, incorporating by reference the terms and conditions of the Stipulation, as if they were fully set forth at length herein.

Based upon the information presented in the Foundational Filing, the record in the 2026 Base Rate Case, and the terms agreed to by the Parties in the Stipulation, the Board **HEREBY FINDS** that the Company's 2026 overall revenue for WSIC purposes is \$77,092,134. The Board **FURTHER FINDS** that the maximum amount of annual WSIC revenues that the Company may collect is \$3,854,607, or no more than five percent (5%) of the Company's total water revenues as established in the 2026 Base Rate Case. The Company shall implement the WSIC surcharge

³ The maximum monthly surcharge is an approximate number only and may be higher or lower depending on many factors, including but not limited to changes in the number of customers served by the Company.

if, and when, it achieves specific levels of infrastructure investment and completes and places the facilities into service as required by N.J.A.C. 14:9-11.1 et seq.

Based on the Stipulation, an average residential customer with a 5/8-inch meter may be subject to a maximum monthly WSIC surcharge of \$4.83. The average residential maximum WSIC surcharge rate is an estimate and may change, however, the maximum annual WSIC revenue requirement, \$3,854,607, cannot be exceeded.

The Board **HEREBY ORDERS** that, in accordance with N.J.A.C. 14:9-11.5(b), the Company shall make WSIC filings on a semi-annual basis, commencing approximately six (6) months after the effective date of the Foundational Filing. The Company must submit their semi-annual WSIC filing within fifteen (15) days of the end of the WSIC recovery period to be reviewed by Staff and Rate Counsel. The Company may recover the interim surcharge associated with the WSIC-eligible projects closed during the WSIC recovery period and not objected to by Staff or Rate Counsel beginning forty-five (45) days after the receipt of the complete semi-annual WSIC filing, subject to refund at the Board's discretion.

The Board **FURTHER ORDERS** that the Company must comply with the base spending requirements set forth in this Order. Failure to comply with the base spending requirements will result in a reduction and refund, where appropriate, of the WSIC surcharge. Thus, NJAWC's WSIC surcharge is interim, subject to refund, and shall not exceed the annual maximum revenue requirement of \$3,854,607 set forth in this Order.

The Board **FURTHER ORDERS** that in accordance with N.J.A.C. 14:9-11.4(e), if within three (3) years after the effective date of the Foundational Filing, NJAWC has not filed a petition in accordance with the Board's rules for the setting of its base rates, all interim charges collected under the WSIC shall be deemed an over-recovery, and shall be credited to customers in accordance with the Board's rules.

Based upon the foregoing, the Board **HEREBY APPROVES** the Foundational Filing and **AUTHORIZES** NJAWC to implement their proposed WSIC, subject to this Order and the Company's ongoing compliance with the WSIC regulations, as well as conformity of the base spending requirements and semi-annual true-up submissions.

The Company's costs, including those related to the WSIC, will remain subject to audit by the Board. This Order shall not preclude or prohibit the Board from taking further action relating to any such audit.

The effective date of this Order is September 16, 2026.


DATED: September 9, 2026

BOARD OF PUBLIC UTILITIES
BY:


BEN HERTZ-SHARGEL
PRESIDENT



CHRISTINE GUHL-SADOVY
COMMISSIONER


MICHAEL BANGE
COMMISSIONER


EMMA REBHORN
COMMISSIONER


JOSEPH COVIELLO
COMMISSIONER

ATTEST:


SHERRI L. LEWIS
BOARD SECRETARY

I HEREBY CERTIFY that the within
document is a true copy of the original
in the files of the Board of Public Utilities.

IN THE MATTER OF THE PETITION OF NEW JERSEY-AMERICAN WATER COMPANY, INC. FOR
AUTHORIZATION TO IMPLEMENT A WASTEWATER SYSTEM IMPROVEMENT CHARGE
BPU DOCKET NO. WR26030098

SERVICE LIST

New Jersey-American Water Company, Inc.

1 Water Street
Camden, NJ 08102
Iselin, NJ 08830

Donald C. Shields, Vice President and Director of
Engineering
donald.shields@amwater.com

Michael B. McKeever, Senior Director Rates and
Regulatory
michael.mckeever@amwater.com

Jamie D. Hawn, Director, Rates and Regulatory
jamie.hawn@amwater.com

Teresa K. Harrold, Esq., Counsel
teresa.harrold@amwater.com

Erin K. Fure, Esq.
erin.fure@amwater.com

Donna Carney
149 Yellowbrook Road, Suite 109
Farmingdale, NJ 07727
Donna.carney@amwater.com

Division of Law

Department of Law & Public Safety
R.J. Hughes Justice Complex
Public Utilities Section
25 Market Street, P.O. Box 112
Trenton, N.J. 08625

Pamela Owen, DAG, Assistant Section Chief
pamela.owen@law.njoag.gov

Meliha Arnautovic, DAG
meliha.arnautovic@law.njoag.gov

Jack Ventura, DAG
jack.ventura@law.njoag.gov

Jordan Mitchell, DAG
jordan.mitchell@law.njoag.gov

Terel Klein, DAG, Section Chief
terel.klein@law.njoag.gov

Rachel Reckeweg
rachel.reckeweg@law.njoag.gov

Tanya Lloyd-Samuel
tanya.lloyd-samuel@law.njoag.gov

Board of Public Utilities

44 South Clinton Avenue, 1st Floor
Post Office Box 350
Trenton, NJ 08625-0350

Sherri Lewis, Secretary of the Board
board.secretary@bpu.nj.gov

Stacy Peterson, Deputy Executive Director
stacy.peterson@bpu.nj.gov

Division of Engineering

Dean Taklif, Director
dean.taklif@bpu.nj.gov

John Masiello, Deputy Director
john.masiello@bpu.nj.gov

Rupal Patel
rupal.patel@bpu.nj.gov

Counsel's Office

Ava-Marie Madeam, General Counsel
avamarie.madeam@bpu.nj.gov

Elsbeth Hans, Deputy General Counsel
elsbeth.hans@bpu.nj.gov

Taylor Hoopes
taylor.hoopes@bpu.nj.gov

Division of Rate Counsel

140 East Front Street, 4th Floor
Post Office Box 003
Trenton, NJ 08625-003

Brian O. Lipman, Esq., Director
blipman@rpa.nj.gov

Christine Juarez, Esq., Managing Attorney
cjuarez@rpa.nj.gov

Emily Lam, Esq.
elam@rpa.nj.gov

Felecia Jackson-Rodgers
frodgers@rpa.nj.gov

LaNee C. Isom, Paralegal
lisom@rpa.nj.gov

Rate Counsel Consultant

Charles R. Sweeney, Consultant
Sweeney Consulting, LLC
2250 Calverton Road
Shaker Heights, OH 44122
chuckrsweeney@gmail.com



Teresa K. Harrold
Counsel
1 Water Street | Camden, NJ 08102
Phone: 717-550-1562 | Mobile: 717-303-8381
teresa.harrold@amwater.com

August 27, 2026

Via Electronic Mail

Hon. Sherri L. Lewis, Secretary
Board of Public Utilities
44 S. Clinton Ave., 1st Floor
Trenton, N.J. 08625

**Re: I/M/O the Petition of New Jersey-American Water Company, Inc. for Authorization to
Implement a Wastewater System Improvement Charge
BPU Docket No. WR26030098**

Dear Secretary Lewis:

Enclosed herewith for the Board's consideration is a signed stipulation, representing the parties' settlement of the above-captioned matter.

Please do not hesitate to contact me should you have any questions or concerns.

Respectfully,


Teresa K. Harrold

TKH:dlc
Enc.

c: Attached service list (via email, w/enc.)

**Petition of New Jersey-American Water Company, Inc. for Authorization to Implement a
Wastewater System Improvement Charge
Board Docket No. WR26030098
SERVICE LIST**

Board of Public Utilities

44 South Clinton Avenue
P.O. Box 350
Trenton, NJ 08625-0350

Stacy Peterson
stacy.peterson@bpu.nj.gov

Dean Taklif
dean.taklif@bpu.nj.gov

Yanina Lepore
yanina.lepore@bpu.nj.gov

Rupal Patel
rupal.patel@bpu.nj.gov

Michael Hunter
michael.hunter@bpu.nj.gov

New Jersey Division of Law
NJ Division of Law
Office of the Attorney General
25 Market Street, P.O. Box 112
Trenton, NJ 08625

Pamela Owen
Deputy Attorney General
pamela.owen@law.njoag.gov

Meliha Arnautovic
Deputy Attorney General
meliha.arnautovic@law.njoag.gov

Division of Rate Counsel
Division of Rate Counsel
140 East Front Street, 4th Fl.
P.O. Box 003
Trenton, NJ 08625-0350

Brian Lipman, Esq., Director
blipman@rpa.nj.gov

Christine Juarez, Esq.
cjuarez@rpa.nj.gov

LaNee Isom
lisom@rpa.nj.gov

Felecia Jackson-Rodgers
frodgers@rpa.nj.gov

Charles R. Sweeney
Sweeney Consulting, LLC
22550 Calverton Road
Shaker Heights, OH 44122
chuckrsweeney@gmail.com

New Jersey-American Water Company, Inc.
852 Wesley Drive
Mechanicsburg, PA 17055

Teresa K. Harrold
teresa.harrold@amwater.com

1 Water Street
Camden, NJ 08102

Donald C. Shields
donald.shields@amwater.com

Michael McKeever
michael.mckeever@amwater.com

Jamie D. Hawn
jamie.hawn@amwater.com

Donna Carney
149 Yellowbrook Road, Suite 109
Farmingdale, NJ 07727
donna.carney@amwater.com

**STATE OF NEW JERSEY
BOARD OF PUBLIC UTILITIES**

IN THE MATTER OF THE PETITION	:	STIPULATION OF SETTLEMENT
OF NEW JERSEY-AMERICAN WATER	:	
COMPANY, INC. FOR	:	
AUTHORIZATION TO IMPLEMENT A	:	BPU DOCKET NO. WR26030098
WASTEWATER SYSTEM	:	
IMPROVEMENT CHARGE	:	

APPEARANCES:

Teresa K. Harrold, Esq., Counsel, New Jersey-American Water Company, Inc.

Meliha Arnautovic, Esq., Deputy Attorney General for Staff of the New Jersey Board of Public Utilities (**Jennifer Davenport**, Attorney General of New Jersey)

Christine Juarez, Esq., Managing Attorney, for the Division of Rate Counsel (**Brian O. Lipman, Esq.**, Director)

TO THE HONORABLE BOARD OF PUBLIC UTILITIES:

BACKGROUND

On March 27, 2026, New Jersey-American Water Company, Inc. (“NJAWC” or “Company”), a public utility of the State of New Jersey, filed a petition with the New Jersey Board of Public Utilities (“Board” or “BPU”) pursuant to N.J.S.A. 48:2-21 and N.J.A.C. 14:9-11.1 et seq., and such statutes, regulations, and Board Orders that may be deemed by the Board to be applicable, for approval of its Foundational Filing to enable the implementation of a Wastewater System Improvement Charge (“WSIC”) for the renewal of wastewater system assets for the period of 2026 through 2029 (“Petition”).

NJAWC is engaged in the production, treatment and distribution of water and collection, conveyance and treatment of wastewater within its defined service territory within the State of New Jersey. Said service territory includes portions of the following counties: Atlantic, Bergen, Burlington, Camden, Cape May, Essex, Gloucester, Hunterdon, Mercer, Middlesex, Monmouth, Morris, Ocean, Passaic, Salem, Somerset, Sussex, Union, and Warren. NJAWC serves

approximately 680,000 water and fire service customers and 70,000 wastewater service customers throughout the state. NJAWC is a wastewater utility within the meaning of N.J.A.C. 14:9-11.2 and 14:9-1.2 and provides wastewater services in the following counties: Atlantic (1 system), Bergen (1 system), Burlington (2 systems), Camden (2 systems), Cape May (2 systems), Gloucester (1 system), Hunterdon (7 systems), Monmouth (2 systems), Morris (5 systems), Ocean (2 systems), Salem (1 system), Somerset (5 systems), Sussex (1 system) and Warren (2 systems).

In BPU Docket No. WX19050614, the Board approved the WSIC framework, which was published in the New Jersey Register on December 7, 2020, and effective on that date. The WSIC rules were subsequently adopted at N.J.A.C. 14:9-11.1 et seq. The rules set forth the conditions and procedures pursuant to which regulated wastewater utilities may seek recovery of WSIC-eligible capital investments through monthly surcharges, set semi-annually, on customer bills.

In support of its Petition, NJAWC submitted a Foundational Filing, consisting of the following information required by N.J.A.C. 14:9-11.4:

- a) An engineering evaluation report of NJAWC's sewer system that:
 - i. Identifies the rationale for the work needed to be accelerated for NJAWC to properly sustain its wastewater infrastructure;
 - ii. Demonstrates that the plan proposed to accelerate the renewal of the wastewater infrastructure is the most cost-effective plan;
 - iii. To the extent that elements of the wastewater infrastructure are failing, identifies what mechanisms are causing the failures; and
 - iv. Identifies what is being done to extend the life of NJAWC's wastewater infrastructure assets.
- b) The following WSIC project information for the upcoming WSIC period:

- i. A list of potential projects with project identification numbers, WSIC-eligible asset class or category, and estimated project costs;
 - ii. The nature, location, estimated duration of project work (including estimated in-service dates) and a description and reason for project necessity;
 - iii. Aggregate information capturing blanket type WSIC-eligible infrastructure to be rehabilitated or replaced (e.g., service laterals, manholes, etc.) and the estimated annual cost of such blanket type replacement programs;
 - iv. Vintage, condition, and other similar relevant, reasonably available information about the eligible infrastructure being rehabilitated or replaced; and
 - v. Other such relevant and appropriate information to assist in making an informed decision regarding any given project.
- c) The expected amount of NJAWC's base spending, including underlying detail documenting that the base spending has been made on the appropriate types of infrastructure; a proposed WSIC assessment, calculated in accordance with subsection N.J.A.C. 14:9-11.9; and work papers showing the detailed calculations supporting the proposed assessment schedule.

After proper public notice in newspapers of general circulation within the Company's service territory, posting of notice on the Company's website, and after service of notice upon affected municipalities and counties within NJAWC's service territory, two (2) virtual public

hearings were held on June 1, 2026, at 4:30 p.m. and 5:30 p.m., presided over by a hearing officer of the Board. No members of the public provided comments at either hearing.

NJAWC, Board Staff, and the New Jersey Division of Rate Counsel (“Rate Counsel”) engaged in discovery and comprehensive settlement discussions were held. As a result of these discussions, Board Staff, Rate Counsel, and NJAWC (collectively, “Stipulating Parties”) reached this stipulation of settlement (“Stipulation”) resolving all issues in this proceeding subject to the terms and conditions stated herein.

SETTLEMENT AGREEMENT

1. NJAWC’s full base rate case is pending at BPU Docket No. WR26010010, OAL Docket No. PUC 03132-2026S.

2. The Stipulating Parties agree that they will use their best efforts to ensure that this Stipulation is presented to the Board for approval concurrent with the Company’s pending full base rate case and that should the Board Order approve this Stipulation, the previous WSIC rate approved in BPU Docket No. WR24030203 will be reset to zero.

3. The Stipulating Parties agree that the first WSIC recovery period will be September 15, 2026, through March 31, 2027.

4. The Stipulating Parties agree that NJAWC’s third WSIC Foundational Filing, including Appendix A – Project List attached to this Stipulation as Attachment A, satisfies the requirements of N.J.A.C. 14:9-11.4(b).

5. The Stipulating Parties agree that the projects listed in Attachment A that begin after the test year in NJAWC’s last base rate case (June 30, 2026) have been reviewed and are WSIC-eligible projects within the scope and meaning of the definition set forth in N.J.A.C. 14:9-11.2 and N.J.A.C. 14:9-11.3(a) and are eligible to be included in NJAWC’s semi-annual WSIC filings pursuant to N.J.A.C. 14:9-11.7.

6. The Stipulating Parties agree that pursuant to N.J.A.C. 14:9-11.5(a)(1), NJAWC may include in its semi-annual WSIC filings for recovery under this Foundational Filing any and all projects approved and carried over from a prior WSIC period.

7. The Stipulating Parties agree that the revenue requirement associated with the actual costs of the approved projects listed in Attachment A shall be recovered through future “WSIC filings” made during the “WSIC period” as those terms are defined in N.J.A.C. 14:9-11.2 at intervals and in a manner consistent with the requirements of N.J.A.C. 14:9-11.5.

8. The Stipulating Parties agree that the annual “base spending” as defined in N.J.A.C. 14:9-11.2 is \$2,331,523, based on the information filed in the Company’s most recent report to the Board at the time the Foundational Filing was submitted (the 2024 Annual Report).

9. The Stipulating Parties agree that the maximum amount of annual WSIC revenue that may be collected by NJAWC is five percent (5%) of the total sum of wastewater revenues that will be set in the Company’s base rate case at BPU Docket No. WR26010010 and OAL Docket No. PUC 03132-2026S and the purchased wastewater treatment revenues in effect on April 1, 2026, at BPU Docket No. WR25110596. The average customer has a 5/8-inch meter which will be subject to a monthly WSIC surcharge of \$4.83¹ per month at the maximum amount of annual revenue authorized.

10. This Stipulation shall be binding on the Stipulating Parties to this proceeding upon approval hereof by the Board. This Stipulation shall bind the Stipulating Parties in this matter only and shall not be considered precedent in any other proceeding involving the Stipulating Parties hereto.

¹ The monthly surcharge is an approximate number only and may be higher or lower depending on many factors, including but not limited to changes in the number of customers served by the Company.

11. This Stipulation contains terms, each of which is interdependent with the others and essential in its own right to the signing of this Stipulation. Each term is vital to the agreement as a whole, since the Stipulating Parties individually and jointly state that they would not have signed the Stipulation had any term been modified in any way. In the event that any modifications whatsoever are made to this Stipulation, each of the Stipulating Parties hereto is entitled to certain procedures in the event of such occurrence.

12. If any modification is made to the terms of this Stipulation, the Stipulating Parties must be given the right to be placed in the position in which each Stipulating Party was before this Stipulation was executed. It is essential that each party be given the option either to modify its own position, to accept the proposed change(s) or to resume the proceeding as if no agreement had been reached.

13. The Stipulating Parties believe that these procedures are fair to all concerned and, therefore, they are made an integral and essential element of this Stipulation.


14. This Stipulation may be executed in as many counterparts as there are signatories to this Stipulation, each of which counterpart shall be an original, but all of which shall constitute one and the same instrument.

NEW JERSEY-AMERICAN WATER COMPANY, INC.

By: 
Teresa K. Harrold
Counsel


Dated: August 24, 2026

BRIAN O. LIPMAN, DIRECTOR
DIVISION OF RATE COUNSEL

By: 
Christine Juarez
Managing Attorney

Dated: August 27, 2026

JENNIFER DAVENPORT
ATTORNEY GENERAL OF NEW JERSEY
Attorney for the Staff of the Board of Public Utilities

By: 
Meliha Arnautovic
Deputy Attorney General

Dated: 08-26-26

New Jersey American Water Inc.
2026 WSIC Foundational Filing
Appendix A

Id	Municipality	Project Title	NAWC Funded (dollars)	Project Type	Prop. Length (feet)	Prop. Dia. (inches)	Proposed Pipe Material	Ex. Dia. (inches)	Existing Pipe Material	Decade Installed	Accelerated Asset Investment Category	Est Project Duration (Days)	Estimated In Service Quarter
7093	HADDONFIELD BORO	Haddonfield - Clinton Avenue - Bellevue Avenue to Oak Avenue	\$209,000	Replace	1055	8	PVC	8	VCP	UNK	Likelihood of Failure	90	>2029
7095	HADDONFIELD BORO	Haddonfield - Friends Avenue - Lake Street to East Kings Highway (CR-41)	\$190,000	Replace	924	8	Ductile Iron	8	VCP	UNK	Likelihood of Failure	60	>2029
7097	HADDONFIELD BORO	Haddonfield - Lake Street - Haddon Avenue (CR-561) to Grove Street (CR-644)	\$285,000	Replace	741	8	PVC	8	VCP	UNK	Likelihood of Failure	60	>2029
7099	HADDONFIELD BORO	Haddonfield - West Cottage Avenue - Warwick Road (CR-669) to South Atlantic Avenue	\$228,000	Replace	1125	8	Ductile Iron	8	VCP	UNK	Likelihood of Failure	90	>2029
7101	HADDONFIELD BORO	Haddonfield - Haddon Avenue (CR-561) - Ellis Street (CR-651) to Marne Avenue	\$931,000	Replace	4861	8	PVC	8	VCP	UNK	Likelihood of Failure	90	2029Q4
7359	HADDONFIELD BORO	Haddonfield- Mt Vernon Sewer	\$60,000 - 1M	Replace	233	6	PVC	6	VCP	1900	Likelihood of Failure	30	2029Q4
10839	HADDONFIELD BORO	Haddonfield - Overhill Road SEWER	\$223,000	Replace	500	8	PVC	8	VCP	UNK	Likelihood of Failure	60	2029Q4
13673	OCEAN CITY	Battersea Rd from Wesley Rd to North Street	\$486,000	Replace	1083	12	PVC	12	AC	1960	Consequence of Failure,Relocation / Opportunity	90	2026Q4
13755	EGG HARBOR CITY	Beethoven Street from 7th Terrace to 12th Terrace	\$1,117,600	Replace	2032	10	PVC	10	CLAY	1910	Consequence of Failure,Likelihood of Failure	90	2027Q2
13756	EGG HARBOR CITY	8th Terrace from Beethoven St to Claudius Street	\$1,287,550	Replace	2341	15	PVC	15	DI	1900	Consequence of Failure,Likelihood of Failure	90	2027Q2
13757	EGG HARBOR CITY	8th Terrace from Claudius Street to Buerger Street	\$612,500	Replace	1225	8	PVC	8	CLAY	1910	Likelihood of Failure	90	2028Q2
13759	EGG HARBOR CITY	11th Terrace from Beethoven Street to White Horse Pike, Arago St, 13th Terrace	\$1,291,000	Replace	2339	8	PVC	8	CLAY	1910	Consequence of Failure,Likelihood of Failure	90	2027Q4
13760	EGG HARBOR CITY	8th Terrace from Beethoven St to Atlantic Avenue	\$1,362,900	Replace	1799	8	PVC	8	CLAY	1910	Consequence of Failure,Likelihood of Failure	90	2029Q2
13763	EGG HARBOR CITY	Beethoven Street from 5th Terrace to 8th Terrace, 5th & 6th Terrace	\$1,549,000	Replace	3099	10	PVC	10	CLAY	1910	Likelihood of Failure,Relocation / Opportunity	90	2027Q2
13765	EGG HARBOR CITY	Chicago Avenue from Claudius St to ACMUA Station	\$1,960,750	Replace	3565	12	PVC	12	PVC	1980	Consequence of Failure,Likelihood of Failure	90	2027Q3
13766	EGG HARBOR CITY	Rehab Arago St from 12th Street to 15th Street	\$913,800	Rehab	4569	8	CLAY	8	CLAY	1910	Likelihood of Failure	90	2029Q3
13767	OCEAN CITY	West/Asbury alley from 24th to 29th Street	\$742,750	Rehab	2971	18	CLAY	18	CLAY	1950	Consequence of Failure	90	2026Q2
13768	OCEAN CITY	West/Asbury alley from 19th Street to 24th Street	\$743,500	Rehab	2974	16	CLAY	16	CLAY	1900	Consequence of Failure	90	2027Q1
13770	OCEAN CITY	West/Asbury alley from 32nd St to 34th St	\$298,500	Rehab	1194	18	VCP	18	VCP	1950	Consequence of Failure	90	2027Q1
13802	HADDONFIELD BORO	Haddonfield - Reillywood Avenue Manhole Replacement	\$183,750	Rehab	525	8	CLAY	8	CLAY	1900	Relocation / Opportunity	60	2027Q1
13805	HADDONFIELD BORO	Haddonfield - Reillywood Avenue Manhole Replacement	\$131,250	Rehab	525	8	CLAY	8	CLAY	1900	Consequence of Failure	60	2027Q1
13831	HADDONFIELD BORO	Haddonfield - Graisbury Ave Lining	\$130,000	Rehab	535	10	CLAY	10	CLAY	1900	Consequence of Failure	60	2027Q1
13854	HOWELL TWP	1823 - Augusta Ct (MRRSA-D-08 to MHW-338)	\$193,200	Replace	322	8	PVC	8	AC	1980	Consequence of Failure,Likelihood of Failure	30	2029Q4
13859	HOWELL TWP	1823 - Main along Long Brook Creek - MLK 600 to MLK-719	\$919,200	Rehab	1532	10	PVC	10	PVC	1990	Consequence of Failure,Crossing Risk Reduction,Likelihood of Failure	90	2029Q4
13860	HOWELL TWP	1823 - Bergerville Rd Sewer Siphon & Main - (MRRSA-M-22 to MHW-195)	\$1,200,000	Replace	1195	18	PVC	18	UNK	1980	Consequence of Failure,Crossing Risk Reduction,Likelihood of Failure,Relocation / Opportunity	90	2029Q1
13865	HOWELL TWP	1823 - Rue De St Germaine - (MHW-384 to terminus)	\$595,500	Rehab	794	8	AC	8	AC	1970	Consequence of Failure,Likelihood of Failure	60	2029Q1
13867	HOWELL TWP	1823 - Parkway Drive (MHW-384 to MHW-348)	\$576,000	Rehab	768	8	AC	8	AC	1970	Consequence of Failure,Likelihood of Failure	60	2028Q1
13868	HOWELL TWP	1823 - Parkway Drive (MHW-348 to MHW-352)	\$541,500	Rehab	722	10	AC	10	AC	1970	Consequence of Failure,Likelihood of Failure	60	2029Q1
13869	HOWELL TWP	1823 - Parkway Drive (MHW-352 to MHW-368)	\$751,500	Rehab	1002	8	AC	8	AC	1970	Consequence of Failure,Likelihood of Failure	90	2029Q1
13870	HOWELL TWP	1823 - Chapel Ln & Evesham Rd (MLK-352 to MLK-360)	\$1,215,750	Rehab	1621	10	AC	10	AC	1970	Consequence of Failure,Likelihood of Failure	90	2029Q1
13871	HOWELL TWP	1823 - Corso Italia (MLK-376 to MLK-382)	\$988,500	Rehab	1318	10	AC	10	AC	1970	Consequence of Failure,Likelihood of Failure	90	2029Q1
13872	HOWELL TWP	1823 - Corso Italia - (MHW-380 to MHW-371)	\$1,305,000	Rehab	1740	8	AC	8	AC	1970	Consequence of Failure,Likelihood of Failure	90	2029Q1
13873	HOWELL TWP	1819 - Zacatin Rd (MHW-407 to MHW-403)	\$982,500	Rehab	1310	8	AC	8	AC	1970	Consequence of Failure,Likelihood of Failure	90	2029Q1
13875	HOWELL TWP	1823 - Zacatin Rd & Catle De Elvira (MHW-407 to MHW-710)	\$831,750	Rehab	1109	8	AC	8	AC	1970	Consequence of Failure,Likelihood of Failure	90	2029Q1
13881	LAKEWOOD TWP	Lakewood - Walden Avenue/Kimberly Drive/Chicanos Drive 8"12" AC Main Replacement	\$952,000	Replace	2219	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13882	LAKEWOOD TWP	Lakewood - W. County Line Road/Teaberry Court 8"12" AC Main Replacement	\$1,020,000	Replace	1465	12	PVC	12	AC	1950	Likelihood of Failure	90	2029Q4
13883	LAKEWOOD TWP	Lakewood - Roselle Court & Case Road 8" AC Main Replacement	\$586,500	Replace	1584	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13884	LAKEWOOD TWP	Lakewood - Gergolian Terrace/Laurelwood Avenue/Pinemere Avenue/Heathwood Avenue 8" AC Main Replacement	\$935,000	Replace	2173	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13885	LAKEWOOD TWP	Lakewood - Lake Park Boulevard & Thistle Court 8"12" AC Main Replacement	\$1,275,000	Replace	2985	12	PVC	12	AC	1950	Consequence of Failure,Likelihood of Failure	90	2029Q4
13887	LAKEWOOD TWP	Lakewood - Carnation Drive/Cactus Drive/Cannas Place/Dogwood Court 8" AC Main Replacement	\$1,368,500	Replace	3202	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13888	LAKEWOOD TWP	Lakewood - Hibiscus Drive/Pansy Drive/Poinsettia Court/Poppy Court/Daisy Court 8" AC Main Replacement	\$1,020,000	Replace	2385	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13889	LAKEWOOD TWP	Lakewood - Barbary Drive/Thyme Drive/Wisteria Court/Petunia Drive/Sumac Court/Gladiola Court/Camellia Drive/ Azalea Court 8" AC Main Replacement	\$1,334,500	Replace	3119	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13890	LAKEWOOD TWP	Lakewood - Sunflower Drive/Privet Court/Sage Court/Ivy Court/Begonia Drive/Hedge Drive/Boxwood Drive/Geranium Drive 8"12" AC Main Replacement	\$1,343,000	Replace	3130	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13891	LAKEWOOD TWP	Lakewood - S. Lake Drive 8"12" AC Main Replacement	\$935,000	Replace	2179	12	PVC	12	AC	1950	Likelihood of Failure	90	2029Q4
13892	LAKEWOOD TWP	Lakewood - Lakeview Drive 8"10" AC Main Replacement	\$935,000	Replace	2187	10	PVC	10	AC	1950	Likelihood of Failure	90	2029Q4
13893	LAKEWOOD TWP	Lakewood - S. Lake Drive 8" AC/VCP Main Replacement	\$1,266,500	Replace	3441	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13894	LAKEWOOD TWP	Lakewood - Central Avenue 8" VCP Main Replacement	\$850,000	Replace	1972	8	PVC	8	CLAY	1950	Consequence of Failure,Likelihood of Failure	90	2029Q4
13896	LAKEWOOD TWP	Lakewood - Flintlock Drive 8" AC Main Replacement	\$1,360,000	Replace	3167	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13897	LAKEWOOD TWP	Lakewood - Brill Street & Wayne Street 8" AC Main Replacement	\$612,000	Replace	1431	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13898	LAKEWOOD TWP	Lakewood - Cannonball Drive & Powderhorn Drive 8"12" AC Main Replacement	\$994,500	Replace	2325	12	PVC	12	AC	1950	Likelihood of Failure	90	2029Q4
13899	LAKEWOOD TWP	Lakewood - Powderhorn Drive/Drum Court/Liberty Drive 8" AC Main Replacement	\$1,011,500	Replace	2347	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13900	LAKEWOOD TWP	Lakewood - Hearth Court 8" AC Main Replacement	\$867,000	Replace	2029	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13901	LAKEWOOD TWP	Lakewood - Ashley Avenue/Cedar Bridge Avenue/Martin Luther King Drive 8" AC Main Replacement	\$1,496,000	Replace	3515	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13902	LAKEWOOD TWP	Lakewood - Cedar Bridge Avenue/Arlington Avenue/Elm Street/Melville Avenue 8"12" AC Main Replacement	\$1,283,500	Replace	3015	12	PVC	12	AC	1950	Likelihood of Failure	90	2029Q4
13903	LAKEWOOD TWP	Lakewood - Martin Luther King Drive/Lois Lane/Lincoln Street 8"12" AC Main Replacement	\$1,411,000	Replace	3302	12	PVC	12	AC	1950	Likelihood of Failure	90	2029Q4
13905	LAKEWOOD TWP	Lakewood - Pine Street 12" AC Main Replacement	\$637,500	Replace	1488	12	PVC	12	AC	1950	Likelihood of Failure	90	2029Q4
13906	LAKEWOOD TWP	Lakewood - Marc Drive	\$697,000	Replace	1619	12	PVC	12	AC	1950	Likelihood of Failure	90	2029Q4
13907	LAKEWOOD TWP	Lakewood - Daniel Drive/Ned Drive/Vine Street 8" AC Main Replacement	\$782,000	Replace	1826	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13908	LAKEWOOD TWP	Lakewood - River Avenue/Cedar Street/Henry Street 8"12" AC Replacement	\$1,190,000	Replace	2842	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13909	LAKEWOOD TWP	Lakewood - Cedar Bridge Avenue & Clover Street 20" AC Main Replacement	\$1,385,500	Replace	3938	20	PVC	20	AC	1950	Likelihood of Failure	90	2029Q4
13912	LAKEWOOD TWP	Lakewood - E. Spruce Street 8"12" AC Main Replacement	\$731,000	Replace	1712	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13913	LAKEWOOD TWP	Lakewood - E. Spruce Street & Carol Street 8" AC Main Replacement	\$986,000	Replace	2294	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4

New Jersey American Water Inc.
2026 WSIC Foundational Filing
Appendix A

Id	Municipality	Project Title	NAWC Funded (dollars)	Project Type	Prop. Length (feet)	Prop. Dia. (inches)	Proposed Pipe Material	Ex. Dia. (inches)	Existing Pipe Material	Decade Installed	Accelerated Asset Investment Category	Est Project Duration (Days)	Estimated In Service Quarter
13914	LAKEWOOD TWP	Lakewood - Cypress Avenue/Read Street/Cathy Lane/Towers Street/Mulford Street 8"12" AC/VCP											
13915	LAKEWOOD TWP	Main Replacement	\$1,742,500	Replace	4095	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13916	LAKEWOOD TWP	Lakewood - Buttell Avenue/Henry Street/Williams Street 8" AC Main Replacement	\$960,500	Replace	2230	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13916	LAKEWOOD TWP	Lakewood - Prospect Street 8" AC/VCP Main Replacement	\$1,113,500	Replace	2592	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13917	LAKEWOOD TWP	Lakewood - Elaine Street/Murray Street/Summit Court/Prospect Street (South) 8" AC/VCP Main Replacement											
13918	LAKEWOOD TWP	Replacement	\$1,445,000	Replace	3372	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13918	LAKEWOOD TWP	Lakewood - Route 9 12" AC Main Clean & Line	\$850,000	Rehab	1997	12	AC	12	AC	1950	Consequence of Failure,Likelihood of Failure	90	2029Q4
13919	HOWELL TWP	1819 - Dag Hammarskjold Blvd (MHW-371 to MHW-389)	\$914,250	Rehab	1219	8	AC	8	AC	1970	Consequence of Failure,Likelihood of Failure	90	2029Q1
13920	HOWELL TWP	1819 - Muhlen Platz & Lowens Strasse (MHW-389 to MHW-399)	\$1,563,750	Rehab	2085	8	AC	8	AC	1970	Consequence of Failure,Likelihood of Failure	90	2029Q1
13921	LAKEWOOD TWP	Lakewood - Route 9 10"12" AC Main Clean & Line	\$1,134,750	Rehab	2670	12	AC	12	AC	1950	Consequence of Failure,Likelihood of Failure	90	2029Q4
13922	LAKEWOOD TWP	1832 - Somerset Ave (MLK-420 to MLK-446)	\$1,826,400	Replace	3044	8	PVC	8	CLAY	1950	Consequence of Failure,Likelihood of Failure	90	2029Q1
13923	LAKEWOOD TWP	Lakewood - Route 9 8"12" AC Main Clean & Line	\$990,250	Rehab	2330	12	AC	12	AC	1950	Consequence of Failure,Likelihood of Failure	90	2029Q4
13924	LAKEWOOD TWP	Lakewood - Route 9 and Sherwood Drive 8" AC Main Replacement	\$578,000	Replace	1342	8	PVC	8	AC	1950	Consequence of Failure,Likelihood of Failure	90	2029Q4
13925	LAKEWOOD TWP	Lakewood - W. Spruce Street & Cedar Court 8" VCP Replacement	\$875,500	Replace	2036	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13926	LAKEWOOD TWP	Lakewood - River Avenue 8"12" AC Main Replacement	\$705,500	Replace	1644	12	PVC	12	AC	1950	Likelihood of Failure	90	2029Q4
13927	LAKEWOOD TWP	Lakewood - Princeswood Avenue & Waldorf Terrace 8" AC Main Replacement	\$1,088,000	Replace	2545	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13928	LAKEWOOD TWP	Lakewood - Claire Drive 8"10" AC Main Replacement	\$637,500	Replace	1463	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13929	LAKEWOOD TWP	Lakewood - Hearstone Drive & Rachel Court 8"10" AC Main Replacement	\$969,000	Replace	2254	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13930	LAKEWOOD TWP	Lakewood - Morris Avenue 8"10" AC Main Replacement	\$1,020,000	Replace	2376	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13931	LAKEWOOD TWP	Lakewood - Clairmont Court/Jenna Court/Lancewood Court 8" AC Main Replacement	\$697,000	Replace	1617	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13932	LAKEWOOD TWP	Lakewood - North Drive & Hearstone Drive 8" AC Main Replacement	\$544,000	Replace	1265	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13933	LAKEWOOD TWP	Lakewood - Ocean Avenue 8" VCP Main Replacement	\$1,139,000	Replace	2673	8	PVC	8	CLAY	1950	Consequence of Failure,Likelihood of Failure	90	2029Q4
13934	LAKEWOOD TWP	Lakewood - Ocean Avenue 16" VCP Main Replacement	\$1,020,000	Replace	2383	16	PVC	16	CLAY	1950	Likelihood of Failure	90	2029Q4
13935	LAKEWOOD TWP	Lakewood - Ocean Avenue 8"10"12" AC/VCP Main Replacement	\$799,000	Replace	1859	10	PVC	10	CLAY	1950	Consequence of Failure,Likelihood of Failure	90	2029Q4
13936	LAKEWOOD TWP	Lakewood - S. Clifton Avenue & N. Lake Drive 8"12" VCP Main Replacement	\$1,224,000	Replace	2755	12	PVC	12	CLAY	1950	Likelihood of Failure	90	2029Q4
13937	LAKEWOOD TWP	Lakewood - N. Lake Drive & Private Way 8"12" AC/VCP Main Replacement	\$1,402,500	Replace	3282	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13938	LAKEWOOD TWP	Lakewood - 1st Street 8" VCP Main Replacement	\$807,500	Replace	1872	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13939	LAKEWOOD TWP	Lakewood - 2nd Street 8" VCP Main Replacement	\$790,500	Replace	1841	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13940	LAKEWOOD TWP	Lakewood - 3rd Street 8" VCP Main Replacement	\$824,500	Replace	1915	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13941	LAKEWOOD TWP	Lakewood - 4th Street 8"12" VCP Main Replacement	\$1,147,500	Replace	2673	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13942	LAKEWOOD TWP	Lakewood - 5th Street 8" AC/VCP Main Replacement	\$1,657,500	Replace	3898	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13943	LAKEWOOD TWP	Lakewood - 6th Street 8" VCP Main Replacement	\$1,266,500	Replace	2957	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13944	LAKEWOOD TWP	Lakewood - 7th Street 8"10"12" VCP Main Replacement	\$1,156,000	Replace	2711	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13945	LAKEWOOD TWP	Lakewood - 8th Street 8" VCP Main Replacement	\$1,147,500	Replace	2675	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13946	LAKEWOOD TWP	Lakewood - 11th Street 8"10" VCP Main Replacement	\$875,500	Replace	2041	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13947	LAKEWOOD TWP	Lakewood - 9th Street 8" AC/VCP Main Replacement	\$238,000	Replace	536	8	PVC	8	AC	1950	Likelihood of Failure	60	2029Q4
13948	LAKEWOOD TWP	Lakewood - Carey Street 8" VCP Main Replacement	\$1,173,000	Replace	2745	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13949	LAKEWOOD TWP	Lakewood - 12th Street 8" VCP & 12" AC Main Replacement	\$1,173,000	Replace	2720	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13950	LAKEWOOD TWP	Lakewood - 13th Street & Courtney Road 8" AC/VCP & 12" AC Main Replacement	\$1,020,000	Replace	2377	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13952	LAKEWOOD TWP	Lakewood - 14th Street/15th Street/Hudson Place 8" AC/VCP Main Replacement	\$773,500	Replace	1804	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13953	LAKEWOOD TWP	Lakewood - E. County Line Road 8" AC/VCP Main Replacement	\$1,428,000	Replace	2724	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13954	LAKEWOOD TWP	Lakewood - Forest Avenue 8" AC/VCP Main Replacement	\$977,500	Replace	2297	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13955	LAKEWOOD TWP	Lakewood - Madison Avenue/Route 9 8" AC/VCP Main Clean & Line	\$1,215,500	Rehab	2638	8	CLAY	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13956	LAKEWOOD TWP	Lakewood - Madison Avenue/Route 9 8" AC/VCP Main Clean & Line	\$1,300,500	Rehab	3042	8	CLAY	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13957	LAKEWOOD TWP	Lakewood - Clifton Avenue 8"10" VCP Main Clean & Line	\$1,572,500	Rehab	3696	8	CLAY	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13958	LAKEWOOD TWP	Lakewood - Lexington Avenue 8" AC/VCP Main Clean & Line	\$1,300,500	Rehab	3048	8	CLAY	8	CLAY	1940	Likelihood of Failure	90	2029Q4
13959	LAKEWOOD TWP	Lakewood - Lexington Avenue 8" VCP Main Clean & Line	\$986,000	Rehab	2301	8	CLAY	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13961	LAKEWOOD TWP	Lakewood - Monmouth Avenue & Washington Place 8"12" AC/VCP Main Replacement	\$1,113,500	Replace	2626	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13962	LAKEWOOD TWP	Lakewood - Monmouth Avenue 8" VCP Main Replacement	\$1,062,500	Replace	2496	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13963	LAKEWOOD TWP	Lakewood - Princeton Avenue 8"12" AC Main Replacement	\$1,045,500	Replace	2435	12	PVC	12	AC	1950	Likelihood of Failure	90	2029Q4
13964	LAKEWOOD TWP	Lakewood - E. Kennedy Boulevard 8"12" AC Main Replacement	\$391,000	Replace	898	8	PVC	8	AC	1950	Likelihood of Failure	60	2029Q4
13965	LAKEWOOD TWP	Lakewood - E. County Line Road/Park Place/Harvard Street/Apple Street 8" AC Main Replacement	\$960,500	Replace	2239	8	PVC	8	AC	1950	Likelihood of Failure	90	2029Q4
13966	LAKEWOOD TWP	Lakewood - Ardenwood Avenue 8" VCP Main Replacement	\$297,500	Replace	689	8	PVC	8	CLAY	1940	Likelihood of Failure	60	2029Q4
13967	LAKEWOOD TWP	Lakewood - Madison Avenue & Coventry Square 8"10" VCP Clean & Line	\$1,262,500	Rehab	2970	8	CLAY	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13968	LAKEWOOD TWP	Lakewood - Coventry Square (N. Section) 8"12" AC/VCP Main Clean & Line	\$1,253,750	Rehab	3081	8	AC	8	AC	1950	Likelihood of Failure	90	2029Q4
13970	LAKEWOOD TWP	Lakewood - Coventry Square (Central Section) 8" AC/VCP Main Clean & Line	\$1,564,000	Rehab	3678	8	AC	8	AC	1950	Likelihood of Failure	90	2029Q4
13971	LAKEWOOD TWP	Lakewood - Coventry Square (S. Section) 8" AC/VCP Main Clean & Line	\$1,623,500	Rehab	3819	8	AC	8	AC	1950	Likelihood of Failure	90	2029Q4
13973	LAKEWOOD TWP	Lakewood - Monmouth Avenue/Coventry Square 8" UNK Force Main Line & Clean	\$408,000	Rehab	960	8	UNK	8	UNK	1900	Consequence of Failure,Likelihood of Failure	60	2029Q4
13980	LAKEWOOD TWP	Lakewood - Hope Hill Lane & Hill Top Court 2" UNK Main Replacement	\$170,000	Replace	377	2	PVC	2	UNK	2010	Likelihood of Failure,Sustained Economic Growth	30	2029Q4
13981	LAKEWOOD TWP	Lakewood - Hurley Avenue & S. Clifton Avenue 8"12" VCP Main Replacement	\$539,750	Replace	1254	12	PVC	12	CLAY	1950	Likelihood of Failure	90	2029Q4
13982	LAKEWOOD TWP	Lakewood - E. 7th Street & Somerset Avenue 8" AC/VCP Main Replacement	\$850,000	Replace	1973	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13983	LAKEWOOD TWP	Lakewood - Ridge Avenue 8" VCP Main Replacement	\$391,000	Replace	909	8	PVC	8	CLAY	1950	Likelihood of Failure	60	2029Q4
13984	LAKEWOOD TWP	Lakewood - Linden Avenue/E. Bergen Avenue/Stirling Avenue 8" AC/VCP Main Replacement	\$884,000	Replace	2059	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13985	LAKEWOOD TWP	Lakewood - N. Oakland Street 8" VCP Main Replacement	\$501,500	Replace	1145	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13986	LAKEWOOD TWP	Lakewood - Ridge Avenue & Westwood Place 8" VCP Main Replacement	\$1,071,000	Replace	2504	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13987	LAKEWOOD TWP	Lakewood - E. 5th Street/Negba Street/School Street 8" VCP Main Replacement	\$1,283,500	Replace	3010	8	PVC	8	CLAY	1950	Consequence of Failure,Likelihood of Failure	90	2029Q4
13988	LAKEWOOD TWP	Lakewood - Bergen Avenue/Cottage Place/Sampson Avenue 8" AC/VCP Main Replacement	\$748,000	Replace	1732	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4
13989	LAKEWOOD TWP	Lakewood - Bruce Street/Dewey Avenue/Congress Street 8" AC/VCP Main Replacement	\$391,000	Replace	896	8	PVC	8	CLAY	1950	Likelihood of Failure	60	2029Q4
13990	SALEM CITY	Salem - Smith Street	\$716,000	Replace	895	8	PVC	8	VCP	UNK	Consequence of Failure,Likelihood of Failure	60	2026Q3
13991	SALEM CITY	Salem Sewer - Eakin Street and 9th Street	\$2,696,000	Replace	3370	8	PVC	8	UNK	1900	Likelihood of Failure	90	2028Q1
13993	LAKEWOOD TWP	Lakewood - Canterbury Road 8" VCP Main Replacement	\$748,000	Replace	1747	8	PVC	8	CLAY	1950	Likelihood of Failure	90	2029Q4

New Jersey American Water Inc.
2026 WSIC Foundational Filing
Appendix A

Id	Municipality	Project Title	NJAWC Funded (dollars)	Project Type	Prop. Length (feet)	Prop. Dia. (inches)	Proposed Pipe Material	Ex. Dia. (inches)	Existing Pipe Material	Decade Installed	Accelerated Asset Investment Category	Est Project Duration (Days)	Estimated In Service Quarter
14007	BOUND BROOK BORO	Watchung Road sanitary sewer replacement	\$246,500	Replace	3421	8	PVC	8	UNK	1900	Likelihood of Failure	90	2026Q3
14008	MANVILLE BORO	Fable Ave Sewer Main Extension	\$17,000	Replace	94	8	PVC	8	PVC	1900	Likelihood of Failure	30	2026Q3
14009	BOUND BROOK BORO	East Main St Sanitary Sewer replacement/relocation	\$9,400	Replace	93	15	PVC	15	UNK	1900	Consequence of Failure,Crossing Risk Reduction,Likelihood of Failure,Relocation / Opportunity	30	2026Q3
14010	BOUND BROOK BORO	North St sewer main replacement	\$2,800	Replace	239	8	PVC	8	PVC	1900	Likelihood of Failure	30	2026Q3
14011	BOUND BROOK BORO	Vosseller Ave sanitary sewer replacement	\$50,000	Replace	504	8	PVC	8	UNK	1900	Consequence of Failure,Likelihood of Failure	60	2026Q3
14012	MANVILLE BORO	N 10th Ave Sewer main replacement	\$49,500	Replace	495	8	PVC	8	UNK	1900	Consequence of Failure,Likelihood of Failure	30	2026Q4
14037	LAKEWOOD TWP	Lakewood - Caranetta Drive 8" VCP Main Replacement	\$85,000	Replace	187	8	PVC	8	CLAY	1950	Likelihood of Failure	30	2029Q4
14038	LAKEWOOD TWP	Lakewood - River Avenue Rt. 9 8" VCP Replacement	\$314,500	Replace	727	8	PVC	8	CLAY	1950	Consequence of Failure,Likelihood of Failure	60	2029Q4
14040	MOUNT EPHRAIM BORO	Mt Ephraim - Harding Avenue Sewer Replacement	\$100,000	Replace	390	8	PVC	8	CLAY	1900	Consequence of Failure	30	2028Q1