STATE OF NEW JERSEY
DEPARTMENT OF COMMUNITY AFFAIRS
DIVISION OF CODES AND STANDARDS
BUREAU OF ROOMING AND BOARDING HOUSE STANDARDS
(609) 984-1704

PAGE 1 OF 3
Control No. 0101-F-0010
No. of Stories 2 Units 5
Lic. Capacity 9 No. of Res. 9
Class F
DATE: 4-1-25

BRBHS-1
10/22

EVALUATION REPORT AND ORDERS OF THE COMMISSIONER

Owner's Name, Address, Zip, County	Property Address
COASTAL RECOVERY SOLUTIONS LLC	120 S. 10TH AVENUE
	ABSECON
Owner's Phone Number	Property Phone Number
Administrator	

TYPE OF EVALUATION

SOCIAL	☒	ADDENDUM	☐
PHYSICAL	☒	CYCLICAL	☒

-PLEASE READ CAREFULLY-

This evaluation performed by the Bureau of Rooming and Boarding House Standards is being conducted pursuant to the ROOMING AND BOARDING HOUSE ACT OF 1979 (N.J.S.A. 55:13B-1 et seq)

You are ORDERED to correct the conditions described in the attached notice of violations by the compliance date indicated for each violation. Failure to comply with these orders will result in penalties and/or a court action in accordance with the Act. Please review the violations with the Bureau representative.

You may contest these orders at an administrative hearing. The request for a hearing must be made within 15 days after receipt of these orders. Each issue intended to be raised at the hearing must be set forth in detail in the letter. Any issue not so raised shall be deemed waived. The hearing shall be held pursuant to The Administrative Procedure Act, (C.52:14B-1 et seq.). Refer to the property address and date of compliance (if applicable) and address the hearing request to:

> **Division of Codes and Standards, Hearing Coordinator, P.O. Box 804, Trenton, New Jersey 08625** with a copy to the **Chief, Bureau of Rooming and Boarding House Standards**, at the same address. A corporation may be represented only by a licensed attorney.
>
> **You will be notified of the time and place of the hearing.**

If you find an extension of time necessary to abate any violation, a letter must be submitted two (2) weeks prior to the date of compliance which states in detail: (1) The violations abated to date; (2) The reason why each unabated violation cannot be corrected prior to the date of penalty; and (3) The date by which all violations can be abated.

By requesting an extension, one expressly waives the right to a hearing and admits that the Notice and Orders are correct and free from procedural and substantive defects.

Commissioner

S. Brad
Received By

By *Bernard A. Raywood, Chief*
Bureau of Rooming and Boarding House Standards

Printed Name of Person Served

4/1/25
Date Time Served

NEIL BOGHEAN
Bureau Representative

White – Owner's Copy Yellow – File Copy Pink and Goldenrod – Evaluator Copies

CamScanner

0101 - 0010
120 S. 10TH AVENUE ABSECON

EVALUATION REPORT AND ORDERS OF THE COMMISSIONER

NJAC

Administrative Code Reference		Compliance Date	Reinspection Date	Compliance Date
	FIRE CERTIFICATE EXP 1/28/26			
	OWNER LICENSE EXP 7/31/25			
	OPERATOR LICENSE EXP 7/31/25			
	FIRST FLOOR			
5:27 13.3(c)	Room 1 - REMOVE KEYED	5/1/25		
	DOOR LOCK. PRIVACY LOCK			
	ONLY ALLOWED			
5:27 4.4(c)	- PROVIDE OUTLET COVERS	5/1/25		
	WHERE MISSING			
5:27 4.4(c)	- PROVIDE SWITCH PLATE COVERS	5/1/25		
	WHERE MISSING			
5:27 13.3(b)	- PROVIDE LOCKBOX FOR EACH	5/1/25		
	RESIDENT			
5:27 4.7(a)	COMMON BATH - REPAIR SHOWER	5/1/25		
	WALL SURFACE			
5:27 13.3(c)	Room 2 - REMOVE KEYED	5/1/25		
	DOOR LOCK. PRIVACY LOCK ONLY			
5:27 13.3(b)	PROVIDE LOCKBOX FOR EACH	5/1/25		
	RESIDENT			
	SECOND FLOOR			
5:27 13.3(c)	Room 3 - REMOVE KEYED DOOR	5/1/25		
	LOCK. PRIVACY LOCK ONLY			
	COMMON BATH - NO VIOLATION			
	Room 4 - NO VIOLATION			
	Room 5 - NO VIOLATION			

CamScanner

120 S 10th 0101 – 0010 AVENUE ABSECON

EVALUATION REPORT AND ORDERS OF THE COMMISSIONER

NJAC

Administrative Code Reference		Compliance Date	Reinspection Date	Compliance Date
	SECOND FLOOR CONTINUED			
	COMMON HALL - NO VIOLATION			
	STOREAGE ROOMS - NO VIOLATION			
	EXTERIOR			
5:27 4.7(n)	- REPLACE OUTLET TO LEFT	5/1/25		
	OF ENTRY DOOR WITH			
	GFCI OUTLET. CURRENT			
	OUTLET HAS GROUND PINS			
	BROKEN IN BOTH RECEPTACLES			
5:27 4.7(n)	- CAP LOOSE WIRE (NEUTRAL) (WHITE)	5/1/25		
	ON REAR BUILDING AND			
[illegible]	CONTAIN WIRE IN JUNCTION	[illegible]		
	BOX WITH COVER REINSTALLED			
5:27 4.7(b)	- REPLACE BROKEN DECK	5/1/25		
	BOARD ON RIGHT SIDE			
	OF HOUSE			

CamScanner