STATE OF NEW JERSEY
DEPARTMENT OF COMMUNITY AFFAIRS
DIVISION OF CODES AND STANDARDS
BUREAU OF ROOMING AND BOARDING HOUSE STANDARDS
(609) 633-6251

BRBHS-1
8/02

POSTED

PAGE 1 of 3
Control No. 0121-F-0017
License No.
Type of Construction Frame
No. of Stories 2 Units 8 Bedrooms
Lic. Capacity 10 No. of Res. 9
Class F
DATE: 6/19/24

◄ EVALUATION REPORT AND ORDERS OF THE COMMISSIONER ►

Owner's Name, Address, Zip, County	Property Address, Zip, County
Hansen House, LLC	6 Braddock Drive
[redacted]	Somers Point, NJ
Owner's Phone Number	Property Phone Number
Operator's Name	

TYPE OF EVALUATION

SOCIAL ☑ ADDENDUM ☐
PHYSICAL ☑ CYCLICAL ☑

— PLEASE READ CAREFULLY —

This evaluation performed by the Bureau of Rooming and Boarding House Standards is being conducted pursuant to the Rooming and Boarding House Act of 1979. (N.J.S.A. 55:13B-1 et seq.).

You are ORDERED to correct the conditions described in the attached notice of violations by the compliance date indicated for each violation. Failure to comply with these orders will result in penalties and/or a court action in accordance with section 10 and 11 of the Act. Please review the violations with the Bureau representative.

You may contest these orders at an administrative hearing. The request for a hearing must be made within 15 days after receipt of these orders. Each issue intended to be raised at the hearing must be set forth in detail in the letter. Any issue not so raised shall be deemed waived. The hearing shall be held pursuant to The Administrative Procedure Act, (C.52:14B□1 et seq.). Refer to the property address and date of compliance (*if applicable*) and address the hearing request to:

> **Division of Codes and Standards, Hearing Coordinator, P.O. Box 804, Trenton, New Jersey 08625** with a copy to the **Chief, Bureau of Rooming and Boarding House Standards**, at the same address. A corporation may be represented only by a licensed attorney.
>
> **You will be notified of the time and place of the hearing.**

If you find an extension of time necessary to abate any violation, a letter must be submitted two (2) weeks prior to the date of compliance which states in detail: (1) The violations abated to date; (2) The reason why each unabated violation cannot be corrected prior to the date of penalty; and (3) The date by which all violations can be abated.

By requesting an extension, one expressly waives the right to a hearing and admits that the Notice and Orders are correct and free from procedural and substantive defects.

Received By
DAVID CURRY
Printed Name of Person Served
6/19/24
Date Time Served

Commissioner
By Jay Raywood
Bureau of Rooming and Boarding House Standards

William Murray
Bureau Representative Evaluator #

White – Owner's Copy Yellow – File Copy Pink and Goldenrod – Evaluator Copies

CamScanner

[X] NJAC 5:27
[ ] NJAC 5:27A

6 Braddock Drive Somers Point, NJ 0121-F-0017

EVALUATION REPORT AND ORDERS OF THE COMMISSIONER

Administrative Code Reference		Compliance Date	Reinspection Date	Compliance Date
	Fire cert exp. 1/19/24			
5:27 1.3(c)4	Provide current fire certificate	7/19/24	Abated 6/19/24	
	Owner lic exp. 10/31/24			
	Operator lic. exp 10/31/23			
5:27 1.6(a)6	Provide current DCA Operator License	7/19/24	Abated	
	2nd Floor			
	Bedroom (Left of stairs)			
	-No violations			
	Bedroom (Right of stairs)			
	-No violations			
	Common hallway			
	-No violations			
	Common bathroom (Full)			
	-No violations			
	1st Floor			
	Bedroom (Left of bathroom)			
	-No violations			
	Occupied by operator. Bedroom (Right of bathroom)			
	Bedroom (Across from bathroom)			
	-No violations			
	Common hallway			
	-No violations			
	Common bathroom (Full)			
	-No violations			

9/11/24

CamScanner

[X] NJAC 5:27
[ ] NJAC 5:27A

6 Braddock Drive Somers Point, NT 0121-F-0017

EVALUATION REPORT AND ORDERS OF THE COMMISSIONER

Administrative Code Reference		Compliance Date	Reinspection Date	Compliance Date
	1st Floor con't			
	Common kitchen			
	-No violations			
	Dining room			
	-No violations			
	Living room			
	-No violations			
	Basement			
	Bedroom (Across from bathroom)			
	-No violations		9/11/24	
	Bedroom (Left of bathroom)			
	-No violations			
	Bedroom (Right of bathroom)			
	-No violations			
	Common entrance			
	- No violations			
	Common bathroom (Full)			
	-No violations			
	Common kitchen			
5:27 4.7(a)	- Damaged plywood inside	7/19/24	Abated	
	cabinet and underneath			
	sink shall be replaced.			
	Dining room / Living room			
	-No violations			
	Exterior			
	-No violations			

CamScanner