STATE OF NEW JERSEY
DEPARTMENT OF COMMUNITY AFFAIRS
DIVISION OF CODES AND STANDARDS
BUREAU OF ROOMING AND BOARDING
HOUSE STANDARDS
(609) 984-1704

ENFORCEMENT
POSTED

PAGE 1 OF 3
Control No. 0337-0007
No. of Stories 2 Units 3 rms
Lic. Capacity 4 No. of Res. 7
Class F
DATE: 7/19/24

BRBHS-1
10/22

EVALUATION REPORT AND ORDERS OF THE COMMISSIONER

Owner's Name, Address, Zip, County	Property Address
Real to Redemption LLC	220 2nd Street
	Westampton
Owner's Phone Number	Property Phone Number
Administrator	

TYPE OF EVALUATION

SOCIAL	☒	ADDENDUM	☐
PHYSICAL	☒	CYCLICAL	☒

-PLEASE READ CAREFULLY-

This evaluation performed by the Bureau of Rooming and Boarding House Standards is being conducted pursuant to the ROOMING AND BOARDING HOUSE ACT OF 1979 (N.J.S.A. 55:13B-1 et seq)

You are ORDERED to correct the conditions described in the attached notice of violations by the compliance date indicated for each violation. Failure to comply with these orders will result in penalties and/or a court action in accordance with the Act. Please review the violations with the Bureau representative.

You may contest these orders at an administrative hearing. The request for a hearing must be made within 15 days after receipt of these orders. Each issue intended to be raised at the hearing must be set forth in detail in the letter. Any issue not so raised shall be deemed waived. The hearing shall be held pursuant to The Administrative Procedure Act, (C.52:14B-1 et seq.). Refer to the property address and date of compliance (if applicable) and address the hearing request to:

Division of Codes and Standards, Hearing Coordinator, P.O. Box 804, Trenton, New Jersey 08625 with a copy to the **Chief, Bureau of Rooming and Boarding House Standards**, at the same address. A corporation may be represented only by a licensed attorney.

You will be notified of the time and place of the hearing.

If you find an extension of time necessary to abate any violation, a letter must be submitted two (2) weeks prior to the date of compliance which states in detail: (1) The violations abated to date; (2) The reason why each unabated violation cannot be corrected prior to the date of penalty; and (3) The date by which all violations can be abated.

By requesting an extension, one expressly waives the right to a hearing and admits that the Notice and Orders are correct and free from procedural and substantive defects.

Commissioner

By *Bernard A. Raywood, Chief*
Bureau of Rooming and Boarding House Standards

Received By

Printed Name of Person Served

7-19-2024
Date Time Served

Bureau Representative

White – Owner's Copy Yellow – File Copy Pink and Goldenrod – Evaluator Copies

Scanned with CamScanner

[X] NJAC 5:27 220 2nd St Westampton
[ ] NJAC 5:27A **EVALUATION REPORT AND ORDERS OF THE COMMISSIONER**

Administrative Code Reference		Compliance Date	Reinspection Date	Compliance Date
	Owner Lic - 11/30/23 exp			
	Operator Lic - 4/30/24 exp			
	Fire Cert - None			
1.6(a)	- Shall provide current	8/19/24	No	
	Class F license to operate			
1.6(a)	- Shall provide current	8/19/24	NO	
	Class F License to own			
1.3(a)4	- Shall provide current	8/19/24	NO	
	Uniform Fire Col Certificate			
3.2(a)	- Shall post house	8/19/24	Yes	
	rules			
3.2(a)	- Shall post residents	8/19/24	yes	9/16/24
	rights			
1.6(a)	- Shall decrease	8/19/24	yes	9/16/24
	amount of tenants from			
	7 to 4 to meet			
	capacity allowed by			
	License			
	- First Floor			
	Kitchen			
	- No violations			
	Living Room			
	- No violations			
	Common Bathroom 1			
	- No violations			
	Common Bathroom 2			
	- No violations			

Scanned with CamScanner

[X] NJAC 5:27 220 2nd Street Westampton
[ ] NJAC 5:27A **EVALUATION REPORT AND ORDERS OF THE COMMISSIONER**

Administrative Code Reference		Compliance Date	Reinspection Date	Compliance Date
	Room 1			
	- No violations			
	Room 2			
	- No violations			
	Room 3			
1.3(a)1	- Shall repair smoke	8/19/24	yes	
	alarm			
	- Second Floor -			
4.4(c)	- Shall not use area	8/19/24	yes	
	as sleeping quarters			
4.4.a	2 beds must be removed.			9/12/24
	Ceiling height is 6'4"			
	and room does not meet			
	fire window requirements			
	- Basement -			
	- No violations			
	- Exterior -			
	- No violations			
	End of Report			

WHITE ~ Owner Copy YELLOW ~ File Copy PINK and GOLDENROD ~Evaluator Copies

Scanned with CamScanner