



State of New Jersey
DEPARTMENT OF COMMUNITY AFFAIRS
101 SOUTH BROAD STREET
PO BOX 802
TRENTON, NJ 08625-0802

CHRIS CHRISTIE
Governor

KIM GUADAGNO
Lt. Governor

RICHARD E. CONSTABLE, III
Commissioner

November 2012

The Department has issued the following guidance for use in addressing electrical systems in the aftermath of Hurricane Sandy:

- Panel underwater
 - Pull the meter
 - Clean and dry all breakers and bus bar
 - Reinstall breakers necessary for temporary occupancy and restoration
 - Within 90 days, all breakers and bus bar must be replaced. In lieu of replacement, the bus bar may be certified by a licensed electrical contractor
- Wiring underwater
 - If undamaged, no replacement is necessary
- Other equipment and outlets (receptacles, lighting, switches, alarms, etc.) underwater
 - Within 90 days, all other equipment and outlets must be replaced