



PHILIP D. MURPHY
Governor

State of New Jersey
DEPARTMENT OF COMMUNITY AFFAIRS
101 SOUTH BROAD STREET
PO Box 802
TRENTON, NJ 08625-0802



LT. GOVERNOR SHEILA Y. OLIVER
Commissioner

BULLETIN 95-1

Issued: September 1995 Revised: September 2017
Subject: Flammable and Combustible Liquid Storage Tanks
Reference: N.J.A.C. 5:23-3.4, 3.11B; 3.20 and 3.21; N.J.A.C. 7:14B-4

Over the past several years, the Department of Community Affairs has issued a number of bulletins on flammable and combustible liquid storage tanks. Each of these bulletins addressed a specific issue related to these tanks. This bulletin consolidates all of these issues into one bulletin for convenient reference.

This bulletin is divided into four separate bulletins (95-1A, 1B, 1C, and 1D). Each bulletin deals with either the installation or the removal/abandonment of certain types of tanks.

For all heating-oil tanks less than 2,001 gallons, Bulletin 95-1A for installation and Bulletin 95-1B for removal/abandonment are applicable.

For commercial heating-oil tanks 2,001 gallons and over, waste-oil tanks and gasoline tanks of any size (UCC and NJ DEP regulated), Bulletin 95-1C for installation and Bulletin 95-1D for removal/abandonment are applicable.