



CERTIFICATE OF ANALYSIS

Customer : Whitman
7 Pleasant Hill Road
Cranbury, NJ 08512

Project ID : Cape May Campus
PAS Project ID : P17-0844

Matrix : Drinking Water
Report Date : 3/2/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0844-01	CR-107-CM	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 11:48	2/24/17 12:47
P17-0844-02	CR-108-CM	Lead	0.488 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 11:50	2/24/17 12:51
P17-0844-03	CR-111-CM	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 11:53	2/24/17 12:56
P17-0844-04	CR-115-CM	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 11:55	2/24/17 13:00
P17-0844-05	OFFICE-105-CM	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 11:58	2/24/17 13:13
P17-0844-06	KITCHEN-103-CM	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 12:00	2/24/17 13:17
P17-0844-07	KITCHEN-ICE MACHINE-CM	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 12:03	2/24/17 13:22
P17-0844-08	CR-125-CM	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 12:04	2/24/17 13:26
P17-0844-09	CR-120-CM	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 12:05	2/24/17 13:30
P17-0844-10	FIELD BLANK-CM	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/21/17 12:07	2/24/17 13:35

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

B = Compound found in blank and samples

E = Concentration exceeds calibration range

J = Estimated result

* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director