



CERTIFICATE OF ANALYSIS

Customer : Whitman
7 Pleasant Hill Road
Cranbury, NJ 08512

Project ID : Cumberland Campus
PAS Project ID : P17-0855

Matrix : Drinking Water
Report Date : 3/3/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0855-01	KITCHEN-HAND SINK	Lead	2.80	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:28	2/27/17 11:12
P17-0855-02	STAFF RM #105-HAND SINK	Lead	0.754 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:29	2/27/17 11:16
P17-0855-03	RM #107-HAND SINK	Lead	3.92	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:30	2/27/17 11:20
P17-0855-04	RM #108-HAND SINK	Lead	1.87 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:32	2/27/17 11:24
P17-0855-05	RM #115-HAND SINK	Lead	2.06	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:33	2/27/17 11:41
P17-0855-06	RM #111-HAND SINK	Lead	2.24	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:36	2/27/17 11:46
P17-0855-07	RM #112-HAND SINK	Lead	0.754 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:37	2/27/17 11:50
P17-0855-08	FIELD BLANK CUMBERLAND	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 08:40	2/27/17 11:54

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

B = Compound found in blank and samples

E = Concentration exceeds calibration range

J = Estimated result

* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director