



CERTIFICATE OF ANALYSIS

Customer : Whitman
7 Pleasant Hill Road
Cranbury, NJ 08512

Project ID : Essex Campus
PAS Project ID : P17-0857

Matrix : Drinking Water
Report Date : 3/3/2017

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P17-0857-01	01-EC-KITCHEN-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 09:00	2/27/17 13:21
P17-0857-02	02-EC-STAFF RM-BU	Lead	0.567 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 09:02	2/27/17 13:25
P17-0857-03	03-EC-MAIN OFFICE-BU	Lead	1.31 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 09:04	2/27/17 13:29
P17-0857-04	04-EC-RM 10-BU	Lead	0.567 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 09:05	2/27/17 13:33
P17-0857-05	05-EC-RM 9-BU	Lead	0.567 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 09:08	2/27/17 13:37
P17-0857-06	06-EC-RM 8-BU	Lead	2.06	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 09:10	2/27/17 13:42
P17-0857-07	07-EC-RM 7-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 09:11	2/27/17 13:46
P17-0857-08	08-EC-RM 6-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 09:12	2/27/17 14:03
P17-0857-09	09-EC-RM 4-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 09:13	2/27/17 14:07
P17-0857-10	10-EC-RM 5-BU	Lead	1.50 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 09:14	2/27/17 16:21
P17-0857-11	11-EC-RM 3-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 09:15	2/27/17 16:25
P17-0857-12	12-EC-RM 2-BU	Lead	0.754 J	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 09:17	2/27/17 16:29
P17-0857-13	13-EC-RM 1-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 09:18	2/27/17 16:34
P17-0857-14	14-EC-FIELD BLANK-BU	Lead	ND	ug/L	1	2.00	0.462	15.0 *	SM 3113 B	2/20/17 09:19	2/27/17 16:38

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

B = Compound found in blank and samples

E = Concentration exceeds calibration range

J = Estimated result

* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director