



## CERTIFICATE OF ANALYSIS

**Customer :** Whitman  
7 Pleasant Hill Road  
Cranbury, NJ 08512

**Project ID :** 540 Route 57E  
**PAS Project ID :** P17-0847

**Matrix :** Drinking Water  
**Report Date :** 3/2/2017

| PAS Sample ID | Client ID              | Analysis | Results | Units | DF | PQL  | MDL   | MCL    | Method    | Date Sampled  | Date Analyzed |
|---------------|------------------------|----------|---------|-------|----|------|-------|--------|-----------|---------------|---------------|
| P17-0847-01   | 540-01: 105/STAFF ROOM | Lead     | ND      | ug/L  | 1  | 2.00 | 0.462 | 15.0 * | SM 3113 B | 2/20/17 14:33 | 2/24/17 10:52 |
| P17-0847-02   | 540-02: 103/KITCHEN    | Lead     | ND      | ug/L  | 1  | 2.00 | 0.462 | 15.0 * | SM 3113 B | 2/20/17 14:35 | 2/24/17 11:00 |
| P17-0847-03   | 540-03: CLASSROOM 107  | Lead     | ND      | ug/L  | 1  | 2.00 | 0.462 | 15.0 * | SM 3113 B | 2/20/17 14:37 | 2/24/17 11:13 |
| P17-0847-04   | 540-04: CLASSROOM 108  | Lead     | ND      | ug/L  | 1  | 2.00 | 0.462 | 15.0 * | SM 3113 B | 2/20/17 14:39 | 2/24/17 11:25 |
| P17-0847-05   | 540-05: CLASSROOM 111  | Lead     | ND      | ug/L  | 1  | 2.00 | 0.462 | 15.0 * | SM 3113 B | 2/20/17 14:41 | 2/24/17 11:30 |
| P17-0847-06   | 540-06: CLASSROOM 112  | Lead     | ND      | ug/L  | 1  | 2.00 | 0.462 | 15.0 * | SM 3113 B | 2/20/17 14:42 | 2/24/17 11:34 |
| P17-0847-07   | 540-07: CLASSROOM 115  | Lead     | ND      | ug/L  | 1  | 2.00 | 0.462 | 15.0 * | SM 3113 B | 2/20/17 14:44 | 2/24/17 11:38 |
| P17-0847-08   | 540-08: FIELD BLANK    | Lead     | ND      | ug/L  | 1  | 2.00 | 0.462 | 15.0 * | SM 3113 B | 2/20/17 00:44 | 2/24/17 11:42 |

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

B = Compound found in blank and samples

E = Concentration exceeds calibration range

J = Estimated result

\* Federal Action Level

All samples are analyzed in accordance with  
New Jersey Department of Environmental  
Protection Protocol

Mark D. Feitelson, Lab. Director