



March 16, 2026

Ref: 021866.013

Mr. Joseph Lenahan
Operations Manager
Office of Education
New Jersey Department of Children and Families
PO Box 710
Trenton, NJ 08625

Re: Lead and Copper in Drinking Water Testing
DCF Regional School – Cherry Hill Campus
30 West Evesham Road
Cherry Hill Township, NJ 08003

Dear Mr. Lenahan,

Vanasse Hangen Brustlin Inc. (VHB) was retained to perform drinking water testing at the New Jersey Department of Children and Families (DCF) Regional Cherry Hill Campus located at 30 West Evesham Road, Cherry Hill Township, New Jersey (subject property). VHB performed the sampling on February 21, 2026. The purpose of the testing was to determine if lead or copper may be present above the established regulatory limits in Client-identified drinking water sources within the subject building.

METHODS

Samples of potable water were collected from each location where water may be used for drinking or food preparation. Sampling protocol included the following:

- Samples were collected on a Saturday when the school was not occupied.
- The sample locations were flushed for several minutes by the Client the day prior to collecting the samples.
- The Client was instructed to not use water from the sampling locations during the overnight period or morning prior to collecting the samples.
- Samples were collected at the Client-identified sampling locations starting with the location nearest to the water service point of entry to the building.
- Each sampling location was inspected for evidence that the water had been used that day prior to collecting the first draw samples (i.e. dripping faucet, water residue in basin).
- Each location was checked to verify whether water treatment (filter/bubbler) was or was not in use.
- Two (2) samples were collected at each location. The first sample is a first-draw sample collected from

1805 Atlantic Avenue

Engineers | Scientists | Planners | Designers

Manasquan, New Jersey 08736

P 732.223.2225



the tap after the overnight resting period. The second is a flush sample collected after running water for 30 seconds.

- Samples were collected in 250 mL bottles.
- Bottles were labeled, and chain-of-custody completed for each sample.
- Samples were dropped off at the laboratory.
- The laboratory accessioned the samples and added the necessary preservatives within the allowable timeframe.

Samples were delivered under chain-of-custody to EMSL Analytical, Inc. (EMSL) 200 US-130 North, Cinnaminson, New Jersey 08077. EMSL is a New Jersey Department of Environmental Protection (NJDEP) Certified Drinking Water Laboratory.

The regulatory limits for lead and copper are established by the United States Environmental Protection Agency (EPA) under the Safe Drinking Water Act – Lead and Copper Rule (LCR). The LCR established an action level of 0.015 mg/L (15 ppb) for lead and 1.3 mg/L (1300 ppb) for copper. The New Jersey Department of Education (NJDOE) and New Jersey Department of Health (NJDOH) have adopted these limits as well.

RESULTS

TABLE 1					
SUMMARY OF LABORATORY ANALYSIS RESULTS – LEAD (Pb)					
Sample ID	FD/FL	Location	Treatment in Use	Result (PPB)	MCL (PPB)
CH-01-FD	FD	Kitchen	Yes	<1.00	15
CH-01-FL	FL	Kitchen	Yes	NA	15
CH-02-FD	FD	Kitchen Machine	Yes	<1.00	15
CH-02-FL	FL	Kitchen Machine	Yes	NA	15
CH-03-FD	FD	Teacher’s Lounge	Yes	<1.00	15
CH-03-FL	FL	Teacher’s Lounge	Yes	NA	15
CH-04-FD	FD	Room 113	Yes	<1.00	15
CH-04-FL	FL	Room 113	Yes	NA	15
CH-05-FD	FD	Room 114	Yes	<1.00	15
CH-05-FL	FL	Room 114	Yes	NA	15
CH-06-FD	FD	Room 115	Yes	<1.00	15
CH-06-FL	FL	Room 115	Yes	NA	15
CH-07-FD	FD	Room 106	Yes	<1.00	15
CH-07-FL	FL	Room 106	Yes	NA	15
CH-08-FD	FD	Room 111	Yes	<1.00	15
CH-08-FL	FL	Room 111	Yes	NA	15
CH-09-FD	FD	Hallway Fountain	Yes	<1.00	15
CH-09-FL	FL	Hallway Fountain	Yes	NA	15
CH-10-FD	FD	Room 107	Yes	<1.00	15
CH-10-FL	FL	Room 107	Yes	NA	15
CH-11-FD	FD	Room 110	Yes	<1.00	15



CH-11-FL	FL	Room 110	Yes	NA	15
CH-12-FD	FD	Room 109	Yes	2.10	15
CH-12-FL	FL	Room 109	Yes	NA	15
CH-13-FD	FD	Room 108	Yes	<1.00	15
CH-13-FL	FL	Room 108	Yes	NA	15
CH-14-FD	FD	Room 123	Yes	<1.00	15
CH-14-FL	FL	Room 123	Yes	NA	15
CH-15-FD	FD	Room 121	Yes	<1.00	15
CH-15-FL	FL	Room 121	Yes	NA	15

MCL – Maximum Contaminant Level; NA – Not Analyzed; FD – First Draw; FL – Flush

TABLE 2					
SUMMARY OF LABORATORY ANALYSIS RESULTS – COPPER (Cu)					
Sample ID	FD/FL	Location	Treatment in Use	Result (PPB)	MCL (PPB)
CH-01-FD	FD	Kitchen	Yes	<35	1300
CH-01-FL	FL	Kitchen	Yes	NA	1300
CH-02-FD	FD	Kitchen Machine	Yes	<35	1300
CH-02-FL	FL	Kitchen Machine	Yes	NA	1300
CH-03-FD	FD	Teacher's Lounge	Yes	<35	1300
CH-03-FL	FL	Teacher's Lounge	Yes	NA	1300
CH-04-FD	FD	Room 113	Yes	<35	1300
CH-04-FL	FL	Room 113	Yes	NA	1300
CH-05-FD	FD	Room 114	Yes	<35	1300
CH-05-FL	FL	Room 114	Yes	NA	1300
CH-06-FD	FD	Room 115	Yes	<35	1300
CH-06-FL	FL	Room 115	Yes	NA	1300
CH-07-FD	FD	Room 106	Yes	<35	1300
CH-07-FL	FL	Room 106	Yes	NA	1300
CH-08-FD	FD	Room 111	Yes	<35	1300
CH-08-FL	FL	Room 111	Yes	NA	1300
CH-09-FD	FD	Hallway Fountain	Yes	<35	1300
CH-09-FL	FL	Hallway Fountain	Yes	NA	1300
CH-10-FD	FD	Room 107	Yes	120	1300
CH-10-FL	FL	Room 107	Yes	NA	1300
CH-11-FD	FD	Room 110	Yes	<35	1300
CH-11-FL	FL	Room 110	Yes	NA	1300
CH-12-FD	FD	Room 109	Yes	<35	1300
CH-12-FL	FL	Room 109	Yes	NA	1300
CH-13-FD	FD	Room 108	Yes	<35	1300
CH-13-FL	FL	Room 108	Yes	NA	1300



CH-14-FD	FD	Room 123	Yes	<35	1300
CH-14-FL	FL	Room 123	Yes	NA	1300
CH-15-FD	FD	Room 121	Yes	<35	1300
CH-15-FL	FL	Room 121	Yes	NA	1300

MCL – Maximum Contaminant Level; NA – Not Analyzed; FD – First Draw; FL – Flush

Laboratory analysis results of the lead and copper sampling indicate the concentrations were below the established regulatory limits at each test location. Flush samples were not analyzed because there were no exceedances reported in the first draw results. Certificates of laboratory analysis are attached to this report.

LIMITATIONS

Results should not be considered to reflect conditions at other tap locations in the facility. The findings in this report are reflective of the conditions at the time of the VHB inspections. The findings and recommendations are valid as of the date of the report. The conclusions are limited based on the site conditions at the time of our inspection and the enclosed analytical results. Please do not hesitate to contact the undersigned at 732-223-2225 if you have questions and/or comments or require additional information.

Sincerely,

A handwritten signature in blue ink that reads "Tom Halter".

Tom Halter
Project Manager
TH:CG

A handwritten signature in blue ink that reads "Chris Glowacki".

Christopher Glowacki, CIH, CIEC
Team Lead – Industrial Hygiene

Attachments (2) – Laboratory Certificate of Analysis and Chain of Custody
– Sample Location Drawing



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012611275

LIMS Reference ID: AE11275

EMSL Customer ID: BRIN50

Attention: TOM HALTER
VHB, Inc. [BRIN50]
1805 Atlantic Avenue
Manasquan, NJ 08736
(732) 223-2225
thalter@brinkenv.com

Project Name: 21866.013 - Cherry Hill
Project ID: _Master Project-BRIN50
Customer PO:
Sales Rep: Christopher Brandt
Received: 02/27/2026 14:05
Reported: 03/13/2026 15:21

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: CH-01-FD Lims Reference ID: AE11275-01 Matrix: Drinking Water Sampled: 02/21/26 09:00:00

Metals

Copper	ND		1	35	µg/L	03/11/26 11:22	03/11/26 17:50	JW1	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	03/11/26 11:22	03/11/26 17:50	JW1	EPA 200.8 (DA)/EPA 200.8

Sample: CH-02-FD Lims Reference ID: AE11275-03 Matrix: Drinking Water Sampled: 02/21/26 09:07:00

Metals

Copper	ND		1	35	µg/L	03/11/26 11:22	03/11/26 17:57	JW1	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	03/11/26 11:22	03/11/26 17:57	JW1	EPA 200.8 (DA)/EPA 200.8

Sample: CH-03-FD Lims Reference ID: AE11275-05 Matrix: Drinking Water Sampled: 02/21/26 09:15:00

Metals

Copper	ND		1	35	µg/L	03/11/26 11:22	03/11/26 17:59	JW1	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	03/11/26 11:22	03/11/26 17:59	JW1	EPA 200.8 (DA)/EPA 200.8

Sample: CH-04-FD Lims Reference ID: AE11275-07 Matrix: Drinking Water Sampled: 02/21/26 09:19:00

Metals

Copper	ND		1	35	µg/L	03/11/26 11:22	03/11/26 18:02	JW1	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	03/11/26 11:22	03/11/26 18:02	JW1	EPA 200.8 (DA)/EPA 200.8

Sample: CH-05-FD Lims Reference ID: AE11275-09 Matrix: Drinking Water Sampled: 02/21/26 09:29:00

Metals

Copper	ND		1	35	µg/L	03/11/26 11:22	03/11/26 18:04	JW1	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	03/11/26 11:22	03/11/26 18:04	JW1	EPA 200.8 (DA)/EPA 200.8

Sample: CH-06-FD Lims Reference ID: AE11275-11 Matrix: Drinking Water Sampled: 02/21/26 09:36:00

Metals

Copper	ND		1	35	µg/L	03/11/26 11:22	03/11/26 18:11	JW1	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	03/11/26 11:22	03/11/26 18:11	JW1	EPA 200.8 (DA)/EPA 200.8

Sample: CH-07-FD Lims Reference ID: AE11275-13 Matrix: Drinking Water Sampled: 02/21/26 09:40:00

Metals

Copper	ND		1	35	µg/L	03/11/26 11:22	03/11/26 18:13	JW1	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	03/11/26 11:22	03/11/26 18:13	JW1	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012611275

LIMS Reference ID: AE11275

EMSL Customer ID: BRIN50

Attention: TOM HALTER
VHB, Inc. [BRIN50]
1805 Atlantic Avenue
Manasquan, NJ 08736
(732) 223-2225
thalter@brinkenv.com

Project Name: 21866.013 - Cherry Hill
Project ID: _Master Project-BRIN50
Customer PO:
Sales Rep: Christopher Brandt
Received: 02/27/2026 14:05
Reported: 03/13/2026 15:21

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: CH-08-FD Lims Reference ID: AE11275-15 Matrix: Drinking Water Sampled: 02/21/26 09:46:00

Metals

Copper	ND		1	35	µg/L	03/11/26 11:22	03/11/26 18:16	JW1	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	03/11/26 11:22	03/11/26 18:16	JW1	EPA 200.8 (DA)/EPA 200.8

Sample: CH-09-FD Lims Reference ID: AE11275-17 Matrix: Drinking Water Sampled: 02/21/26 09:55:00

Metals

Copper	ND		1	35	µg/L	03/11/26 11:22	03/11/26 18:18	JW1	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	03/11/26 11:22	03/11/26 18:18	JW1	EPA 200.8 (DA)/EPA 200.8

Sample: CH-10-FD Lims Reference ID: AE11275-19 Matrix: Drinking Water Sampled: 02/21/26 10:05:00

Metals

Copper	120		1	35	µg/L	03/11/26 11:22	03/11/26 18:20	JW1	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	03/11/26 11:22	03/11/26 18:20	JW1	EPA 200.8 (DA)/EPA 200.8

Sample: CH-11-FD Lims Reference ID: AE11275-21 Matrix: Drinking Water Sampled: 02/21/26 10:10:00

Metals

Copper	ND		1	35	µg/L	03/11/26 11:22	03/11/26 18:22	JW1	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	03/11/26 11:22	03/11/26 18:22	JW1	EPA 200.8 (DA)/EPA 200.8

Sample: CH-12-FD Lims Reference ID: AE11275-23 Matrix: Drinking Water Sampled: 02/21/26 10:16:00

Metals

Copper	ND		1	35	µg/L	03/11/26 11:22	03/11/26 18:29	JW1	EPA 200.8 (DA)/EPA 200.8
Lead	2.10		1	1.00	µg/L	03/11/26 11:22	03/11/26 18:29	JW1	EPA 200.8 (DA)/EPA 200.8

Sample: CH-13-FD Lims Reference ID: AE11275-25 Matrix: Drinking Water Sampled: 02/21/26 10:24:00

Metals

Copper	ND		1	35	µg/L	03/11/26 11:22	03/11/26 18:32	JW1	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	03/11/26 11:22	03/11/26 18:32	JW1	EPA 200.8 (DA)/EPA 200.8

Sample: CH-14-FD Lims Reference ID: AE11275-27 Matrix: Drinking Water Sampled: 02/21/26 10:30:00

Metals

Copper	ND		1	35	µg/L	03/11/26 11:22	03/11/26 18:39	JW1	EPA 200.8 (DA)/EPA 200.8
Lead	ND		1	1.00	µg/L	03/11/26 11:22	03/11/26 18:39	JW1	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012611275

LIMS Reference ID: AE11275

EMSL Customer ID: BRIN50

Attention: TOM HALTER
VHB, Inc. [BRIN50]
1805 Atlantic Avenue
Manasquan, NJ 08736
(732) 223-2225
thalter@brinkenv.com

Project Name: 21866.013 - Cherry Hill

Project ID: _Master Project-BRIN50
Customer PO:
Sales Rep: Christopher Brandt
Received: 02/27/2026 14:05
Reported: 03/13/2026 15:21

Work Order Case Narrative

Emailed client 3/3 SB Samples not recorded COC ; Cancel flush samples



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012611275

LIMS Reference ID: AE11275

EMSL Customer ID: BRIN50

Attention: TOM HALTER
VHB, Inc. [BRIN50]
1805 Atlantic Avenue
Manasquan, NJ 08736
(732) 223-2225
thalter@brinkenv.com

Project Name: 21866.013 - Cherry Hill

Project ID: _Master Project-BRIN50
Customer PO:
Sales Rep: Christopher Brandt
Received: 02/27/2026 14:05
Reported: 03/13/2026 15:21

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Copper	NJDEP
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2026
NYSDOH	New York State Department of Health ELAP	10872	04/01/2026
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2026
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2026
CTDPH	Connecticut Department of Public Health	PH-0270	06/30/2026
California ELAP	California Water Boards	1877	06/30/2026
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	04/01/2027
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026
21-A2LA	A2LA Food Chem/Mat Sci	2845.15	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012611275

LIMS Reference ID: AE11275

EMSL Customer ID: BRIN50

Attention: TOM HALTER
VHB, Inc. [BRIN50]
1805 Atlantic Avenue
Manasquan, NJ 08736
(732) 223-2225
thalter@brinkenv.com

Project Name: 21866.013 - Cherry Hill

Project ID: _Master Project-BRIN50
Customer PO:
Sales Rep: Christopher Brandt
Received: 02/27/2026 14:05
Reported: 03/13/2026 15:21

Notes and Definitions

Item	Definition
P2	Sample was preserved at the lab prior to analysis.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: EnvChemistry2@EMSL.com

AE11275

Customer Information	Customer ID:			Billing Information	Billing ID:		
	Company Name:	VHB			Company Name:		
	Contact Name:	Tom Heltzer			Billing Contact:		
	Street Address:	1805 Atlanta Ave			Street Address:		
	City, State, Zip:	Manassas VA 20108	Country:		City, State, Zip:		
	Phone:	703 575 5007			Phone:		
Email(s) for Report:	THACTERE@VHB.com		Email(s) for Invoice:				

Project Name/No:	21866.013- Cherry Hill		Purchase Order:		
EMSL LIMS Project ID: <small>(If applicable, EMSL will provide)</small>			US State where sample collected:	NT	
State of Connecticut (CT) must select project location: <input type="checkbox"/> Commercial (Taxable) <input type="checkbox"/> Residential (Non-Taxable)			PWS ID:		
Samples for Compliance?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	If Yes, for NPDES?	<input type="checkbox"/> Yes <input type="checkbox"/> No	State Reporting Required? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Samples Collected by (Check One):	<input type="checkbox"/> EMSL <input checked="" type="checkbox"/> CLIENT	Samples Received Chilled?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Sample(s) Temperature Upon Receipt (LAB ONLY) 1.7°C	
Sampled By Name:	T. Heltzer		Sampled By Signature:		
Sampler ID#:			(if applicable)		
No. Samples in Shipment:					

Turn-Around-Time (TAT) Standard Turn-Around-Time: 2 Weeks The following TAT's are subject to Lab approval. Call lab to confirm TAT before submittal: 1 Week 4 Days 3 Days 2 Days 1 Day

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix <small>DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other</small>	Preservative <small>1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other Describe below in Special Instructions</small>	List Test(s) Needed: <small>(Write in test below, then record # of bottles for each test in box)</small>								Comments
						Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:	
CH-01-FD			2/11/26 900	DW	2									Kitchen
CH-01-FL			900	↓	↓									↓
CH-02-FD			907	↓	↓									Ice Machine
CH-02-FL			↓	↓	↓									↓

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Reporting requirements: Results Only Results and QC Reduced Deliverables Hzresults EDD Excel Other

Method of Shipment:			Sample Condition Upon Receipt:	Received on Ice? <input type="checkbox"/>	
Relinquished by:		Date/Time:	Received by:		Date/Time: 2/26/26 2:45 PM
Relinquished by:		Date/Time:	Received by:		Date/Time: 2/27/26 0900

Controlled Document - COC-07 Chemistry R15 07/14/2025 AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

HNO3 @ 11:30 AM
3/3/26

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

AE11275

PHONE: (800) 220-3675

EMAIL: EnvChemistry2@EMSL.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other Describe below in Special Instructions	List Test(s) Needed: (Write in test below, then record # of bottles for each test in box)								Comments	
						Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
CH-03-FD	<input type="checkbox"/>	<input type="checkbox"/>	2/1/06 915	DW	2	X	X								Staff Room
CH-03-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-04-FD	<input type="checkbox"/>	<input type="checkbox"/>	919	↓	↓										113
CH-04-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓										↓
CH-05-FD	<input type="checkbox"/>	<input type="checkbox"/>	929	↓	↓										114
CH-05-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓										↓
CH-06-FD	<input type="checkbox"/>	<input type="checkbox"/>	936	↓	↓										115
CH-06-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓										↓
CH-07-FD	<input type="checkbox"/>	<input type="checkbox"/>	940	↓	↓										106

Method of Shipment:		Sample Condition Upon Receipt:		Received on Ice? <input type="checkbox"/>	
Relinquished by:		Date/Time:		Received by:	
Relinquished by:		Date/Time:		Date/Time: 2/27/2006 0900	

Controlled Document - COC-07 Chemistry R16 07/14/2025

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

AE11275

PHONE: (800) 220-3675
EMAIL: EnvChemistry2@EMSL.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other Describe below in Special Instructions	List Test(s) Needed: (Write in test below, then record # of bottles for each test in box)								Comments	
						Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
CH-07-FL	<input type="checkbox"/>	<input type="checkbox"/>	2/6/06 9:40	DW	2	Pb	Cu								106
CH-08-FD	<input type="checkbox"/>	<input type="checkbox"/>	9:46												111
CH-08-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓
CH-09-FD	<input type="checkbox"/>	<input type="checkbox"/>	9:55												Hall Fountain
CH-09-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓
CH-10-FD	<input type="checkbox"/>	<input type="checkbox"/>	10:05												107
CH-10-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓
CH-11-FD	<input type="checkbox"/>	<input type="checkbox"/>	10:10												110
CH-11-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓

Method of Shipment:		Sample Condition Upon Receipt:		Received on Ice? <input type="checkbox"/>	
Relinquished by: <i>[Signature]</i>		Date/Time:		Received by: <i>[Signature]</i>	
Date/Time:		Received by: <i>[Signature]</i>		Date/Time: <i>2/26/06 2:45 PM</i>	
Relinquished by:		Date/Time:		Received by: <i>[Signature]</i>	
Date/Time:		Received by: <i>[Signature]</i>		Date/Time: <i>2/27/06 09:00</i>	

Controlled Document - COC-07 Chemistry R16 07/14/2025

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

AE11275

PHONE: (800) 220-3675
EMAIL: EnvChemistry2@EMSL.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other Describe below in Special Instructions	List Test(s) Needed: (Write in test below, then record # of bottles for each test in box)								Comments	
						Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
CH-12-FD	<input type="checkbox"/>	<input type="checkbox"/>	2/6/26 1016	DW	2	X	X								109
CH-12-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-13-FD	<input type="checkbox"/>	<input type="checkbox"/>	1024	↓	↓	↓	↓								108
CH-13-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-14-FD	<input type="checkbox"/>	<input type="checkbox"/>	1030	↓	↓	↓	↓								103
CH-14-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-15-FD	<input type="checkbox"/>	<input type="checkbox"/>	1039	↓	↓	↓	↓								101
CH-15-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
	<input type="checkbox"/>	<input type="checkbox"/>	↓												

Method of Shipment:		Sample Condition Upon Receipt:		Received on Ice? <input type="checkbox"/>	
Relinquished by: <i>[Signature]</i>		Date/Time:		Received by: <i>[Signature]</i>	
Relinquished by:		Date/Time:		Date/Time: 2/26/26 2:45 PM	
Relinquished by:		Date/Time:		Received by: <i>[Signature]</i>	
Relinquished by:		Date/Time:		Date/Time: 2/27/26 0900	

Controlled Document - COC-07 Chemistry R16 07/14/2025

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

AE11275

PHONE: (800) 220-3675
EMAIL: EnvChemistry2@EMSL.com

Customer Information	Customer ID:	Billing ID:		
	Company Name: VHB	Company Name:		
	Contact Name: Tom Halter	Billing Contact:		
	Street Address: 1805 Atlantic Ave	Street Address:		
	City, State, Zip: Manasquan NJ 08736	Country:	City, State, Zip:	
	Phone: 201 575 5007	Country:		
Email(s) for Report: THACT@VHB.com	Email(s) for Invoice:			

Project Name/No: 21866.013- Cherry Hill

EMSL LIMS Project ID: (If applicable, EMSL will provide)

US State where sample collected: NJ

State of Connecticut (CT) must select project location:
 Commercial (Taxable) Residential (Non-Taxable)

Samples for Compliance? Yes No If Yes, for NPDES? Yes No

PWS ID: State Reporting Required? Yes No

Samples Collected by (Check One): EMSL CLIENT

Sample(s) Temperature Upon Receipt (LAB ONLY): 1.7°C

Sampled By Name: T. Halter

Sampled By Signature: [Signature]

Sampler ID#: (if applicable)

No. Samples in Shipment:

Turn-Around-Time (TAT) Standard Turn-Around-Time: 2 Weeks

The following TAT's are subject to Lab approval. Call lab to confirm TAT before submittal:

1 Week 4 Days 3 Days 2 Days 1 Day

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other Describe below in Special Instructions	List Test(s) Needed: (Write in test below, then record # of bottles for each test in box)								Comments	
						Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
CH-01-FD			2/1/26 900	DW	2	X	X								Kitchen
CH-01-FL			900												↓
CH-02-FD			907												Ice Machine
CH-02-FL															↓

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Reporting requirements: Results Only Results and QC Reduced Deliverables Hzresults EDD Excel Other

Method of Shipment:

Sample Condition Upon Receipt: Received on Ice? Check if Yes

Relinquished by: [Signature] Date/Time:

Received by: [Signature] Date/Time: 2/26/26 2:45 PM

Relinquished by: [Signature] Date/Time:

Received by: [Signature] Date/Time: 2/27/26 0900

Controlled Document - COC-07 Chemistry R15 07/14/2025

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

HNO3 @ 11:30 AM
3/3/26

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

AE11275

PHONE: (800) 220-3675
EMAIL: EnvChemistry2@EMSL.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other Describe below in Special Instructions	List Test(s) Needed: (Write in test below, then record # of bottles for each test in box)								Comments	
						Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
CH-03-FD	<input type="checkbox"/>	<input type="checkbox"/>	2/1/06 915	DW	2	X	X								Staff Room
CH-03-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-04-FD	<input type="checkbox"/>	<input type="checkbox"/>	919	↓	↓	↓	↓								113
CH-04-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-05-FD	<input type="checkbox"/>	<input type="checkbox"/>	929	↓	↓	↓	↓								114
CH-05-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-06-FD	<input type="checkbox"/>	<input type="checkbox"/>	936	↓	↓	↓	↓								115
CH-06-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-07-FD	<input type="checkbox"/>	<input type="checkbox"/>	940	↓	↓	↓	↓								106

Method of Shipment:		Sample Condition Upon Receipt:		Received on Ice? <input type="checkbox"/>	
Relinquished by:	Date/Time:	Received by:	Date/Time: 2-26-06 2:45 PM		
Relinquished by:	Date/Time:	Received by:	Date/Time: 2/27/26 0900		

Controlled Document - COC-07 Chemistry R16 07/14/2025

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

AE11275

PHONE: (800) 220-3675
EMAIL: EnvChemistry2@EMSL.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix <small>DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other</small>	Preservative <small>1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other Describe below in Special Instructions</small>	List Test(s) Needed: <small>(Write in test below, then record # of bottles for each test in box)</small>								Comments	
						Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
CH-07-FL	<input type="checkbox"/>	<input type="checkbox"/>	2/10/09 940	DW	2	Pb	Cu								106
CH-08-FD	<input type="checkbox"/>	<input type="checkbox"/>	946												111
CH-08-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓
CH-09-FD	<input type="checkbox"/>	<input type="checkbox"/>	955												Hall Fountain
CH-09-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓
CH-10-FD	<input type="checkbox"/>	<input type="checkbox"/>	1005												107
CH-10-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓
CH-11-FD	<input type="checkbox"/>	<input type="checkbox"/>	1010												110
CH-11-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓

Method of Shipment:		Sample Condition Upon Receipt:		Received on Ice? <input type="checkbox"/>	
Relinquished by: <i>[Signature]</i>		Date/Time:		Received by: <i>[Signature]</i>	
Relinquished by:		Date/Time:		Date/Time: <i>2/26/09 2:45 PM</i>	
		Date/Time:		Date/Time: <i>2/27/09 0900</i>	

Controlled Document - COC-07 Chemistry R16 07/14/2025

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE: (800) 220-3675
EMAIL: EnvChemistry2@EMSL.com

AE11275

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other Describe below in Special Instructions	List Test(s) Needed: (Write in test below, then record # of bottles for each test in box)								Comments	
						Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
CH-12-FD	<input type="checkbox"/>	<input type="checkbox"/>	2/6/26 10:06	DW	2	X	X								109
CH-12-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓
CH-13-FD	<input type="checkbox"/>	<input type="checkbox"/>	1024												108
CH-13-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓
CH-14-FD	<input type="checkbox"/>	<input type="checkbox"/>	1030												103
CH-14-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓
CH-15-FD	<input type="checkbox"/>	<input type="checkbox"/>	1039												101
CH-15-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓
CH-16-FD	<input type="checkbox"/>	<input type="checkbox"/>	↓												

Method of Shipment: CH-16-FL

Sample Condition Upon Receipt: _____

Received on Ice? Check if Yes

Relinquished by: [Signature] Date/Time: _____

Received by: [Signature] Date/Time: 2/26/26 2:45 PM

Relinquished by: _____ Date/Time: _____

Received by: [Signature] Date/Time: 2/27/26 0900

Controlled Document - COC-07 Chemistry R16 07/14/2025

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: EnvChemistry2@EMSL.com

AE11275

Customer Information	Customer ID:			Billing Information	Billing ID:		
	Company Name:	VHB			Company Name:		
	Contact Name:	Tom Halter			Billing Contact:		
	Street Address:	1805 Atlanta Ave			Street Address:		
	City, State, Zip:	Manasquan NJ 08736	Country:		City, State, Zip:		Country:
	Phone:	Jol 575 5007			Phone:		
Email(s) for Report: THACT@VHB.com				Email(s) for Invoice:			

Project Name/No:	21866.013- Cherry Hill		Purchase Order:	
EMSL LIMS Project ID: (If applicable, EMSL will provide)		US State where sample collected:	NJ	
Samples for Compliance? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		If Yes, for NPDES? <input type="checkbox"/> Yes <input type="checkbox"/> No		State of Connecticut (CT) must select project location: <input type="checkbox"/> Commercial (Taxable) <input type="checkbox"/> Residential (Non-Taxable)
Samples Collected by (Check One): <input type="checkbox"/> EMSL <input checked="" type="checkbox"/> CLIENT		Samples Received Chilled? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		PWS ID:
Sampled By Name: T. Halter		Sampled By Signature:		State Reporting Required? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
				Sample(s) Temperature Upon Receipt (LAB ONLY)
				1.7°C
Sampler ID#: (if applicable)		No. Samples in Shipment:		

Turn-Around-Time (TAT) Standard Turn-Around-Time: 2 Weeks 1 Week 4 Days 3 Days 2 Days 1 Day

The following TAT's are subject to Lab approval. Call lab to confirm TAT before submittal.

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other Describe below in Special Instructions	List Test(s) Needed: (Write in test below, then record # of bottles for each test in box)								Comments	
						Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
CH-01-FD			2/1/26 900	DW	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>								Kitchen
CH-01-FL			900	↓	↓	↓	↓								↓
CH-02-FD			907	↓	↓	↓	↓								Ice Machine
CH-02-FL				↓	↓	↓	↓								↓

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Reporting requirements: Results Only Results and QC Reduced Deliverables HZresults EDD Excel Other

Method of Shipment:	Sample Condition Upon Receipt:	Received on Ice? <input type="checkbox"/>
Relinquished by:	Date/Time:	Received by:
Relinquished by:	Date/Time:	Received by:
		Date/Time: 2/26/26 2:45 PM
		Date/Time: 2/27/26 0900

Controlled Document - COC-07 Chemistry R15 07/14/2025

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

HNO3 @ 11:30 AM
3/3/26



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: EnvChemistry2@EMSL.com

AE11275

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other Describe below in Special Instructions	List Test(s) Needed: (Write in test below, then record # of bottles for each test in box)								Comments	
						Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
CH-03-FD	<input type="checkbox"/>	<input type="checkbox"/>	2/1/06 915	DW	2	X	X								Staff Room
CH-03-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-04-FD	<input type="checkbox"/>	<input type="checkbox"/>	919	↓	↓	↓	↓								113
CH-04-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-05-FD	<input type="checkbox"/>	<input type="checkbox"/>	929	↓	↓	↓	↓								114
CH-05-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-06-FD	<input type="checkbox"/>	<input type="checkbox"/>	936	↓	↓	↓	↓								115
CH-06-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-07-FD	<input type="checkbox"/>	<input type="checkbox"/>	940	↓	↓	↓	↓								106

Method of Shipment:		Sample Condition Upon Receipt:		Received on Ice? <input type="checkbox"/>	
Relinquished by: <i>[Signature]</i>		Date/Time:		Received by: <i>[Signature]</i>	
Relinquished by:		Date/Time:		Date/Time: <i>2/27/26 0900</i>	

Controlled Document - COC-07 Chemistry R16 07/14/2025

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

AE11275

PHONE: (800) 220-3675
EMAIL: EnvChemistry2@EMSL.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other Describe below in Special Instructions	List Test(s) Needed: (Write in test below, then record # of bottles for each test in box)								Comments	
						Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
CH-07-FL	<input type="checkbox"/>	<input type="checkbox"/>	2/1/06 9:40	DW	2	Pb	Cu								106
CH-08-FD	<input type="checkbox"/>	<input type="checkbox"/>	9:46												111
CH-08-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓
CH-09-FD	<input type="checkbox"/>	<input type="checkbox"/>	9:55												Hall Fountain
CH-09-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓
CH-10-FD	<input type="checkbox"/>	<input type="checkbox"/>	10:05												107
CH-10-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓
CH-11-FD	<input type="checkbox"/>	<input type="checkbox"/>	10:10												110
CH-11-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓												↓

Method of Shipment:		Sample Condition Upon Receipt:		Received on Ice? <input type="checkbox"/>	
Relinquished by: <i>[Signature]</i>		Date/Time:		Received by: <i>[Signature]</i>	
Relinquished by:		Date/Time:		Date/Time: 2/26/06 2:45 PM	
				Date/Time: 2/27/06 09:00	

Controlled Document - COC-07 Chemistry R16 07/14/2025

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.

Environmental Chemistry Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Rt. 130 N
Cinnaminson, NJ 08077

PHONE: (800) 220-3675
EMAIL: EnvChemistry2@EMSL.com

AE11275

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Client Sample ID	Comp	Grab	Date / Time Collected	Matrix DW=Drinking Water WW=Wastewater S=Soil A=Air SL=Sludge O=Other	Preservative 1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other Describe below in Special Instructions	List Test(s) Needed: (Write in test below, then record # of bottles for each test in box)								Comments	
						Test 1:	Test 2:	Test 3:	Test 4:	Test 5:	Test 6:	Test 7:	Test 8:		
CH-12-FD	<input type="checkbox"/>	<input type="checkbox"/>	2/6/10 10:06	DW	2	Pb	Cu								109
CH-12-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-13-FD	<input type="checkbox"/>	<input type="checkbox"/>	1024	↓	↓	↓	↓								108
CH-13-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-14-FD	<input type="checkbox"/>	<input type="checkbox"/>	1030	↓	↓	↓	↓								103
CH-14-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-15-FD	<input type="checkbox"/>	<input type="checkbox"/>	1039	↓	↓	↓	↓								101
CH-15-FL	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								↓
CH-16-FD	<input type="checkbox"/>	<input type="checkbox"/>	↓	↓	↓	↓	↓								

Method of Shipment: CH-16-FL

Relinquished by: [Signature] Date/Time: _____

Relinquished by: _____ Date/Time: _____

Sample Condition Upon Receipt: _____

Received on Ice? Check if Yes

Received by: [Signature] Date/Time: 2/26/2010 4:50 PM

Received by: [Signature] Date/Time: 2/27/2010 0900

Controlled Document - COC-07 Chemistry R16 07/14/2025

AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

