

WEEKLY RESUME

6/25/79 to 6/29/79

✓ Cards
✓ Board

6/27/79 Mc Laughlin/Tomaro SPECIAL
VALENTINE BROOK Called
ALLENDALE

Report received of fish kill in Valentine Brook- 6 dead fish observed-sample taken-non-poll

6/27/79 Cordasco/Parr SPECIAL
SECOND RIVER Called
BLOOMFIELD

Liquid soap spill on highway-Fire Dept. flushed down with water into catch basin, thence 2nd Rive

6/28/79 Cordasco/Parr SPECIAL
THIRD RIVER Called
NUTLEY

Report received of green color in brook, investigation made, found brook running clear, green cast visible from vegetation

6/28/79 Cordasco/Parr
CITY OF NEWARK
MEADOWBROOK STORM SEWER ✓

No new action taken to abate this pollution violation of long standing.

6/28/79 McLaughlin/Tomaro SPECIAL
PASSAIC RIVER ✓
BOAT TRIP

Inspectors conducted tour of Passaic River by boat- several irregularities noted-to be followed up by inspectors in district.

6/29/79 Fiore/Colello
BARON MOTOR CARRIERS INC. Called
145 BLANCHARD ST.
NEWARK

Violation-Elimination
Spill-55gallon drum blue vegetabl dye. Washed down-into catch basin thence Passaic River

6/29/79 Fleming/Perrapato
CITY OF CLIFTON ✓
ATHENIA STORM SEWER

No new action taken to abate this pollution violation of long standing.

6/29/79 Fleming/Perrapato
CITY OF CLIFTON ✓
8" sanitary line, 3rd River
at Automatic Data Processing

Last sample taken non-polluting in spite of fact that repairs have not been made.

6/29/79 Fleming/Perrapato
CITY OF CLIFTON ✓
manhole 3rd River at rear
Atlantic Chem Co.

Slight seepage from base of man-hole-Repairs to be made within a week or two

6/29/79 Cordasco/Parr
DURITE CIRCUITS INC.
141 RIVER RD.
NUTLEY

Follow
up

Will make connection to sanita-
line

6/29/79 Sventy/De Marco
CITY OF GARFIELD
SCHROEDERS BROOK ✓

6/29/79 McLaughlin/Tomaro
BORO OF HAWTHORNE
LINCOLN ST DITCH ✓

6/29/79 Sventy/De Marco
BORO OF LODI
MILLBANK BROOK ✓

6/29/79 Sventy-DeMarco SPECIAL
BORO OF LODI
30" Main line loc
Main Ave., Wallington ✓

6/29/79 Sventy/De Marco
LODI BROOK
LODI ✓

6/29/79 Sventy-DeMarco
TOWN OF LYNDHURST
LAKE AVE STORM SEWER ✓

6/29/79 Sventy/De Marco
TOWN OF LYNDHURST
NEW YORK AVE STORM SEWER ✓

6/29/79 Fiore/Colello
MOSCATELLO BROS. INC.
65 Pennsylvania Ave.
KEARNY

called

6/29/79 Fiore/Colello
NATIONAL FUEL OIL
PASSAIC AVE.
EAST NEWARK

called

6/29/79 Cordasco/Parr
TOWN OF ORANGE
WASHINGTON ST STORM ✓

6/29/79 Fleming/Perrapato
CITY OF PASSAIC
MADISON ST STORM SEWER ✓

6/29/79 SVENTY DE MARCO
BORO OF WALLINGTON
48" MAIN AVE STORM SEWER ✓

Source of pollution to brook
(high fecal coliform) under
investigation.

Origin of pollution remains
unknown

Violation of long standing- sour
as yet undetermined.

Temporary repairs seem to have
been effective- permanent repair
will be made sometime in future.

Inspectors met with representati
of NJDEP- made inspection of bro
His opinion Stepan Chem. free of
any violation-Fecal in brook, Bor
of Lodi's problem

Violation of long standing-sour
of pollution as yet undetermine

Contributor to pollution in
Lake Ave Storm line-source unde
investigation

Violation & Elimination
Oil flushed out of tanker truck
so repairs could be made. Oil
mixed with water entered catch
basin, thence Passaic River

Citizen called to report oil
slick in Passaic River-traced
to this company-exact source
as yet undetermined

New 24" sanitary line being
installed. No pollution enterin
Wigwam Brook.

No new effort has been made to
determine the source of pollut:
to this storm line-Sobota DPW
will make effort as soon as
intermittent high fecal co
more urgent problems are so
Source under investigation

WEEKLY RESUME

10/29/79 to 11/2/79

11/2 Cordasco/Parr
TOWN OF BELLEVILLE
Chestnut St. outlet

Samples taken of outlet analyzed
as polluting.

11/2 Sventy/Cuccinello
~~CBS~~ TOYS
Paul Kohner Drive
Elmwood Park

Monthly

Oily material continues to seep
under and around filter fence -
despite efforts to contain.

11/2 Fleming/Perrapato
CITY OF CLIFTON
Athenia Storm

Sample polluting - nothing new being
done to correct pollution.

11/2 Fleming/Perrapato
CITY OF CLIFTON
8" Sanitary Line, Crossing
3rd River at A.D.P.

Sample taken polluting - seepage
continues at this point.

11/2 Sventy/Cuccinello
COOK MACHINERY
380 Pleasantview Ave.
Hackensack

INSP

Violation-Elimination - runoff from
steam cleaning of machinery reached
catch basin thence Millbank Brook.

11/2 Sventy/Cuccinello
CURTISS WRIGHT
Passaic St.
Wood Ridge

Monthly

Several inspections of Folds Brook
reveals no visible oil - source as
yet undetermined.

11/2 Fleming/Perrapato
DUNKIN DONUTS
Union Ave. and Main Ave.
Clifton

INSP.

Special - city completed new tie in
of sanitary line.

11/2 Sventy/Cuccinello
IMPERIAL ELECTRO PLATING
52 Park Ave.
Lyndhurst

Monthly

To date no corrective action has
been taken at this company.

11/2 Fiore/Colello
TOWN OF KEARNY
Pennsylvania Ave.

✓

Pollution still present at this
location.

11/2 Sventy/Cuccinello
BORO OF LODI
Millbank Brook Before &
After Gibraltar Chem. & Plastics

✓

Samples taken were analyzed as
polluting.

BORO OF LODI
12" Sventy/Cuccinello
12" overflow into Saddle
River at Hendricks St. Pump
Station

Monthly

Numerous efforts were made, requesting
boro to take action in eliminating
this pollution - but to no avail.

11/2 Sventy/Cuccinello
TOWN OF LYNDHURST
Lake Ave. Storm ✓

Sample analyzed as polluting, fecal coliform.

11/2 Sventy/Cuccinello
TOWN OF LYNDHURST
New York Ave. storm at
Livingston ✓

Same as above.

11/2 Cuccinello/Sventy
MARATHON TRUCK LEASING
42 Arnot St.
Lodi *INSP.*

Special - encroachment observed at this location.

11/2 Mc Laughlin/Tomaro
MATLACK INC.
Rt. 322
Swedesboro, N.J. *INSP.*

Violation-Elimination - spillage occurred as the result of a broken hose, at E 24th St., Paterson.

11/2 Sventy/Cuccinello
MILLBANK BROOK
Storm Ditch from
Hasbrouck Heights *INSP.*

Black discoloration in storm ditch thence Millbank Brook - source of pollution still under investigation.

11/2 Fiore/Colello
NATIONAL FUEL OIL
Passaic Ave.
E. Newark *Monthly*

Oil sheen still observed on Passaic River.

11/2 Fiore/Colello
CITY OF NEWARK
Blanchard, Lockwood &
Roanoke Storm Sewers ✓

Status quo

11/2 Cordasco/Parr
CITY OF NEWARK
Meadowbrook Storm ✓

Status quo

11/2 Cordasco/Parr
CITY OF ORANGE
Washington St. ✓

Believe 2 taverns in area are illegally hooked up into this line - city to make investigation.

11/2 Fleming/Perrapato
CITY OF PASSAIC
Madison St. Storm ✓

Samples taken analyzed as polluting

11/3 Sventy
Fleischers Brook
Elmwood Park *called*

Special - received complaint of black in brook - appeared to be vegetation.

WEEKLY RESUME

9/17/79 to 9/21/79

✓ Cards
✓ Board

- | | |
|---|---|
| <p>✓ 9/17/79 Cordasco/Parr
BLANCHARD ST. STORM
Outlet
Newark</p> <p><u>INSP.</u></p> | <p>Special-
Illegal dumping of oil evident at
storm sewer manhole cover and
surrounding area.</p> |
| <p>✓ 9/17/79 Cupo/Sventy/Perrapato
PANTASOTE
26 Jefferson St.
Passaic</p> <p><u>INSP.</u></p> | <p>White resin spill into Weasel Brook -
Olsen and Hassold Inc. obtained to
clean up brook.</p> |
| <p>✓ 9/17/79 Cupo/Perrapato
CITY OF PASSAIC
Mc Donald Brook
entrance to Hughes Lake</p> <p>✓</p> | <p>Violation-Elimination - Polluting sample
was due to construction in Clifton of
sanitary lines</p> |
| <p>✓ 9/17/79 Fiore/Colello
POLK ST. STORM SEWER
Newark</p> <p><u>INSP.</u></p> | <p>Special - Due to emergency repairs -
sanitary overflow outlet let out -
repairs made 9/13</p> |
| <p>✓ 9/18/79 Fiore/Colello
BLANCHARD ST.
Newark</p> <p><u>INSP.</u></p> | <p>Special - Observed oil overflowing from
2 manholes - city says monies were
appropriated to clean and repair lines.</p> |
| <p>✓ 9/18/79 Mc Laughlin/Tomaro
FABRICOLOR
1 Van Houton St.
Paterson</p> <p><u>INSP.</u></p> | <p>Violation-Elimination - Cracked sanitary
line responsible for reddish-brown
liquid entering Passaic River</p> |
| <p>✓ 9/18/79 Tomaro/Mc Laughlin
HAWTHORNE PRINT CO.
179 Goffle Road
Hawthorne</p> <p><u>INSP.</u></p> | <p>Violation-Elimination - Water soluble
blue color from slop sink entered
sanitary line thence Goffle Brook</p> |
| <p>✓ 9/20/79 Cuccinello/Sventy
GREGORY ARMS APTS.
6-12 Hillside Ave.
Nutley</p> <p>✓</p> | <p>Special - a meeting was held at Nutley
Town Hall in regard to oil spill at this
location</p> |
| <p>✓ 9/20/79 Mc Laughlin/Tomaro
MOLLY ANNS BROOK
Haledon Ave.
Haledon</p> <p><u>Called</u></p> | <p>Special - Checked out complaint of
sewer overflow - investigation found no
overflow or evidence of one</p> |
| <p>✓ 9/21/79 Cordasco/Parr
TOWN OF BELLEVILLE
Chestnut St. outlet</p> <p>✓</p> | <p>Samples taken - analyzed as non polluting</p> |
| <p>✓ 9/21/79 Fleming/Perrapato
CITY OF CLIFTON
Athenia Storm Sewer</p> <p>✓</p> | <p>Pollution continues at this location</p> |
| <p>✓ 9/21/79 Fleming/Perrapato
CITY OF CLIFTON
8" Line Crossing</p> <p>✓</p> | <p>Leak discovered at this location -
repairs expected to be made week of
9/24</p> |

9/21/79 Cuccinello/Fiore/
Fleming/Perrapato
CITY OF CLIFTON
24" outlet to Passaic River
Rte. 21 Near Moon Carrier ✓

Special - Recent sample was found to be non polluting

9/21/79 Sventy/Cuccinello
BORO OF ELMWOOD PARK
D.P.W. Yard ?

Special - a fire occurred at this location of leaves, branches etc. - fire hosed down - runoff did not reach Passaic River

9/21/79 Sventy/Cupo
TOWN OF GARFIELD
Schroeders Brook ✓

High fecal coliform present in brook

9/21/79 Cupo/Cuccinello/
Cordasco/Parr & Sventy
GREGORY ARMS APARTMENTS
6-12 Hillside Avenue
Nutley

Oil spill occurred at this location - In the process of being cleaned

came in over air

Imp. found source

9/21/79 Sventy/Cupo
BORO OF LODI
Millbank Brook After
Gibraltar Chem. & Plastics ✓

Sample after analyzed as polluting, high fecal coliform

9/21/79 Sventy/Cuccinello
TOWN OF LYNDHURST
New York Ave. & Livingston ✓

Fecal coliform present in storm sewer which runs into Lake Ave. thence Passaic River

9/21/79 Fiore/Colello
MONSANTO CO.
Pennsylvania Ave.
Kearny ✓

Polluting material into sanitary sewer to be corrected

9/21/79 Fiore/Colello
NATIONAL FUEL OIL CO.
Passaic Ave.
East Newark ✓

Oil continues to leack from tanks - in spite of preventive measures

9/21/79 Cordasco/Parr
CITY OF NEWARK
Meadowbrook Storm ✓

Pollution continues at this location

9/21/79 Cordasco/Parr
CITY OF ORANGE
Washington St. Storm ✓

No pollution occurring at this location

9/21/79 Fleming/Perrapato
CITY OF PASSAIC
Madison St. Storm ✓

Samples taken show high fecal coliform

✓ cards
✓ board

WEEKLY RESUME

10/9/79 to 10/12/79

10/12/79 Cordasco/Parr TOWN OF BELLEVILLE Chestnut St. Storm ✓	Scheduled samples were not taken due to heavy rains.
10/12 Fleming/Perrapato CITY OF CLIFTON Athenia Storm Sewer ✓	Sample continues to show signs of pollution.
10/12 Fleming/Perrapato CITY OF CLIFTON 8" Sanitary Line Crossing 3rd River at A.D.P. ✓	City formulating plans to correct this problem.
10/12 Fleming/Perrapato CONTINENTAL CHEMICAL CO. 270 Clifton Blvd. Clifton ✓ <i>CWPD INSP.</i>	Suds in yard flowed over embankment into storm drain thence Weasel Brook - a permanent barrier is to be constructed to prevent problem.
10/12 Cordasco/Parr HARDMAN INCORP. 600 Cortlandt St. Belleville ✓	Violation-Elimination - floor drains have been sealed and street and property cleaned.
10/12 Tomaro/Mc Laughlin BORO OF HAWTHORNE Goffle Brook-Wagaraw Road ✓	Violation-Elimination - past few samples analyzed as non- polluting - previous pollution attributed to blocked sanitary sewer at Hawthorne Print Co.
10/12 Sventy/Cuccinello TOWN OF LYNDFURST New York Ave. Storm ✓	Fecal coliform still present in storm sewer
10/12 Cordasco/Parr TOWN OF MONTCLAIR 729 Valley Road Catch Basin ✓	Catch basin cleaned - sewage pipe in catch basin to be repaired sometime next week.
10/12 Fiore/Colello NATIONAL FUEL OIL CO. Passaic Avenue E. Newark ✓	Oil still visible in river inspite of efforts being made to contain oil and clean up.
10/12 Cordasco/Parr CITY OF NEWARK Meadowbrook Storm ✓	Pollution continues at this location
10/12 Cordasco/Parr CITY OF ORANGE Washington St. ✓	No pollution occurring at this time- construction should be completed by next week - weather, permitting.
10/12 Fleming/Perrapato PANTASOTE CO. 26 Jefferson St., Passaic ✓	New 8" steel pipe presently being installed -

✓ Weekly progress reports

✓ cards
✓ brand

WEEKLY RESUME

11/26/79 to 11/30/79

11/30 Cordasco/Parr
TOWN OF BELLEVILLE ✓
Chestnut St. outlet

No samples taken this week - will continue to investigate.

11/30 Sventy/Cuccinello
CBS TOYS
Paul Kohner Dr. *Monthly*
Elmwood Park

Oily material continues to seep through filter fence - company seeking solution to problem.

11/30 Fleming/Perrapato
CITY OF CLIFTON ✓
Athenia Storm

City to conduct survey with help of P.V.S.C. River Inspection Dept. in order to locate source of pollution problem.

11/30 Fleming/Perrapato
CITY OF CLIFTON ✓
8" Sanitary Line Crossing
3rd River at A.D.P.

Work to correct problem to begin on 12/3/79.

11/30 Sventy/Cuccinello
CURTISS WRIGHT
Passaic St. *Monthly*
Wood Ridge

Boom and pads maintained - source of oil undetermined - brook appears clear.

11/30 Tomaro/Mc Laughlin
BORO OF FAIR LAWN ✓
North Chamber

Special - due to heavy rains chamber opened - closed on following day.

11/30 Sventy/Cuccinello
CITY OF GARFIELD ✓
Schroeders Brook

Samples taken analyzed as non polluting

11/30 Sventy
IMPERIAL ELECTRO PLATING *Monthly*
52 Park Ave.
Lyndhurst

No corrective action has been taken - pollution still exists - recommend our legal dept. to intercede.

11/30 Sventy/Cuccinello
BORO OF LODI ✓
Millbank Brook at
Saddle River

Sanitary line to be checked for any leaks or breaks.

11/30 Sventy/Cuccinello
BORO OF LODI ✓
Millbank Br. before - after
Gibraltar Chemical and
Plastics

Dye tests conducted to locate source - inconclusive - sample taken analyzed as high fecal coliform.

11/30 Sventy/Cuccinello *Monthly*
BORO OF LODI
12" Overflow at Hendricks
St. Pump Station

Monies to correct problem are a problem at present time.

11/30 Sventy/Cuccinello TOWN OF LYNDHURST Lake Ave. storm ✓	Efforts have been made to locate source of pollution - but to no avail
11/30 Sventy/Cuccinello TOWN OF LYNDHURST New York Ave. storm ✓	Source of pollution under investigation - survey being made by E. T. Killam Co.
11/30 Fiore/Colello MONSANTO Pennsylvania Ave. Kearny ✓	Ortho phosphate still evident in samples.
11/30 Fiore/Colello NATIONAL FUEL OIL Passaic Ave. Newark ✓	Sheen on surface of river still visible.
11/30 Fiore/Colello CITY OF NEWARK Blanchard, Lockwood, & Roanoke Storm Sewers ✓	Samples taken found to be polluting.
11/30 Fiore/Colello NEWARK HOUSING AUTHORITY 535 Ave. P Newark (drums of contaminated material) ✓	Special - 55 gallon drums carted off property - remaining contaminated drums on property of N.J. Turnpike must be removed.
11/30 Cordasco/Parr CITY OF NEWARK Meadowbrook Storm outlet ✓	Status quo
11/30 Cordasco/Parr CITY OF ORANGE Washington St. Storm ✓	Sample taken analyzed as non polluting,
11/30 Fleming/Perrapato CITY OF PASSAIC Madison St. Storm ✓	Status quo
11/30 Fleming/Perrapato CITY OF PASSAIC Speer Village ✓	Unable to sample this week, too high waters covering outlet.
11/30 Fleming/Perrapato CITY OF PASSAIC Oak St. & Paulison Ave. <i>called</i>	Special - sanitary overflow occurred, DPW notified - line cleared.
11/30 Fleming/Perrapato/ Sventy/Cuccinello PANTASOTE 26 Jefferson St. Passaic <i>INSP. Sventy-L.C.</i>	Received complaint of oily film on surface of river - traced to this company
11/30 Cupo/Sventy/Fleming/ & CITY OF CLIFTON Perrapato Paulison Ave. storm <i>Progress</i>	A series of 3 samples taken - 1 non polluting - 2 polluting - high fecal coliform -

✓ Board
✓ Cards

WEEKLY RESUME

12/24/79 to 12/28/79

✓ 12/26 Sventy/Perrapato
CITY OF CLIFTON
Scoles and Shafto Sts.

INSP

Violation-Elimination - due to broken pipe - city bypassed sanitary to storm, this practice was stopped by order of inspectors

12/28 Sventy
CBS TOYS
Paul Kohner Dr.
Elmwood Park

monthly

Inspections made during month found no oily material seeping under filter fence

12/28 Cuccinello/Perrapato
CITY OF CLIFTON
Athenia Storm Sewer ✓

Sample taken analyzed as polluting

12/28 Sventy
CURTISS WRIGHT
Passaic St.
Wood Ridge

monthly

Filter pads and boom maintained at storm line - oily material contained - Feds Brook clear

✓ 12/28 Sventy/Tomaro
CITY OF GARFIELD
Cottage Place/River Drive

INSP

Violation-Elimination - blockage in sanitary line caused overflow into street catch basin thence Passaic River

12/28 Fiore/Colello/
Perrapato
TOWN OF KEARNY
Pennsylvania Ave. ✓

Pennsylvania Ave. storm samples polluting - taken at Monsanto Company was non polluting

12/28 Sventy
BORO OF LODI
Millbank Brook at Mouth to
Saddle River

monthly

8" line located 5' under Main St. discharges into brook - polluting materials-to be corrected sometime in future, stated by K. Job Boro Engineer

12/28 Sventy
BORO OF LODI
12" Overflow into the
Saddle River at Hendricks
St. Pump Station

monthly

There has been no visible trace of seepage at this location during the month of December

12/28 Sventy
TOWN OF LYNDHURST
Lake Ave. Storm ✓

Samples taken analyzed as polluting

12/28 Sventy
TOWN OF LYNDHURST
New York Ave. storm at Livingston ✓

same as above

12/28 Fiore/Colello
NATIONAL FUEL OIL
Passaic Ave.
East Newark

update

Slight oil sheen still evident
at this time

12/28 Fiore/Colello/
Perrapato ✓
CITY OF NEWARK
Blanchard St., Lockwood St.
& Roanoke Ave. Storm Sewers

Pollution still continues at these
areas - nothing being done by city
to abate problem

12/28 Cordasco/Parr ✓
CITY OF NEWARK
Meadowbrook Storm

Status quo

12/28 Cordasco/Parr ✓
CITY OF ORANGE
Washington St.

Sample taken non polluting-outlet
running clear

12/29 Cuccinello/Perrapato ✓
CITY OF PASSAIC
Madison St.

Samples indicate polluting - fecal

12/28 Tomaro/Perrapato
CITY OF PASSAIC
Paulison and Oak St. *update*

Bypassing of sanitary to storm took
place - this was ordered stopped
by inspectors

12/29 Cuccinello/Perrapato ✓
CITY OF PASSAIC
Speer Village outlet

Sample taken analyzed as polluting

12/31/79 Cuccinello/Fleming/
Perrapato
CITY OF PASSAIC
Monroe St. and Parker Ave. *INSP. (V.E.)*

Overflow of sanitary line into Weasel
Brook along Parker Ave.