



**NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER SYSTEM ENGINEERING
TECHNICAL REVIEW FORM**

**GENERAL CONDITIONS
(N.J.A.C. 7:10-11.6)**

Water Purveyor	PWSID#	Municipality		
		YES	NO	N/A
1. Does the system's overall instrumentation meet the requirements of N.J.A.C. 7:10-11.6(b)?		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2. Is the system equipped with the appropriate analytic equipment?		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3. Do the proposed disinfection methods comply with AWWA standards C651- C654 as required by N.J.A.C. 7:10-11.6(d)?		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4. If a cross connection exists with an unapproved water source (e.g. well, swimming pool, sewage pump station) has the system obtained a Physical Connection Permit as per N.J.A.C. 7:10-10?		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5. Are water treatment plant residuals properly handled and disposed of?		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6. If applicable, have NJPDES permits been obtained for the disposal of treatment plant residuals?		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7. Does the design of all buildings comply with the requirements of N.J.A.C 7:10-11.6(g)?		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8. For 1 MGD or higher capacity treatment plants, are necessary tools and accessories provided (N.J.A.C. 7:10-11.6(h)?		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9. Is auxiliary power required and if so is auxiliary power provided (N.J.A.C. 7:10-11.6(i)?		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10. Does the system meet the minimum storage requirements (N.J.A.C. 7:19-6.7)?		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11. Do all proposed additives meet ANSI/NSF Standard 60 as required by N.J.A.C. 7:10-8.2(a)1?		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

YES NO N/A

12. Do all material used in construction of the water system's components which come in contact with drinking water meet ANSI\NSF Standard 61 as required by N.J.A.C. 7:10-8.2(a)2?

Submit appropriate engineering plans, specifications, reports, etc. to substantiate your answers

This form is required to be submitted with all N.J.A.C. 7:10-11.5 Permit Applications

I hereby certify that answers provided herein are accurate and reflective of the project being considered for approval.



Signature of Engineer
Professional Engineer's Embossed Seal

_____ Date

_____ N.J.P.E. #

Type or Print Name of Engineering Firm

