

NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION **BUREAU OF WATER SYSTEM ENGINEERING TECHNICAL REVIEW FORM**

GRANULAR ACTIVATED CARBON CONTACTORS (N.J.A.C. 7:10-11.15(h))

Water Purveyor	PWSID#	Municipality			
No. of Contactors:	Modes o	of Operation: Series OR Parallel Upflow OR Downflo	w		
Vessel Material: Alum Concr	rete				
Type of Media Effective Size	Media Thickness	Uniformity Coefficient			
	Carbo Empt	on Volume per Contactor: on Mass per Contactor: ty Bed Contact Time:			
Well No.	Capacity (gpm)	Contaminant Level Found Design Level (ppb) (ppb)	•		
		YES NO	N/A		
1. Does the design meet req	A.C. 7:10-11.14?				
2. Is the empty bed contact	time not less than 20 minutes?	(N.J.A.C. 7:10-11.15(h)2)			
3. Are the units capable of t (N.J.A.C. 7:10-11.15(h)3	peing backwashed at a rate not	less than 12 gpm/ft ² ?			

BWSE-PA15H (09/13)	Page 2 of 2	Project No. WCP					
			YES	NO	N/A		
4. If the units are being used for both filt time of breakthrough been re-determine effect of frequent backwashing? (N.J.	ned to account for the ch						
5. For pressure units, are means provided (N.J.A.C. 7:10-11.15(h)5)	l to release excess pressu	ire?					
6. Are influent, intermediate, and effluent (N.J.A.C. 7:10-11.15(h)6)	at sampling taps provided	1?					
7. Is the system designed to use virgin ca	arbon? (N.J.A.C. 7:10-11	.15(h)8)					
8. Is the granular activated carbon bed at	least 48 inches deep? (N	J.J.A.C. 7:10-11.15(h)9)) 🗌				
9. Is each unit provided with isolation va	alves and a drain? (N.J.A.	.C. 7:10-11.15(h)12)					
Submit appropriate engineering plans, specifications, reports, etc. to substantiate your answers I hereby certify that answers provided herein are accurate and reflective of the project being considered for approval.							
Signature of Engineer Professional Engineer's Embossed Seal	Date	N.J.P.E. #					

Type or Print Name of Engineering Firm

PA15H (09/13)

Professional Engineer's Embossed Spal