

Sum

DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATERSHED MANAGEMENT


REVISION TO THE ATLANTIC COUNTY WATER QUALITY MANAGEMENT PLAN

TAKE NOTICE that on **MAY 17 1999**, pursuant to the provisions of the Water Quality Planning Act, N.J.S.A. 58:11A-1 et seq., and the Statewide Water Quality Management Planning rules, N.J.A.C. 7:15-3.5, a revision to the Atlantic County Water Quality Management Plan was adopted by the Department. This revision adds the proposed 18 unit single family home **Tranquility Estates** development to the sewer service area of the Atlantic County Utilities Authority's City Island Treatment Plant. The proposed development will be located on Block 6504, Lot 9 in Egg Harbor Township, Atlantic County, and will contain 27.8 acres. It has a projected wastewater flow of 5,400 gallons per day based on 300 gallons per day for each of 18 residential units.



Lance R. Miller
Director
Division of Watershed Management
Department of Environmental
Protection

Date 5/17/99




SANITARY SEWER PLAN	
	THANQUANTY ESTATES STEELMANVILLE ROAD BLOCK 184, LOT 1 TOWNSHIP OF EDEN HARBOR ATLANTIC COUNTY, NEW JERSEY
ROBERT A. BRUCE PROFESSIONAL ENGINEER No. 12-10000-0000	ROBERT BRUCE & ASSOCIATES Consulting Engineers and Planners 1000 N. 1st Street, 2nd Floor Atlantic City, NJ 08401
SHEET NO. 001 OF 001	DATE: 08/14/99

FIGURE NO. 4
U.S.C.G.S. QUAD
SCALE: 1"=2000'

Tranquility Estate

