


DEPARTMENT OF ENVIRONMENTAL PROTECTION  
DIVISION OF WATERSHED MANAGEMENT


REVISION TO THE ATLANTIC COUNTY WATER QUALITY  
MANAGEMENT PLAN

TAKE NOTICE that on **JUN 14 2005**, pursuant to the provisions of the Water Quality Planning Act, N.J.S.A.58:11A-1 et seq., and the Statewide Water Quality Management Planning rules, N.J.A.C. 7:15-3.5, a revision to the Atlantic County Water Quality Management Plan (WQMP) was adopted by the Department. This revision modifies the Atlantic County WQMP and the Egg Harbor Township Wastewater Management Plan to add Lot 10, Block 6504 to the Atlantic County Utilities Authority's City Island Treatment Plant sewer service area. This lot is 1.25 acres and is located at the intersection of Steelmanville Road and Glen Aire Drive in Egg Harbor Township. The proposal is to subdivide the lot for the construction of 2 single family dwellings. The projected increase in the wastewater flow discharged to the Atlantic County Utilities Authority City Island Treatment Plant will be 600 gallons per day. This treatment plant is permitted by New Jersey Pollutant Discharge Elimination System (NJPDES) permit number NJ0024473 and has a permitted flow of 40 million gallons per day. It has adequate capacity to treat the additional flow from this proposed revision and will not require an increase in its permitted flow. This addition to the sewer service area qualifies as a revision in accordance with N.J.A.C 7:15-3.5(b)(4)(v) which states: "Expansion of a future sewer service area to contiguous lots, where the expansion involves less than 100 acres,

contributes less than 8,000 gallons per day of additional wastewater flow, and does not create a significantly new pattern of sewer development such that a significant potential or incentive is created for additional revisions or amendments to open new areas to sewer development."

  
\_\_\_\_\_

Lawrence J. Baier, Director  
Division of Watershed Management  
Department of Environmental Protection

  
\_\_\_\_\_

Date