


DEPARTMENT OF ENVIRONMENTAL PROTECTION
OFFICE OF ENVIRONMENTAL PLANNING

AMENDMENT TO THE MONMOUTH COUNTY WATER QUALITY MANAGEMENT
PLAN

Public Notice

Take notice that on **SEP 29 1997**, pursuant to the provisions of the New Jersey Water Quality Planning Act, N.J.S.A. 58:11A-1 et seq., and the Statewide Water Quality Management Planning rules (N.J.A.C. 7:15-3.4), an amendment to the Monmouth County Water Quality Management Plan was adopted by the Department of Environmental Protection. This amendment designates Block 57.01, Lot 19, on Monmouth Road in Millstone Township, Monmouth County, as "Service Area for Wastewater Facilities with Planning Flows of Less Than 20,000 Gallons Per Day Which Discharge to Ground Water." The future wastewater planning flow of the wastewater treatment and disposal system will be approximately 4,200 gallons per day, based on a flow contribution of 35 gallons per seat per day for the 120 seat McDonald's restaurant.

This amendment represents only one part of the permit process and other issues will be addressed prior to final permit issuance. Additional issues which were not reviewed in conjunction with this amendment but which may need to be addressed may include, but are not limited to, the following: antidegradation; effluent limitations; water quality analysis; exact locations and designs of future treatment works (pump stations, interceptors, sewers, outfalls, wastewater treatment plants); and development in wetlands, flood prone areas, designated Wild and Scenic River areas, or other environmentally sensitive areas which are subject to regulation under Federal or State statutes or rules.



SITE

Carrs Tavern

Holmeson

Deboys Ch

INTERCHANGE 16

Burkesville

PROSPECTOWN LAKE WILDLIFE MANAGEMENT AREA

MONMOUTH CO
CREEK

Toms