



DEPARTMENT OF ENVIRONMENTAL PROTECTION  
DIVISION OF WATERSHED MANAGEMENT

REVISION TO THE MONMOUTH COUNTY WATER QUALITY MANAGEMENT  
PLAN

TAKE NOTICE that on **JUL 02 2003**, pursuant to the provisions of the Water Quality Planning Act, N.J.S.A.58:11A-1 et seq, and the Statewide Water Quality Management Planning rules, N.J.A.C. 7:15-3.5, a revision to the Monmouth County Water Quality Management Plan was adopted by the Department. This revision expands the sewer service area of the Township of Middletown Sewerage Authority (TOMSA) to include the Laurel Ridge Development to be located on Block 795, Lot 4 in Middletown Township. That property, approximately twelve acres in size, consists of one existing residential home and six new single-family homes. In addition, there are four existing residential lots (Block 794, Lot 2 and Block 795, Lots 1, 2, and 3) which would connect into the sewer system. The total acreage to be added to the TOMSA sewer service area is 17.99 acres. The estimated average daily wastewater flow to result from this project is 3,300 gallons per day (GPD) based on 300 GPD from each of the eleven units. This revision has been reviewed in accordance with Executive Order No. 109 (2000) and N.J.A.C. 7:15-5.18. Due to the scope of this revision, it is not subject to the alternatives analyses under that Executive Order and rule provision.



Lawrence J. Bajer, Director  
Division of Watershed Management  
Department of Environmental Protection

  
Date