



DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATERSHED MANAGEMENT

REVISION TO THE NORTHEAST WATER QUALITY MANAGEMENT PLAN

TAKE NOTICE that on **AUG 13 2003**, pursuant to the provisions of the Water Quality Planning Act, N.J.S.A.58:11A-1 et seq, and the Statewide Water Quality Management Planning rules, N.J.A.C. 7:15-3.5, a revision to the Northeast Water Quality Management Plan (NEWQMP) was adopted by the Department. This revision will note in both the NEWQMP and the Rockaway Valley Sewerage Authority (RVRSA) Wastewater Management Plan (WMP), the flow of the Green Pond Well Field and Treatment Plant, New Jersey Pollutant Discharge Elimination System (NJPDES) permit number NJ0035785. This facility is classified as a minor discharger whose activity is the treatment and supply of potable water for public use. The combined long-term average flow is estimated to be 0.2 million gallons per day (MGD). The permit will authorize the discharge of an average of 0.2 MGD of untreated filter backwash from granulated activated carbon filters and potable water used for orifice calibration to White Meadow Brook, which is classified FW2-NT. In accordance with N.J.A.C 7:15-3.5(b)4i, this revision modifies Table V-3 for Industrial Dischargers in the NEWQMP to reflect the permitted flow from an industrial treatment works when there is no change in service area or discharge type proposed.


Lawrence J. Baier, Director
Division of Watershed Management
Department of Environmental Protection


Date