


DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATERSHED MANAGEMENT


REVISION TO NORTHEAST WATER QUALITY MANAGEMENT PLAN

TAKE NOTICE that on **APR 15 2008**, pursuant to the provisions of the Water Quality Planning Act, N.J.S.A.58:11A-1 et seq, and the Statewide Water Quality Management Planning rules, N.J.A.C. 7:15-3.5, a revision to the Northeast Water Quality Management Plan was adopted by the Department. The ST Linden Terminal is located in the City of Linden, Union County Block: 587 Lots 2.2 and 4. This revision is for a new discharge of 150 gallons per day of Boiler Blowdown which will discharge through an already existing onsite permitted stormwater outfall to the Arthur Kill. The current boiler blowdown is being collected by a vacuum truck and shipped off site. The rest of the wastewater from the site discharges to the Linden Roselle Sewerage Authority. This project qualifies as a revision under N.J.A.C. 7:15-3.5 (b) 4i, as it is an increase of flow from an industrial treatment works where there is no change in service area or discharge location.



Lawrence J. Baier, Director

Division of Watershed Management
Department of Environmental Protection



Date