

**NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION
OFFICE OF WATER RESOURCES MANAGEMENT COORDINATION**

Revision to the Sussex County Water Quality Management Plan

Public Notice

TAKE NOTICE that on **MAR 24 2015** pursuant to the provisions of the Water Quality Planning Act, N.J.S.A.58:11A-1 et seq., and the Statewide Water Quality Management Planning rules, N.J.A.C. 7:15-3.5, a revision to the Sussex County Water Quality Management Plan was adopted by the Department. This revision modifies the Morris County Wastewater Management Plan (WMP) to identify portions of Block 273.01, Lots 2.061 & 2.062, within Jefferson Township, Morris County as a Discharge to Groundwater Service Area for the Highlander View Apartments.

Recently, Green and Fifteen, LLC submitted an application for a revision to the Morris County WMP proposing the addition of 4.83 acres to the SSA for two residential apartment buildings each containing 4 one-bedroom apartments and 15 two-bedroom apartments. The total projected wastewater flow from this 38 apartments proposed development in accordance with N.J.A.C. 7:14A-23.3 is 7,950 gallons per day (gpd).

The Department has determined that this project qualifies as a revision in accordance with P.L. 2011, c. 203, amended by P.L. 2013, c. 188, where the WMP agency has submitted a WMP designating sewer service area and the proposed development or activity is for installation of individual subsurface sewage disposal facilities having a wastewater planning flow greater than 2,000 gallons per day and less than 8,000 gallons per day and meets the technical requirements for eligibility for a NJPDES Discharge to Ground Water permit.

In addition, pursuant to N.J.A.C. 7:15-5.24(b), the Department has concluded that no significant impacts will occur to environmentally sensitive areas as a result of this revision.

CKokas

Colleen Kokas, Director
Office of WRM Coordination
Department of Environmental Protection

3-24-15

Date