

DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATER RESOURCES

AMENDMENT TO THE TRI-COUNTY WATER QUALITY MANAGEMENT PLAN

Public Notice

Take notice that on **JAN 31 1991**, pursuant to the provisions of the Water Quality Planning Act, N.J.S.A. 58:11A-1 et seq., and the Statewide Water Quality Management Planning rules (N.J.A.C. 7:15-3.4), an amendment to the Tri-County Water Quality Management Plan was adopted by the Department. This amendment adopts the Township and the City of Burlington Wastewater Management Plan (WMP). The Township and City of Burlington WMP proposes to expand the sewer service area of Burlington Township and Burlington City to include the majority of both municipalities. In addition, the WMP proposes to upgrade and expand the Burlington Township Central Avenue Wastewater Treatment Facility (WTF) to a wastewater flow capacity of 3.65 million gallons per day (MGD) and move the effluent outfall location to the Delaware River. The existing LaGorce Square WTF will be abandoned and replaced by a 1.0 MGD pumping station. This pumping station will transfer wastewater from eastern Burlington Township to the expanded Central Avenue WTF. The Burlington City WTF will be upgraded and rerated to a design capacity of 2.7 MGD and the effluent outfall location will be moved to the Delaware River. An existing 600,000 GPD force main, which transfers wastewater from the Central Avenue WTF to the City WTF, will become a permanent component of the municipal infrastructure.

DATE: JAN 31 1991

ORIGINAL SIGNED BY
LEROY T. CATTANEO P.E., P.P.,
Deputy Director
Division of Water Resources
Department of Environmental
Protection