


DEPARTMENT OF ENVIRONMENTAL PROTECTION  
DIVISION OF WATERSHED MANAGEMENT

REVISION TO THE TRI-COUNTY WATER QUALITY MANAGEMENT PLAN

TAKE NOTICE that on **MAR 24 1999**, pursuant to the provisions of the Water Quality Planning Act, N.J.S.A. 58:11A-1 *et seq.*, and the Statewide Water Quality Management Planning rules, N.J.A.C. 7:15-3.5, a revision to the Tri-County Water Quality Management Plan (WQMP) was adopted by the Department. This revision modifies the Mount Holly Municipal Utilities Authority (MHMUA) Wastewater Management Plan (WMP) and allows the U.S. Navy AEGIS Combat System Engineering Development Site (CSEDS) in Moorestown Township, Burlington County to discharge non-contact cooling water to the MHMUA Sewage Treatment Plant (STP) in addition to the previously approved discharge of domestic wastewater from this site.

In addition, the revision reduced the total projected wastewater flow in the MHMUA WMP from Moorestown Township for both domestic and non-contact cooling water sources. The domestic discharge projection was reduced from 15,075 gallons per day (gpd) to 3,000 gpd. The non-contact cooling water discharge projection was reduced from 10,000 gpd to 3,000 gpd. Since the non-contact cooling water was not previously proposed to be discharged to the MHMUA, the total projected wastewater planning flow decrease to the MHMUA STP from this revision was 9,075 gpd, from 7.675 million gallons per day (mgd) to 7.665 (mgd).



Lance R. Miller  
Director  
Division of Watershed Management  
Department of Environmental Protection

3/24/99  
Date

navyAEGISfn