

DEPARTMENT OF ENVIRONMENTAL PROTECTION  
DIVISION OF WATERSHED MANAGEMENT

REVISION TO THE TRI-COUNTY WATER QUALITY MANAGEMENT PLAN

Public Notice

Take notice that on **MAY 23 2000**, pursuant to the provisions of the New Jersey Water Quality Planning Act, N.J.S.A. 58:11A-1 et seq., and the Statewide Water Quality Management Planning rules (N.J.A.C. 7:15-3.4), a revision to the Tri-County Water Quality Management Plan was adopted by the Department of Environmental Protection (Department). This revision proposal was submitted on behalf of East Greenwich Township and revises the Gloucester County Utilities Authority (GCUA) Consolidated Region Facilities Plan.

This revision has been proposed to increase the sewer service area to include 13 single-family homes located on Block 1002, Lot 1.15 and will produce a flow of 3900 gallons per day. This flow will be conveyed by an eight-inch sanitary sewer extension to the GCUA Deptford Sewer Treatment Plant. Do to the scope of this revision it is not subject to the alternative analysis required by Executive Order 109.



Lance R. Miller  
Director  
Division of Watershed Management

5/23/00  
Date