


DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATERSHED MANAGEMENT

REVISION TO THE TRI-COUNTY WATER QUALITY MANAGEMENT
PLAN

TAKE NOTICE that on **DEC 14 2004**, pursuant to the provisions of the Water Quality Planning Act, N.J.S.A.58:11A-1 et seq., and the Statewide Water Quality Management Planning rules, N.J.A.C. 7:15-3.5, a revision to the Tri-County Water Quality Management Plan was adopted by the Department. This proposal revises the service area for the Pinelands Wastewater Company Plant # 2 for Southampton Township, Burlington County to include Wawa Store No. 376 located on 2.26 acres at Block 1501; Lot 6. The revised service area is depicted as "Wawa" on a digitally prepared map entitled "WASTEWATER MANAGEMENT PLAN, APPENDIX 2, VINCENTOWN, COAH SITE, SCHOOL AND MUNICIPAL COMPLEX", prepared by Richard A. Alaimo Association of Engineers, dated October 2002, and revised by NJDEP.

Wawa has performed weekly pump outs of their septic tank for the past 5 years. This revision allows for the abandonment of the existing onsite septic system and connection to the service area for the Pinelands Wastewater Company Plant # 2. This will increase the sewer service area by 2.26 acres and will provide approximately 385 gallons per day (GPD) of wastewater. This expansion of the sewer service area for Southampton

Township is to a contiguous lot, less than 100 acres in size, contributing less than 8,000 GPD of additional wastewater flow and does not create a significantly new pattern of sewer development.



Lawrence J. Baier, Director
Division of Watershed Management
Department of Environmental Protection



Date