


DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATERSHED MANAGEMENT

REVISION TO THE TRI-COUNTY WATER QUALITY MANAGEMENT PLAN

TAKE NOTICE that on **SEP 12 2006**, pursuant to the provisions of the Water Quality Planning Act, N.J.S.A. 58-11A-1 et seq., and the Statewide Water Quality Management Planning rules, N.J.A.C. 7:15-3.5, a revision to the Tri-County Water Quality Management Plan (WQMP) was adopted by the Department. This revision corrects the Tri-County WQMP and the Logan Township MUA Wastewater Management Plan pursuant to N.J.A.C. 7:15-3.5(b) 1, to include a discharge from an existing industrial facility known as Logan Generating Co LP which was previously identified in the WMP as a zero discharge facility. This facility has discharged to the Delaware River under NJPDES permit number NJ0076872 since 1991. Under normal operating conditions this discharge consists of stormwater and groundwater from non-process areas of the plant that is discharged through two outfalls. The total current long-term average discharge amount is 0.12 MGD, with no permitted flow limitation in the NJPDES permit. Under certain emergency conditions the discharge consists of reject water from the reverse osmosis system and cooling tower blowdown. When the salt line within the Delaware River migrates upstream due to lack of freshwater flow this emergency discharge is allowed to protect equipment from saltwater damage. This facility is located in Logan Township, Gloucester County at 76 Route 130.



Lawrence Baier, Director
Division of Watershed Management
Department of Environmental
Protection

September 12, 2006
Date