



DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATERSHED MANAGEMENT

REVISION TO THE UPPER DELAWARE WATER QUALITY
MANAGEMENT PLAN

TAKE NOTICE that on NOV 26 2003 pursuant to the provisions of the Water Quality Planning Act, N.J.S.A.58:11A-1 et seq, and the Statewide Water Quality Management Planning rules, N.J.A.C. 7:15-3.5, a revision to the Upper Delaware Water Quality Management Plan was adopted by the Department. This revision expands the Warren County Pequest River Municipal Utility Authority's Oxford Sewage Treatment Plant sewer service area to include Block 38, Lot 26 in the Washington Township, Warren County. This property is currently designated in Washington Township Wastewater Management Plan as "Service Area for Wastewater Facilities with Planning Flows of Less than 2,000 gpd which Discharges to Groundwater". This qualifies as a revision per N.J.A.C 7:15-3.5(b)4v which provides for expansion of sewer service to contiguous lots, where the expansion involves less than 100 acres, contributes less than 8,000 gpd of additional wastewater flow, and does not create a significantly new pattern of sewer development such that a significant potential or incentive is created for additional revision or amendments to open new areas to sewer development. This revision will amend both the Warren County Pequest River Municipal Utility Authority and Washington Township, Warren County Wastewater Management Plans. No sewage treatment plant expansion is necessary to accommodate this flow.



Lawrence J. Baier, Director
Division of Watershed Management
Department of Environmental Protection



Date