


DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATERSHED MANAGEMENT


REVISION TO THE UPPER DELAWARE WATER QUALITY
MANAGEMENT PLAN

TAKE NOTICE that on **APR 12 2004**, pursuant to the provisions of the Water Quality Planning Act, N.J.S.A.58:11A-1 et seq, and the Statewide Water Quality Management Planning rules, N.J.A.C. 7:15-3.5, a revision to the Upper Delaware Water Quality Management Plan was adopted by the Department. This revision is for Frelinghuysen Township Elementary School, located at Lot 27, Block 201, Frelinghuysen Township, Warren County. The Frelinghuysen Township Wastewater Management Plan (WMP) currently identifies the permitted flow and design capacity of 6,000 gallons per day (gpd) and a 20-Year projected flow of 3,750 gpd and population to be served as 250 students and 55 faculty. This revision will change the projected 20-Year population to be served to 375 students and 25 faculty and the projected wastewater flow to 5,625 gpd as per N.J.A.C 7:14A-23.3 projected flow criteria. This modification qualifies as a revision pursuant to N.J.A.C 7:15-3.5(b) 1i, as the WMP was adopted in 1997 while the 1996 NJPDES permit reflected the building was at that time occupying 30,000 square feet and designed to accommodate 400 persons (375 students and 25 staff).



Lawrence J. Baier, Director

Division of Watershed Management
Department of Environmental Protection



Date