

NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION
OFFICE OF ENVIRONMENTAL PLANNING

REVISION TO THE UPPER RARITAN WATER QUALITY MANAGEMENT PLAN

TAKE NOTICE that on **AUG 03 1995**, pursuant to the provisions of the Water Quality Planning Act, N.J.A.C. 58:11A-1 et seq., and the Statewide Water Quality Management Planning Rules, N.J.A.C. 7:15-3.5, a revision to the Upper Raritan Water Quality Management Plan was adopted by the Department. This revision identifies the Glen Gardner Hotel, located on Main Street in the Borough of Glen Gardner, Hunterdon County (Block 8, Lot 8), as an existing facility requiring a New Jersey Pollutant Discharge Elimination System permit. The Glen Gardner Hotel currently consists of six single family apartments and one bar (which is closed). The closed bar portion of the facility will be renovated and reopened as a public coffee house/cafe. The six single family apartments discharge 2,100 gallons per day (gpd) of wastewater to an existing subsurface sewage disposal system. The closed bar did not discharge to the same subsurface sewage disposal system as the six single family apartments. When the remodeled public coffee house/cafe opens it will discharge 500 gpd (100 patrons at 5 gpd per patron) of wastewater to its own subsurface sewage disposal system. The former subsurface sewage disposal system which had served the former bar will be abandoned. There will be no increase in wastewater flow from the original wastewater planning flow of 2,600 gpd formerly discharged to ground water from the Glen Gardner Hotel facility.



Martin A. Bierbaum
Administrator
Office of Environmental Planning
Department of Environmental Protection

8/3/95
Date

MRD:GLENREV.DOC