

DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATERSHED MANAGEMENT

REVISION TO THE UPPER RARITAN WATER QUALITY MANAGEMENT PLAN

TAKE NOTICE that on **JUL 12 2004**, pursuant to the provisions of the Water Quality Planning Act, N.J.S.A.58:11A-1 et seq, and the Statewide Water Quality Management Planning rules, N.J.A.C. 7:15-3.5, a revision to the Upper Raritan Water Quality Management Plan was adopted by the Department. This revision for the Mount Olive Library revises the Mount Olive Township Wastewater Management Plan.

This revision expands the sewer service area of the Mount Olive Villages Sewer Company Sewer Treatment Plant to include Block 7900/Lot 3, the site of the new Mount Olive Library. The Mount Olive Library is currently identified in the Mount Olive Township Wastewater Management Plan as an On-Site Groundwater Discharge Area for Facilities of Less than 2,000 gallons per day (gpd). Upon completion the library will be 20,800 square feet. The wastewater generated by the Mount Olive Library site will total 1,857 gpd. This project is being processed as a revision pursuant to N.J.A.C. 7:15-3.5 (b)4 because the site is adjacent to the current Sewer Service Area, the site is less than 100 acres and generates less than 8,000 gpd.



Lawrence J. Baier, Director

Division of Watershed Management
Department of Environmental Protection



Date