

DOCKET NO. D-2015-007 CP-3

DELAWARE RIVER BASIN COMMISSION

Discharge to a Tributary of Special Protection Waters

**Pennsylvania Department of Conservation and Natural Resources
Washington Crossing Historic Park Upper Wastewater Treatment Plant
Solebury Township, Bucks County, Pennsylvania**

PROCEEDINGS

This docket is issued in response to an application submitted to the Delaware River Basin Commission (DRBC or Commission) on January 30, 2025 (Application), for renewal of the docket holder's existing wastewater treatment plant (WWTP) and its discharge. The Pennsylvania Department of Environmental Protection (PADEP) issued National Pollutant Discharge Elimination System (NPDES) Permit No. PA0042978 for this discharge.

The application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Bucks County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on February 4, 2026.

A. DESCRIPTION

1. Purpose. The purpose of this docket is to renew approval of the docket holder's existing 0.025 million gallons per day (mgd) WWTP and its discharge. Due to minimal flows being generated, all wastewater is currently being pumped/hailed to an off-site treatment facility for treatment/disposal. In the future, and as more facilities are brought back online in the service area, the park intends to treat wastewater at the Upper WWTP.

2. Location. The docket holder's WWTP is located off River Road in Solebury Township, Bucks County, Pennsylvania. The WWTP will continue to discharge treated effluent to Delaware River Water Quality Zone 1D at River Mile 146.6 and is located in the drainage area to the Lower Delaware Special Protection Waters (SPW) and has been classified as Significant Resource Waters (SRW).

The location of the WWTP outfall in the Delaware River Watershed is as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
001	40° 20' 7"	74° 56' 22"

3. **Area Served.** The docket holder's WWTP will continue to serve the "Upper" portion of Washington Crossing Historic Park in Solebury Township located in Bucks County, Pennsylvania. For the purpose of defining the Area Served, the Type of Discharge and the Service Area sections from the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in Section C. DECISION of this docket.

4. **Design Criteria.** When operating, the docket holder's 0.025 mgd WWTP utilizes a conventional activated sludge treatment process with chlorine contact disinfection.

5. **Facilities.** The WWTP facilities consist of an influent pump station, an equalization tank, two (2) aeration tanks, a clarifier, an alum feed system, a sludge holding tank, and a chlorine contact disinfection tank.

The docket holder's WWTP discharges to waters classified as SPW and is required to have available standby power. The existing WWTP has a generator installed capable of providing standby power.

The docket holder's WWTP is not staffed 24 hours per day and shall have a remote alarm system that continuously monitors plant operations in accordance with the Commission's SPW requirements. The existing WWTP has a remote alarm system installed that continuously monitors plant operations.

The docket holder has prepared and implemented an emergency management plan (EMP) for the existing WWTP in accordance with Commission SPW requirements.

The project facilities are not located in the 100-year floodplain.

When the WWTP is operating, wasted sludge will be hauled off-site for disposal in accordance with the NPDES Permit No. PA0042978.

6. **Water Withdrawals.** The potable water supply in the project service area is provided by individual on-site groundwater wells. The groundwater withdrawals are operated at a withdrawal rate below the DRBC groundwater withdrawal review threshold and are not subject to Commission review and approval.

7. **NPDES Permit / DRBC Effluent Requirements.** NPDES Permit No. PA0042978 issued by the PADEP includes final effluent limitations for the project discharge to surface waters classified by the PADEP as supporting warm water fishes (WWF) and migratory fishes (MF). EFFLUENT TABLES C-1 & C-2 included in Section C. DECISION condition C.1. of this docket, contain effluent requirements for DRBC parameters that must be met as a condition of this approval. Effluent requirements for Outfall No. 001 are based on a discharge rate of 0.025 mgd.

8. **Relationship to the Comprehensive Plan.** The existing WWTP was included in the Comprehensive Plan by Docket No. D-2015-007 CP-1 on September 16, 2015. The WWTP approval was renewed by Docket No. D-2015-007 CP-2, on September 11, 2019. Issuance of this docket will continue the WWTP and its discharge in the Comprehensive Plan.

B. **FINDINGS**

The docket holder applied to renew approval of their existing 0.025 mgd WWTP and its discharge.

Due to the minimal and intermittent nature of sewage inflows in more recent years, in 2017 the facility commenced contracting to have raw sewage from the collection system pumped and hauled to an offsite wastewater treatment plant for treatment. Therefore, the WWTP is not currently treating sewage and does not discharge. The docket holder has requested continuance of the approval to treat and discharge for future operations as more facilities in the service area come online or inflows become more consistent.

1. **Special Protection Waters**

In 1992, the DRBC adopted SPW requirements, as part of the DRBC *Water Quality Regulations (WQR)*, designed to protect existing water quality in applicable areas of the Delaware River Basin. One hundred twenty miles of the Delaware River from Hancock, New York downstream to the Delaware Water Gap has been classified by the DRBC as SPW. This stretch includes the sections of the river federally designated as "Wild and Scenic" in 1978 -- the Upper Delaware Scenic and Recreational River and the Delaware Water Gap National Recreation Area - - as well as an eight-mile reach between Milrift and Milford, Pennsylvania which is not federally designated. The SPW regulations apply to this 120-mile stretch of the river and its drainage area.

On July 16, 2008, the DRBC approved amendments to its *Water Quality Regulations (WQR)* that provide increased protection for waters that the Commission classifies as SPW. The portion of the Delaware River and its tributaries within the boundary of the Lower Delaware River Management Plan Area was approved for SPW designation

The docket holder's WWTP discharges to the drainage area to the Lower Delaware SPW. The docket holder's WWTP discharge is required to comply with the SPW requirements, as outlined in Article 3.10.3A.2. of the *WQR*.

Article 3.10.3A.2.e.1). and 2). of the Commission's *WQR* states that projects subject to review under Section 3.8 of the Compact that are located in the drainage area of SPW must submit for approval a Non-Point Source Pollution Control Plan (NPSPCP) that controls the new or increased non-point source loads generated within the portion of the docket holder's service area which is also located within the drainage area of SPW. The service area of the docket holder is located in the drainage area to the SPW. Since this project does not entail additional construction and/or expansion of facilities and service area and there are no new or increased non-point source loads associated with this approval, the NPSPCP requirement is not applicable at this time. Accordingly, Section C. DECISION condition C.3. has been included in this docket.

Solebury Township is regulated by the PADEP as a Stormwater Phase II municipality and is permitted by PADEP as such. Solebury Township adopted and implemented a stormwater ordinance in accordance with the PADEP requirements. The PADEP Stormwater Phase II requirements satisfy the NPSPCP requirements of the Commission.

As noted above in A.3. the docket holder's area served is located entirely in Solebury Township. This township has enacted and is actively implementing a non-point source/stormwater control ordinance adopting the Solebury Township Stormwater Management Ordinance No. 2011-06. Compliance with the Solebury Township Stormwater Management Ordinance No. 2011-06, effective on May 24, 2011, generally meets the requirements of Article 3.10.3.A.2.e.1 of the Commission's Water Quality Regulations for the Area Served as described in A.3. above within Solebury Township. Prior to allowing connections from any new service areas or any new developments not in compliance with these Ordinances the docket holder shall submit and have approved by the Executive Director of the DRBC a Non-Point Source Pollution Control Plan (NPSPCP) in accordance with Section 3.10.3.A.2.e.

2. Other

The nearest surface water intake of record for public water supply is located on the Delaware River approximately 11 River Miles downstream of the docket holder's IWTP and is operated by Pennsylvania American Water Company.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit conform with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge that meets the effluent requirements as set forth in the Commission's *Water Quality Regulations (WQR)*.

C. DECISION

Effective on the approval date for Docket No. D-2015-007 CP-3 below, the project described in Docket No. D-2015-007 CP-2 is removed from the Comprehensive Plan to the extent that it is not included in Docket No. D-2015-007 CP-3; Docket No. D-2015-007 CP-2 is terminated and replaced by Docket No. D-2015-007 CP-3; and the project and the appurtenant facilities described in Section A “DESCRIPTION” of this docket shall be included in the Comprehensive Plan. The project and appurtenant facilities as described in Section A of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

Monitoring and Reporting

1. The docket holder shall comply with the requirements contained in the EFFLUENT TABLES below. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email aemr@drbc.gov on the **Annual Effluent Monitoring Report Form** located at this web address: <https://www.nj.gov/drbc/programs/project/docket-app-info.html#3>. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations. The following average monthly effluent limits are among those listed in the NPDES Permit and meet or are more stringent than the effluent requirements of the DRBC.

EFFLUENT TABLE C-1: DRBC Parameters Included in NPDES Permit

OUTFALL 001 (Delaware River)		
PARAMETER	LIMIT	MONITORING
pH (Standard Units)	6 to 9 at all times	As required by NPDES Permit
Total Suspended Solids	30 mg/l	As required by NPDES Permit
Dissolved Oxygen	4.0 mg/l (minimum at all times)	As required by NPDES Permit
CBOD ₅ (at 20° C)	25 mg/l	As required by NPDES Permit
Ammonia Nitrogen	20 mg/l	As required by NPDES Permit
Fecal Coliform	200 colonies per 100 ml as a geo. avg.	As required by NPDES Permit
Phosphorus	1.0 mg/l	As required by NPDES Permit
Total Dissolved Solids	Monitor & Report	As required by NPDES Permit

OUTFALL 001 (Delaware River)		
PARAMETER	LIMIT	MONITORING
Total Nitrogen (5-1 to 9-30)	Monitor & Report	As required by NPDES Permit
Nitrate as Nitrogen (5-1 to 9-30)	Monitor & Report	As required by NPDES Permit

* See DECISION Condition C.6.

The following monitoring requirements and average monthly effluent limits are for DRBC parameters not listed in the NPDES Permit.

EFFLUENT TABLE C-2: DRBC Parameters Not Included in NPDES Permit

OUTFALL 001 (Delaware River)		
PARAMETER	LIMIT	MONITORING
CBOD ₅ (at 20° C)	Monitor & Report Percent Removal	Monthly

Other Conditions

2. Nothing in this docket constitutes a defense to any penalty action for past conduct of the docket holder or ongoing activity not authorized by this approval. In particular, renewal of this docket does not resolve violations – whether in the past or continuing – of provisions of the Delaware River Basin Compact (“Compact”) or any rule, regulation, order or approval duly issued by the Commission or the Executive Director pursuant to the Compact. The Commission reserves its right to take appropriate enforcement action against the docket holder, including but not limited to recovery of financial penalties consistent with Section 14.17 of the Compact, for any and all such prior or continuing violations.

3. Prior to allowing connections from any new service areas or any new developments, the docket holder shall either submit and have approved by the Executive Director of the DRBC a NPSPCP in accordance with Section 3.10.3.A.2.e. or receive written confirmation from the Executive Director of the DRBC that the new service area complies with a DRBC-approved NPSPCP.

4. Prior to the docket holder initiating any substantial alterations or additions to the existing WWTP as defined in Section 3.10.3A2.a.16) of the Commission’s WQR, an application must be submitted and approved by the Commission. Such an application shall be submitted prior to final design to ensure that the Commission can provide the docket holder with draft effluent limitations for SPW specific parameters as guidance for design as to not require duplication of work or cause a substantial expenditure of public funds without Commission approval. The docket holder is encouraged to contact the Commission staff during the planning stages to identify the potential effluent limitations required to meet the no measurable change parameters under SPW.

- 5.** Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.
- 6.** The docket holder may request permission from the Executive Director to perform specific conductance monitoring in lieu of TDS monitoring. The request shall be made in writing and shall include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow specific conductance monitoring in lieu of TDS monitoring.
- 7.** In accordance with 18 C.F.R. 401.8. of the Commission's *Rules of Practice and Procedure (RPP)*, if at any future time the Project is changed materially from the Project as described in this docket, it will be deemed to constitute a new and different project for the purposes of Article 11 of the Delaware River Basin Compact and will require Commission amendment of the Comprehensive Plan. In accordance with the same section of the RPP, whenever a change to the Project is made, the sponsor must advise the Executive Director, who will determine whether the change is deemed materially for purposes of this provision.
- 8.** This approval shall expire on the expiration date set forth below unless prior thereto the docket holder has applied to the Commission to renew or extend this approval.
- 9.** The docket holder is responsible for timely submittal to the DRBC of a docket renewal application on the appropriate application form including the appropriate docket application filing fee (see 18 C.F.R. 401.43) at least 6 months in advance of the docket expiration date set forth below. The docket holder will be subject to late filed renewal surcharges in the event of untimely submittal of its renewal application, whether DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. If a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below, the terms and conditions of the current docket will remain fully effective and enforceable pending the grant or denial of the application for docket approval.
- 10.** The docket holder is permitted to treat and discharge wastewater as set forth in the Area Served Section of this docket, which incorporates by reference the Type of Discharge and Service Area sections of the docket holder's Application to the extent consistent with all other conditions of this section. Any expansion beyond that included in Section A.3. Area Served is subject to DRBC review and approval in accordance with Section 3.8 of the Compact.

- 11.** In accordance with the Commission’s regulations at 18 C.F.R. Part 440, the docket holder is prohibited from discharging wastewater from high volume hydraulic fracturing (“HVHF”) or HVHF-related activities to waters or land within the Basin. The docket holder is further prohibited from discharging hydraulic fracturing wastewater, whether treated or untreated, from sources within or outside the Basin, without obtaining the Commission’s prior review and express approval in the form of a revised docket. Violation of this or any condition of this docket approval may result in enforcement, including the risk of financial penalties, pursuant to Section 14.17 of the Delaware River Basin Compact and Section 2.7.8 (18 CFR 401.98) of the Commission’s Rules of Practice and Procedure.
- 12.** The facility and operational records shall be available at all times for inspection by the DRBC.
- 13.** The facility shall be operated at all times to comply with the requirements of the Commission’s *WQR*.
- 14.** If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.
- 15.** Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.
- 16.** The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.
- 17.** No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).
- 18.** The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, to ensure proper control, use and management of the water resources of the Basin.
- 19.** The docket holder shall be subject to applicable DRBC regulatory program fees, in accordance with duly adopted DRBC resolutions and/or regulations (see 18 C.F.R. 401.43).
- 20.** This approval is transferable by request to the DRBC Executive Director provided that the project purpose and area served approved by the Commission in this docket will not be materially altered because of the change in project ownership. The request shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).

- 21.** The docket holder shall request a name change of the entity to which this approval is issued if the name of the entity to which this approval is issued changes its name. The request for name change shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).
- 22.** The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.
- 23.** Prior to allowing connections from any new service areas or any new developments not in compliance with the Ordinances described in Section B.1. above, the docket holder shall submit and have approved by the Executive Director of the DRBC a Non-Point Source Pollution Control Plan (NPSPCP) in accordance with Section 3.10.3.A.2.e.
- 24.** Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the *Rules of Practice and Procedure (RPP)*. In accordance with Section 15.1(p) of the *Delaware River Basin Compact*, cases and controversies arising under the *Compact* are reviewable in the United States district courts.

BY THE COMMISSION

APPROVAL DATE: March 4, 2026

EXPIRATION DATE: April 30, 2030