

BD- This DRAFT Docket has been prepared for the purposes of the scheduled public hearing and may be substantially modified as a result of the public hearing process prior to Commission action.

1/21/2025 8:45 AM

DOCKET NO. D-1966-096 CP-6

DELAWARE RIVER BASIN COMMISSION

**Brookhaven Borough
Wastewater Treatment Plant
Brookhaven Borough, Delaware County, Pennsylvania**

PROCEEDINGS

This docket is issued in response to an application submitted to the Delaware River Basin Commission (DRBC or Commission) on August 8, 2024 (Application), for renewal of the docket holder's existing wastewater treatment plant (WWTP) and its discharge. The Pennsylvania Department of Environmental Protection (PADEP) issued National Pollutant Discharge Elimination System (NPDES) Permit No. PA0023949 for this discharge.

The Application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Delaware County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on February 5, 2025.

A. DESCRIPTION

- Purpose.** The purpose of this docket is to renew the approval of the docket holder's existing 0.25 million gallons per day (mgd) WWTP and its discharge. The effluent limitations for Outfall 001 were determined using an effluent discharge rate of 0.192 mgd.
- Location.** The docket holder's WWTP is located to the east of the intersection of Brookhaven Road and Bridgewater Road in Brookhaven Borough, Delaware County, Pennsylvania. The WWTP will continue to discharge treated effluent to Chester Creek at River Mile 82.9 – 4.3 (Delaware River – Chester Creek).

The location of the WWTP outfall in the Chester Creek Watershed as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
001	39° 51' 44"	75° 23' 42"

Specific location information has been withheld for security reasons.

3. **Area Served.** The docket holder's WWTP will continue to serve most of Brookhaven Borough, Delaware County, Pennsylvania. For the purpose of defining the Area Served, the Type of Discharge and the Service Area sections from the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in Section C. DECISION of this docket.

4. **Design Criteria.** The docket holder's existing 0.25 mgd WWTP utilizes a Modified Ludzak-Ettinger (MLE) activated sludge treatment process. The WWTP is designed for an annual average flow of 0.192 mgd, and a hydraulic design capacity of 0.25 mgd.

5. **Facilities.** The WWTP facilities consist of an influent screen, an EQ tank, two (2) anoxic tanks, two (2) aeration tanks, two (2) clarifiers, a chlorine tank and a dichlorination tank.

The project facilities are located in the flood hazard area (FEMA-designated 100-year flood zone). The docket holder has flood-proofed up to the flood hazard protection elevation (one foot above 100-year flood elevation). The docket holder has accomplished this by raising the tops of the tanks above the flood protection elevation.

Wasted sludge will continue to be hauled off-site for disposal in accordance with the NPDES Permit No. PA0023949.

6. **Water Withdrawals.** The potable water supply in the project service area is owned and operated by the Chester Water Authority (CWA). The CWA water withdrawal is described in detail in Docket No. D-1984-055 CP-1, which was approved on August 2, 1989.

7. **NPDES Permit / DRBC Effluent Requirements.** NPDES Permit No. PA0023949 issued by the PADEP includes final effluent limitations for the project discharge of 0.25 mgd to surface waters classified by the PADEP as supporting Warm Water Fishes (WWF) and Migratory Fishes (MF). EFFLUENT TABLE C-1 included in Section C. DECISION Condition C.1. of this docket, contains effluent requirements for DRBC parameters that must be met as a condition of this approval.

8. **Relationship to the Comprehensive Plan.** The existing WWTP was added to the Comprehensive Plan by Docket No. D-1966-096 CP-1 on March 27, 1968. An application (D-1966-096 CP-2) for the approval of modifications to the WWTP (replacement and relocation of project outfall) was submitted to the DRBC on June 1, 1998, but the project was never approved by the Commission. The WWTP approval was renewed and/or modified by Docket Nos. D-1966-096 CP-3, D-1966-096 CP-4 and D-1966-096 CP-5 on March 3, 2010, December 9, 2015 and March 13, 2019, respectively. Issuance of this docket (D-1966-096 CP-6) will continue the WWTP in the Comprehensive Plan.

B. FINDINGS

The docket holder applied to renew approval of their existing 0.25 mgd WWTP and its discharge. No modifications to the WWTP are proposed.

Near the project site, Chester Creek has an estimated seven-day low flow with a recurrence interval of ten years (Q_{7-10}) of 10.5 mgd (16.3 cfs). The ratio of this low flow to the hydraulic design wastewater discharge from the 0.25 mgd WWTP is approximately 42 to 1.

There are no surface water intakes of record for public water supply located downstream of the docket holder's WWTP.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit conform with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge meeting the effluent requirements as set forth in the Commission's *Water Quality Regulations (WQR)*.

C. DECISION

Effective on the approval date for Docket No. D-1966-096 CP-6 below, the project described in Docket No. D-1966-096 CP-5 is removed from the Comprehensive Plan to the extent that it is not included in Docket No. D-1966-096 CP-6; Docket No. D-1966-096 CP-5 is terminated and replaced by Docket No. D-1966-096 CP-6; and the project and the appurtenant facilities described in Section A "DESCRIPTION" of this docket shall be continued in the Comprehensive Plan. The project and appurtenant facilities as described in Section A of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

Monitoring and Reporting

1. The docket holder shall comply with the requirements contained in the EFFLUENT TABLES below. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email aemr@drbc.gov on the **Annual Effluent Monitoring Report Form** located at this web address: <https://www.nj.gov/drbc/programs/project/docket-app-info.html#3>. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations. The following average monthly effluent limits are among those listed in the NPDES Permit and meet or are more stringent than the effluent requirements of the DRBC.

EFFLUENT TABLE C-1: DRBC Parameters Included in NPDES Permit

OUTFALL 001 (Discharge to Chester Creek)		
PARAMETER	LIMIT	MONITORING
pH (Standard Units)	6 to 9 at all times	As required by NPDES permit
Dissolved Oxygen	4.0 minimum	As required by NPDES permit
Total Suspended Solids	30 mg/l	As required by NPDES permit
Total Suspended Solids Influent	Monitor and Report	As required by NPDES permit
CBOD ₅ (at 20° C)	5/01-10/31 20 mg/l	As required by NPDES permit
	11/01-4/30 25 mg/l	
CBOD ₅ Influent	Monitor and Report	As required by NPDES permit
BOD ₅ Influent	Monitor and Report	As required by NPDES permit
Total Dissolved Solids*	Monitor and Report	As required by NPDES permit**
Total Nitrogen	Monitor and Report	As required by NPDES permit
Ammonia Nitrogen (5-1 to 10-31) (11-1 to 4-30)	5.0 mg/l	As required by NPDES permit
	15.0 mg/l	
Total Phosphorus (5-1 to 10-31) (11-1 to 4-30)	1.0 mg/l	As required by NPDES permit
	2.0 mg/l	
Fecal Coliform	200 colonies per 100 ml as a geo. avg.	As required by NPDES permit

* See DECISION Condition C.3.

Other Conditions

2. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.

3. The docket holder may request the Executive Director in writing the substitution of specific conductance for TDS. The request should include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow the substitution of specific conductance for TDS monitoring.

4. This approval shall expire on the expiration date set forth below unless prior thereto the docket holder has applied to the Commission to renew or extend this approval.

5. The docket holder is responsible for timely submittal to the DRBC of a docket renewal application on the appropriate application form including the appropriate docket application filing fee (see 18 C.F.R. 401.43) at least 6 months in advance of the docket expiration date set forth below. The docket holder will be subject to late filed renewal surcharges in the event of untimely submittal of its renewal application, whether DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. If a timely and complete

application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below, the terms and conditions of the current docket will remain fully effective and enforceable pending the grant or denial of the application for docket approval.

6. The docket holder is permitted to treat and discharge wastewater as set forth in the Area Served Section of this docket, which incorporates by reference the Type of Discharge and Service Area sections of the docket holder's Application to the extent consistent with all other conditions of this DECISION Section.

7. In accordance with the Commission's regulations at 18 C.F.R. Part 440, the docket holder is prohibited from discharging wastewater from high volume hydraulic fracturing ("HVHF") or HVHF-related activities to waters or land within the Basin. The docket holder is further prohibited from discharging hydraulic fracturing wastewater, whether treated or untreated, from sources within or outside the Basin, without obtaining the Commission's prior review and express approval in the form of a revised docket. Violation of this or any condition of this docket approval may result in enforcement, including the risk of financial penalties, pursuant to Section 14.17 of the *Delaware River Basin Compact* and Section 2.7.8 (18 CFR 401.98) of the Commission's *Rules of Practice and Procedure*. The facility and operational records shall be available at all times for inspection by the DRBC.

8. The facility and operational records shall be available at all times for inspection by the DRBC.

9. The facility shall be operated at all times to comply with the requirements of the Commission's *WQR*.

10. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.

11. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.

12. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.

13. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).

14. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, in order to ensure proper control, use and management of the water resources of the Basin.

15. The docket holder shall be subject to applicable DRBC regulatory program fees, in accordance with duly adopted DRBC resolutions and/or regulations (see 18 CFR 401.43).
16. This approval is transferable by request to the DRBC Executive Director provided that the project purpose and area served approved by the Commission in this docket will not be materially altered because of the change in project ownership. The request shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 CFR 401.43).
17. The docket holder shall request a name change of the entity to which this approval is issued if the name of the entity to which this approval is issued changes its name. The request for name change shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 CFR 401.43).
18. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.
19. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the *Rules of Practice and Procedure*. In accordance with Section 15.1(p) of the *Delaware River Basin Compact*, cases and controversies arising under the *Compact* are reviewable in the United States district courts.

BY THE COMMISSION

APPROVAL DATE:

EXPIRATION DATE: August 31, 2029