

**DOCKET NO. D-2004-021 CP-4**

**DELAWARE RIVER BASIN COMMISSION**

**Warminster Municipal Authority  
Warminster-NAWC Wastewater Treatment Plant  
Warminster Township, Bucks County, Pennsylvania**

**PROCEEDINGS**

This docket is issued in response to an application submitted to the Delaware River Basin Commission (DRBC or Commission) on November 16, 2022 (Application), for renewal of the docket holder's existing wastewater treatment plant (WWTP) and its discharge. The WWTP is currently being temporarily bypassed until more planned development projects are completed in the area. At this time, flow to the WWTP is too low for economical operation. The Pennsylvania Department of Environmental Protection (PADEP) issued National Pollutant Discharge Elimination System (NPDES) Permit No. PA0058742 for this discharge.

The application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Bucks County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on May 8, 2024.

**A. DESCRIPTION**

**1. Purpose.** The purpose of this docket is to renew approval of the docket holder's existing 1.2 million gallons per day (mgd) WWTP and its discharge. The WWTP is currently being temporarily bypassed until more planned development projects are completed in the area. At this time, flow to the WWTP is too low for economical operation.

**2. Location.** The docket holder's WWTP is located between Eagle Drive and Johnsville Boulevard in Warminster Township, Bucks County, Pennsylvania. The WWTP will continue to discharge treated effluent to the unnamed tributary (UNT) to Little Neshaminy Creek, at River

Mile 115.6 – 23.6 – 3.3 – 1.4 (Delaware River – Neshaminy Creek – Little Neshaminy Creek – UNT Little Neshaminy Creek).

The location of the WWTP outfall in the Neshaminy Creek Watershed is as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
001	40° 13' 1.00"	75° 4' 28.00"

3. **Area Served.** The docket holder's WWTP will continue to serve a portion of Warminster Township located in Bucks County, Pennsylvania. For the purpose of defining the Area Served, the Type of Discharge and the Service Area sections from the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in Section C. DECISION of this docket.

4. **Design Criteria.** The docket holder's 1.2 mgd WWTP utilizes a sequencing batch reactor (SBR) treatment process with Ultraviolet (UV) disinfection.

The docket holder's WWTP is currently off-line due to the facility's inability to meet flow efficiency need for the WWTP's capacity. Influent wastewater flows received by the NAWC WWTP average 10% of the WWTP's flow capacity, and its treatment is too inefficient to maintain its operation. Therefore, flows are diverted to the 8.18 mgd Log College WWTP, also maintained by the docket holder as described in Docket No. D-1988-067 CP.

5. **Facilities.** The WWTP facilities consist of a mechanical bar screen, aerated grit chamber, dual tank SBR system, effluent flow equalization, filtration, and UV disinfection. Aerobic digestion is followed by dewatering (centrifuge).

The project facilities are not located in the 100-year floodplain.

Wasted sludge will continue to be hauled off-site for disposal in accordance with the NPDES Permit No. PA0058742.

6. **Water Withdrawals.** The potable water supply in the project service area is provided by the docket holder's groundwater wells withdrawal described in Docket No. D-2000-019 CP-3, approved on March 9, 2022. Additionally, potable water supply within the service area is provided by North Wales Water Authority as described in Docket No. D-1990-006 CP-4, approved on September 9, 2021.

7. **NPDES Permit / DRBC Effluent Requirements.** NPDES Permit No. PA0058742 issued by the PADEP includes final effluent limitations for the project discharge to surface waters classified by the PADEP as supporting warm water fishes and migratory fishes (WWF-MF) EFFLUENT TABLE C-1 included in Section C. DECISION condition C.1. of this docket, contains effluent requirements for DRBC parameters that must be met as a condition of this approval. Effluent requirements for Outfall No. 001 are based on a discharge rate of 1.2 mgd.

8. **Relationship to the Comprehensive Plan.** The existing WWTP was included in the Comprehensive Plan by Docket No. D-2004-021 CP on June 2, 2004. The WWTP approval was renewed by Docket Nos. D-2004-021 CP-2 and D-2004-021 CP-3, on September 13, 2013, and December 11, 2019, respectively. Issuance of this docket will continue the WWTP and its discharge in the Comprehensive Plan.

## B. **FINDINGS**

The docket holder applied to renew approval of their existing 1.2 mgd WWTP and its discharge. The WWTP is currently being temporarily bypassed until more planned development projects are completed in the area. At this time, flow to the WWTP is too low for economical operation. PADEP issued an updated approval of the docket holder's Act 537 Planning for the diversion in May 2019. During the period that the facility is off-line, flows are diverted to Log College WWTP. The docket holder has requested continuance of the approval to treat and discharge for future operations as more facilities in the service area come online or inflows become more consistent.

At the WWTP discharge location, the UNT to Little Neshaminy has an estimated seven-day low flow with a recurrence interval of ten years ( $Q_{7-10}$ ) of less than 0.1 cubic feet per second (cfs) and therefore is classified by the Commission as an intermittent stream.

The nearest surface water intake of record for public water supply is located on the Neshaminy Creek approximately 18 River Miles downstream of the docket holder's WWTP and is operated by Aqua Pennsylvania.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit conform with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge that meets the effluent requirements as set forth in the Commission's *Water Quality Regulations (WQR)*.

## C. **DECISION**

Effective on the approval date for Docket No. D-2004-021 CP-4 below, the project described in Docket No. D-2004-021 CP-3 is removed from the Comprehensive Plan to the extent that it is not included in Docket No. D-2004-021 CP-4; Docket No. D-2004-021 CP-3 is terminated and replaced by Docket No. D-2004-021 CP-4; and the project and the appurtenant facilities described in Section A "DESCRIPTION" of this docket shall be included in the Comprehensive Plan. The project and appurtenant facilities as described in Section A of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

### **Monitoring and Reporting**

1. The docket holder shall comply with the requirements contained in the EFFLUENT TABLE below. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email [aemr@drbc.gov](mailto:aemr@drbc.gov) on the **Annual Effluent Monitoring Report Form** located at this web address: <https://www.nj.gov/drbc/programs/project/docket-app-info.html#3>. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations. The following average monthly effluent limits are among those listed in the NPDES Permit and meet or are more stringent than the effluent requirements of the DRBC.

**EFFLUENT TABLE C-1: DRBC Parameters Included in NPDES Permit**

<b>OUTFALL 001 (Discharge to unnamed tributary of Neshaminy Creek)</b>		
<b>PARAMETER</b>	<b>LIMIT</b>	<b>MONITORING</b>
pH (Standard Units)	6 to 9 at all times	As required by NPDES Permit
Total Suspended Solids	10 mg/l	As required by NPDES Permit
BOD <sub>5</sub> (at 20° C) Influent	Monitor & Report	As required by NPDES Permit
CBOD <sub>5</sub> (at 20° C)	10 mg/l 85% Minimum Removal	As required by NPDES Permit
Ammonia Nitrogen (5-1 to 10-31) (11-1 to 4-30)	1.5 mg/l 3.0 mg/l	As required by NPDES Permit
Fecal Coliform	200 colonies per 100 ml as a geo. avg.	As required by NPDES Permit
Total Dissolved Solids*	1,000 mg/l *	As required by NPDES Permit

\* See Section C. DECISION Condition C.4.

### **Other Conditions**

2. Within 30 days of the date that the project has been placed on-line, the docket holder shall notify the DRBC of the starting date and scheduled completion date. Within 30 days of the date of project completion, the docket holder shall notify the DRBC of the facility's start up.

3. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.

4. The docket holder may request in writing, for approval from the Executive Director for the substitution of specific conductance for TDS. The request should include information that

supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow the substitution of specific conductance for TDS monitoring.

5. Section 2.3.10 of the Commission's *Rules of Practice and Procedure (RPP)* (18 C.F.R. 401.41), limiting the Commission's approval to three years in the absence of an expenditure of substantial funds by the project sponsor in reliance on the approval, is hereby waived for good cause shown in accordance with Section 2.9.3 (18 C.F.R. 401.123) of the same regulations. This approval shall expire on the expiration date set forth below unless prior thereto the docket holder has applied to the Commission to renew or extend this approval.

6. The docket holder is responsible for timely submittal to the DRBC of a docket renewal application on the appropriate application form including the appropriate docket application filing fee (see 18 C.F.R. 401.43) at least 6 months in advance of the docket expiration date set forth below. The docket holder will be subject to late filed renewal surcharges in the event of untimely submittal of its renewal application, whether DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. If a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below, the terms and conditions of the current docket will remain fully effective and enforceable pending the grant or denial of the application for docket approval.

7. The docket holder is permitted to treat and discharge wastewater as set forth in the Area Served Section of this docket, which incorporates by reference the Type of Discharge and Service Area sections of the docket holder's Application to the extent consistent with all other conditions of this section. Any expansion beyond that included in Section A.3. Area Served is subject to DRBC review and approval in accordance with Section 3.8 of the Compact.

8. In accordance with the Commission's regulations at 18 C.F.R. Part 440, the docket holder is prohibited from discharging wastewater from high volume hydraulic fracturing ("HVHF") or HVHF-related activities to waters or land within the Basin. The docket holder is further prohibited from discharging hydraulic fracturing wastewater, whether treated or untreated, from sources within or outside the Basin, without obtaining the Commission's prior review and express approval in the form of a revised docket. Violation of this or any condition of this docket approval may result in enforcement, including the risk of financial penalties, pursuant to Section 14.17 of the Delaware River Basin Compact and Section 2.7.8 (18 CFR 401.98) of the Commission's Rules of Practice and Procedure.

9. The facility and operational records shall be available at all times for inspection by the DRBC.

10. The facility shall be operated at all times to comply with the requirements of the Commission's *WQR*.

11. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.

12. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.
13. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.
14. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).
15. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, to ensure proper control, use and management of the water resources of the Basin.
16. The docket holder shall be subject to applicable DRBC regulatory program fees, in accordance with duly adopted DRBC resolutions and/or regulations (see 18 C.F.R. 401.43).
17. This approval is transferable by request to the DRBC Executive Director provided that the project purpose and area served approved by the Commission in this docket will not be materially altered because of the change in project ownership. The request shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).
18. The docket holder shall request a name change of the entity to which this approval is issued if the name of the entity to which this approval is issued changes its name. The request for name change shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).
19. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.
20. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the *Rules of Practice and Procedure (RPP)*. In accordance with Section 15.1(p) of the *Delaware River Basin Compact*, cases and controversies arising under the *Compact* are reviewable in the United States district courts.

**BY THE COMMISSION**

**APPROVAL DATE:**

**EXPIRATION DATE:      October 31, 2032**