

**DOCKET NO. D-1975-093 CP-7**

**DELAWARE RIVER BASIN COMMISSION**

**Discharge to a Tributary of Special Protection Waters  
Tamiment Resort Wastewater Treatment Plant  
Lehman Township, Pike County, Pennsylvania**

**PROCEEDINGS**

This docket is issued in response to an application submitted to the Delaware River Basin Commission (DRBC or Commission) on October 24, 2025 (Application), to renew the approval of the docket holder's existing wastewater treatment plant (WWTP) and its discharge. The Pennsylvania Department of Environmental Protection (PADEP) issued National Pollutant Discharge Elimination System (NPDES) Permit No. PA0037290 for this discharge.

The application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Pike County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on May 6, 2026.

**A. DESCRIPTION**

- 1. Purpose.** The purpose of this docket is to renew the approval of the docket holder's existing 0.25 million gallons per day (mgd) WWTP and its surface water discharge and spray irrigation land discharge.
- 2. Location.** The docket holder's WWTP is located at Lake Drive in Lehman Township, Pike County, Pennsylvania at the Tamiment Resort and Country Club. When WWTP effluent is not spray applied to Tamiment Resort and Country Club grounds, it is discharged to an unnamed tributary to Little Bush Kill, which is a tributary to Bush Kill, at River Mile 226.9 – 0.8 - 1.5 - 1.85 (Delaware River – Bush Kill– Little Bush Kill – UNT Little Bush Kill) via Outfall No. 100. Outfall No. 100 is located just downstream of a lake named First Pond (locally known as Pond Run Creek) which is downstream from two (2) other impoundments located directly in-line on the unnamed tributary to Little Bush Kill. Outfall No. 001 is approximately two (2) miles upstream of the boundary of the Delaware Water Gap National Recreation area. The WWTP discharge is located in the drainage area to the section of the non-tidal Delaware River known as the Middle Delaware, which is classified as Special Protection Waters (SPW).

The location of the WWTP outfall is as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
001	41° 7' 52"	75° 1' 35"

3. **Area Served.** The docket holder's WWTP will continue to serve Tamiment Resort and Country Club, as well as the adjacent Mountain Laurel Center for the Performing Arts, in Lehman Township, Pike County, Pennsylvania. For the purpose of defining the Area Served, the Type of Discharge and the Service Area sections from the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in Section C. DECISION of this docket.

4. **Design Criteria.** The docket holder's 0.25 mgd WWTP utilizes an extended aeration treatment process with an anoxic zone and filtration. During suitable weather conditions, effluent from the WWTP is land discharged. When weather conditions are unsuitable, effluent is discharged to an unnamed tributary to Little Bush Kill. The WWTP uses chlorine as its disinfection treatment process.

5. **Facilities.** The WWTP facilities consist of a comminutor and bypass bar screen, two (2) equalization tanks, a flow splitter box, five (5) extended aeration tanks with anoxic zones, five (5) final clarifiers, a flash mixing unit for alum and soda ash addition, a flocculation tank, two (2) high rate effluent filtration beds, and a chlorine contact tank which includes a post aeration chamber. During suitable weather conditions, treated WWTP effluent is pumped to a six-foot deep, lined, aerated holding pond located between the 8th and 17th greens of the Tamiment Golf Course for irrigation use, as needed. When conditions are unsuitable for spray irrigation, treated WWTP effluent is discharged to Tributary of Little Bush Kill.

A maximum spray irrigation application rate of 1.5 inches/acre/week on the approximate 110 -acre golf course site was approved by PADEP in its Water Management Permit (Part II) No. 5200401.

The docket holder's WWTP discharges to waters classified as SPW and is required to have available standby power. The existing WWTP has a generator installed capable of providing standby power.

The docket holder's WWTP is not staffed 24 hours per day and shall have a remote alarm system that continuously monitors plant operations in accordance with the Commission's SPW requirements. The existing WWTP has a diesel-powered permanent generator with automatic transfer switch installed that continuously monitors plant operations.

The docket holder has prepared and implemented an emergency management plan (EMP) for the existing WWTP in accordance with Commission SPW requirements.

The project facilities are not located in the 100-year floodplain.

Wasted sludge will continue to be hauled off-site for disposal in accordance with the NPDES Permit No. PA0037290.

6. **Water Withdrawals.** The potable water supply in the project service area is provided by ground water wells owned and operated by the docket holder. The docket holder's water withdrawal is described in detail in Docket No. D-1989-033 CP-4, which was approved on June 15, 2016.
7. **NPDES Permit / DRBC Effluent Requirements.** NPDES Permit No. PA0037290 issued by the PADEP includes final effluent limitations for the project discharge to surface waters classified by the PADEP as supporting high quality, migratory fishes, cold water fishes (HQ-MF, CWF). EFFLUENT TABLE C-1 included in Section C. DECISION condition C.1. of this docket, contains effluent requirements for DRBC parameters that must be met as a condition of this approval. Effluent requirements for Outfall No. 001 are based on a discharge rate of 0.25 mgd.
8. **Relationship to the Comprehensive Plan.** The existing WWTP was included in the Comprehensive Plan via Docket No. D-1975-093 CP-1 on July 23, 1975, which approved an upgrade and expansion to the WWTP; however, the upgrade and expansion project approved by D-1975-093 CP-1 was never constructed. Docket No. D-1975-093 CP (Rev) replaced Docket No. D-1975-093 CP-1 on April 20, 1983 and added the WWTP to the Comprehensive Plan. Docket Nos. D-1975-093 CP-3, D-1975-093 CP-4, and D-1975-093 CP-5 modified/renewed the WWTP on December 7, 2005, December 8, 2010, and March 16, 2016, respectively. Issuance of this docket will continue the WWTP and its discharge in the Comprehensive Plan.

## B. FINDINGS

The docket holder applied to renew the approval of the docket holder's existing 0.25 million gallons per day (mgd) WWTP and its surface water discharge and spray irrigation land discharge.

### 1. Special Protection Waters

In 1992, the DRBC adopted SPW requirements, as part of the DRBC *Water Quality Regulations (WQR)*, designed to protect existing water quality in applicable areas of the Delaware River Basin. One hundred twenty miles of the Delaware River from Hancock, New York downstream to the Delaware Water Gap has been classified by the DRBC as SPW. This stretch includes the sections of the river federally designated as "Wild and Scenic" in 1978 -- the Upper Delaware Scenic and Recreational River and the Delaware Water Gap National Recreation Area - - as well as an eight-mile reach between Milrift and Milford, Pennsylvania which is not federally designated. The SPW regulations apply to this 120-mile stretch of the river and its drainage area.

On July 16, 2008, the DRBC approved amendments to its *WQR* that provide increased protection for waters that the Commission classifies as SPW. The portion of the Delaware River and its tributaries within the boundary of the Lower Delaware River Management Plan Area was

approved for SPW designation and clarity on definitions and terms were updated for the entire program.

The docket holder's WWTP discharges to the drainage area to the Middle Delaware SPW. The docket holder's WWTP discharge is required to comply with the SPW requirements, as outlined in Article 3.10.3A.2. of the *WQR*.

Article 3.10.3A.2.e.1). and 2). of the Commission's *WQR* states that projects subject to review under Section 3.8 of the Compact that are located in the drainage area of SPW must submit for approval a Non-Point Source Pollution Control Plan (NPSPCP) that controls the new or increased non-point source loads generated within the portion of the docket holder's service area which is also located within the drainage area of SPW. The service area of the docket holder is located in the drainage area to the SPW. Since this project does not entail additional construction or expansion of facilities and service area and there are no new or increased non-point source loads associated with this approval, the NPSPCP requirement is not applicable at this time. Accordingly, Section C. DECISION condition C.2. has been included in this docket.

Lehman Township is regulated by the PADEP as a Stormwater Phase II municipality and is permitted by PADEP as such. Lehman Township adopted and implemented a stormwater ordinance in accordance with the PADEP requirements. The PADEP Stormwater Phase II requirements satisfy the NPSPCP requirements of the Commission.

As noted above in A.3. the docket holder's area served is located entirely in Lehman Township. This Township has enacted and is actively implementing non-point source/stormwater control ordinances adopting Stormwater Management Ordinance No. 104. Compliance with the Stormwater Management Ordinance No. 104, approved on October 6, 2005 and updated on April 2, 2008, generally meet the requirements of Article 3.10.3.A.2.e.1 of the Commission's Water Quality Regulations for the Area Served as described in A.3. above within Lehman Township. Prior to allowing connections from any new service areas or any new developments not in compliance with these Ordinances the docket holder shall submit and have approved by the Executive Director of the DRBC a Non-Point Source Pollution Control Plan (NPSPCP) in accordance with Section 3.10.3.A.2.e.

## **2. Other**

At the WWTP discharge location, the unnamed tributary to Bush Kill has an estimated seven-day low flow with a recurrence interval of ten years ( $Q_{7-10}$ ) of less than 0.1 cubic feet per second (cfs) and therefore is classified by the Commission as an intermittent stream.

The nearest surface water intake of record for public water supply is located on the Delaware River approximately 46 River Miles downstream of the docket holder's WWTP and is operated by City of Easton.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit conform with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge that meets the effluent requirements as set forth in the Commission's *Water Quality Regulations (WQR)*.

### C. DECISION

Effective on the approval date for Docket No. D-1975-093 CP-7 below, the project described in Docket No. D-1973-093 CP-6 is removed from the Comprehensive Plan to the extent that it is not included in Docket No. D-1975-093 CP-7; Docket No. D-1973-093 CP-6 is terminated and replaced by Docket No. D-1975-093 CP-7; and the project and the appurtenant facilities described in Section A "DESCRIPTION" of this docket shall be included in the Comprehensive Plan. The project and appurtenant facilities as described in Section A of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

#### Monitoring and Reporting

1. The docket holder shall comply with the requirements contained in the EFFLUENT TABLE below. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email [aemr@drbc.gov](mailto:aemr@drbc.gov) on the **Annual Effluent Monitoring Report Form** located at this web address: <https://www.nj.gov/drbc/programs/project/docket-app-info.html#3>. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations. The following average monthly effluent limits are among those listed in the NPDES Permit and meet or are more stringent than the effluent requirements of the DRBC.

**EFFLUENT TABLE C-1: DRBC Parameters Included in NPDES Permit**

<b>OUTFALL 001 (Discharge to UNT to Little Bush Kill)</b>		
<b>PARAMETER</b>	<b>LIMIT</b>	<b>MONITORING</b>
pH (Standard Units)	6 to 9 at all times	As required by NPDES Permit
Total Suspended Solids	30 mg/l	As required by NPDES Permit
Dissolved Oxygen	7.0mg/l (minimum at all times)	As required by NPDES Permit
CBOD <sub>5</sub> (at 20° C)	10 mg/l (85% Minimum Removal)	As required by NPDES Permit

OUTFALL 001 (Discharge to UNT to Little Bush Kill)		
PARAMETER	LIMIT	MONITORING
Ammonia Nitrogen (5-1 to 10-31) (11-1 to 4-30)	2.0 mg/l 6.0 mg/l	As required by NPDES Permit
Fecal Coliform (5-1 to 9-30) (10-1 to 4-30)	200 colonies per 100 ml as a geo. avg. 2000 colonies per 100 ml as a geo. avg.	As required by NPDES Permit
Phosphorus	1.0 mg/l	As required by NPDES Permit
Total Dissolved Solids	1,000 mg/l *	As required by NPDES Permit
CBOD <sub>5</sub> (at 20° C) Influent	Monitor & Report	As required by NPDES Permit
Total Kjeldahl Nitrogen	Monitor & Report	As required by NPDES Permit

\* See DECISION Condition C.5.

### **Other Conditions**

2. Prior to allowing connections from any new service areas or any new developments, the docket holder shall either submit and have approved by the Executive Director of the DRBC a NPSPCP in accordance with Section 3.10.3.A.2.e. or receive written confirmation from the Executive Director of the DRBC that the new service area complies with a DRBC-approved NPSPCP.

3. Prior to the docket holder initiating any substantial alterations or additions to the existing WWTP as defined in Section 3.10.3A.2.a.16) of the Commission's *WQR*, an application must be submitted and approved by the Commission. Such an application shall be submitted prior to final design to ensure that the Commission can provide the docket holder with draft effluent limitations for SPW specific parameters as guidance for design as to not require duplication of work or cause a substantial expenditure of public funds without Commission approval. The docket holder is encouraged to contact the Commission staff during the planning stages to identify the potential effluent limitations required to meet the no measurable change parameters under SPW.

4. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.

5. The docket holder may request permission from the Executive Director to perform specific conductance monitoring in lieu of TDS monitoring. The request shall be made in writing and shall include information that supports the effluent specific correlation between TDS and specific

conductance. Upon review, the Executive Director may modify the docket to allow specific conductance monitoring in lieu of TDS monitoring.

6. In accordance with 18 C.F.R. 401.8. of the Commission's *Rules of Practice and Procedure (RPP)*, if at any future time the Project is changed materially from the Project as described in this docket, it will be deemed to constitute a new and different project for the purposes of Article 11 of the Delaware River Basin Compact and will require Commission amendment of the Comprehensive Plan. In accordance with the same section of the *RPP*, whenever a change to the Project is made, the sponsor must advise the Executive Director, who will determine whether the change is deemed material for purposes of this provision.

7. This approval shall expire on the expiration date set forth below unless prior thereto the docket holder has applied to the Commission to renew or extend this approval.

8. The docket holder is responsible for timely submittal to the DRBC of a docket renewal application on the appropriate application form including the appropriate docket application filing fee (see 18 C.F.R. 401.43) at least 6 months in advance of the docket expiration date set forth below. The docket holder will be subject to late filed renewal surcharges in the event of untimely submittal of its renewal application, whether DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. If a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below, the terms and conditions of the current docket will remain fully effective and enforceable pending the grant or denial of the application for docket approval.

9. The docket holder is permitted to treat and discharge wastewater as set forth in the Area Served Section of this docket, which incorporates by reference the Type of Discharge and Service Area sections of the docket holder's Application to the extent consistent with all other conditions of this section. Any expansion beyond that included in Section A.3. Area Served is subject to DRBC review and approval in accordance with Section 3.8 of the Compact.

10. In accordance with the Commission's regulations at 18 C.F.R. Part 440, the docket holder is prohibited from discharging wastewater from high volume hydraulic fracturing ("HVHF") or HVHF-related activities to waters or land within the Basin. Violation of this or any condition of this docket approval may result in enforcement, including the risk of financial penalties, pursuant to Section 14.17 of the Delaware River Basin Compact and Section 2.7.8 (18 CFR 401.98) of the Commission's Rules of Practice and Procedure.

11. The facility and operational records shall be available at all times for inspection by the DRBC.

12. The facility shall be operated at all times to comply with the requirements of the Commission's *WQR*.

13. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.

- 14.** Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.
- 15.** The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.
- 16.** No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).
- 17.** The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, to ensure proper control, use and management of the water resources of the Basin.
- 18.** The docket holder shall be subject to applicable DRBC regulatory program fees, in accordance with duly adopted DRBC resolutions and/or regulations (see 18 C.F.R. 401.43).
- 19.** This approval is transferable by request to the DRBC Executive Director provided that the project purpose and area served approved by the Commission in this docket will not be materially altered because of the change in project ownership. The request shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).
- 20.** The docket holder shall request a name change if the name of the entity to which this approval is issued changes its name. The request for name change shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).
- 21.** The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.
- 22.** Prior to allowing connections from any new service areas or any new developments not in compliance with the Ordinances described in Section B.1. above, the docket holder shall submit and have approved by the Executive Director of the DRBC a Non-Point Source Pollution Control Plan (NPSPCP) in accordance with Section 3.10.3.A.2.e. of the *WQR*.
- 23.** Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the *Rules of Practice and Procedure (RPP)*. In accordance with Section 15.1(p) of the *Delaware River Basin Compact*, cases and controversies arising under the *Compact* are reviewable in the United States district courts.

**BY THE COMMISSION**

**APPROVAL DATE:            June 11, 2026**

**EXPIRATION DATE: May 31, 2030**