

DOCKET NO. D-2006-008-3

DELAWARE RIVER BASIN COMMISSION

Located in Drainage Area to Special Protection Waters

Green Walk Trout Hatchery, Inc.

Groundwater Withdrawal

Washington Township, Northampton County, Pennsylvania

PROCEEDINGS

This docket is issued in response to an Application submitted to the Delaware River Basin Commission (DRBC or Commission) on April 13, 2026 for renewal of an allocation of groundwater and review of a groundwater withdrawal project (Application).

The Application was reviewed for approval under Section 3.8 and for a withdrawal permit under Section 10.3 *Delaware River Basin Compact*. The Lehigh Valley Planning Commission has been notified of pending action on this docket. A public hearing on this project was held by the DRBC on August 5, 2026.

A. DESCRIPTION

1. **Purpose.** The purpose of this project is to renew the approval of an existing groundwater withdrawal of up to 13.392 million gallons per month (mgm) of groundwater to supply the docket holder's commercial trout hatchery from existing Wells W-2, W-5 and W-6.

2. **Location.** The project wells are screened in the unconsolidated deposits overlying the Martinsburg Formation. The project is located in the Delaware River Watershed, within the drainage area to the Lower Delaware Special Protection Waters, in Washington Township, Northampton County, Pennsylvania.

Specific location information has been withheld for security reasons.

3. **Area Served.** The wells are only used to supply water to the docket holder's trout hatchery. For the purpose of defining Area Served, the Application is incorporated herein by reference consistent with conditions contained in Section C. DECISION of this docket.

4. **Design Criteria.** The docket holder operates the on-site wells to supply water to their commercial trout hatchery. Groundwater withdrawals are piped into various hatchery structures, which drain into Greenwalk Creek. Greenwalk Creek flows directly through the trout raceway systems, with no surface water diversions from the creek or raceway systems. Greenwalk Creek is naturally supplemented by a series of springs and seeps located on the property, as well as the on-site wells.

Wells W-2, W-5 and W-6 provide cold, highly oxygenated water which is essential in raising trout from egg to adult. Well W-2 is the primary source to the trout hatchery. Well W-6 supplies water to the eastern portions of the raceway system as well as for the production of trout fry. Well W-5 is an emergency back-up source for the trout hatchery. The hatchery's water demands vary depending upon hydrological conditions as well as the changing needs of trout in various life stages. In circumstances necessitating all three (3) wells to operate concurrently, the combined withdrawal rate averages 300 gallons per minute (gpm). Withdrawals by the docket holder are non-consumptive and are discharged entirely back to Greenwalk Creek.

The average and maximum demand is 0.393 million gallons per day (mgd) and 0.432 mgd, respectively. The docket holder estimates no increase in demand over the next 10 years. The allocation of 13.392 mgm should be sufficient to meet the future demands of the docket holder's commercial trout hatchery.

5. **Facilities.** The existing project wells have the following characteristics:

WELL NO.	DEPTH (FEET)	CASED DEPTH/ CASING DIAMETER	PUMP CAPACITY (GPM)	YEAR DRILLED
W-2	63	53' / 6"	150	1970
W-5	63	53' / 6"	100	1970
W-6	63	53' / 6"	160	1970

All three wells are screened from 53 to 63 feet.

All wells are metered.

Prior to entering the distribution system, the water is not treated.

The project facilities are above the 100-year flood elevation.

The irrigation system is presently not interconnected with any other distribution system.

6. **Other.** Discharge water from the hatchery is conveyed to Greenwalk Creek. The PADEP does not require a National Pollutant Discharge Elimination System (NPDES) permit for this discharge.

B. FINDINGS

1. Special Protection Waters

In 1992, the DRBC amended its *Water Quality Regulations (WQR)* by the addition of regulations for the protection of Special Protection Waters (SPW), designed to maintain the quality of interstate waters where existing quality is better than the established stream quality objectives. As the result of its initial classifications and subsequent amendments, the Commission has designated the entire non-tidal main stem Delaware River from Hancock, New York to Trenton, New Jersey as SPW. DRBC's SPW regulations apply within the designated reaches and their drainage area.

The well providing water supply to the docket holder is located within the drainage area to SPW. Sections 3.10.3A.2.e.1) and 2) of the *WQR* state that projects subject to review under Section 3.8 of the *Compact* that are located within the drainage area of SPW must submit for approval a Non-Point Source Pollution Control Plan (NPSPCP) that controls the new or increased non-point source loads generated within the portion of the docket holder's service area which is also located within the drainage area of SPW.

Since this project involves the renewal of an approval for existing activities and does not entail additional construction or expansion of facilities or create new or increased non-point source loads, the NPSPCP requirement is not applicable at this time. Condition C.21. of this docket provides that at such time, if ever, as additions to the area served by the docket holder's withdrawals are proposed, the docket holder will be required to demonstrate compliance with an approved NPSPCP in accordance with DRBC's SPW regulations.

2. Other Findings

The DRBC estimates that the project withdrawals, used for the purpose of commercial trout hatchery supply, result in negligible consumptive use. The DRBC definition of consumptive use is defined in Article 5.5.1.D. of the *Administrative Manual – Part III – Basin Regulations – Water Supply Charges*.

The project is designed to conform to the requirements of the *Water Code (WC)* and *Water Quality Regulations* of the DRBC.

The project as approved herein does not impair or conflict with the Comprehensive Plan.

C. DECISION

Effective on the approval date for Docket No. D-2006-008-3 below, Docket No. D-2006-008-2 is terminated and replaced by Docket No. D-2006-008-3. The project and appurtenant facilities as described in Section A.4. (Design Criteria) and A.5. (Facilities) are approved subject to the following conditions, pursuant to Section 3.8 of the *Compact*:

Monitoring and Reporting

1. The docket holder shall continue to report to the PADEP all surface and groundwater sources described in this docket in accordance with the Pennsylvania Regulations (Title 25 - Environmental Protection, [25 PA. CODE CH. 110], Water Resources Planning).

2. The project withdrawals shall be metered by means of an automatic continuous recording device, flow meter, or other method, and shall be measured to within 5 percent of actual flow. Meters or other methods of measurement shall be subject to approval and inspection by the PADEP as to the type, method, installation, maintenance, calibration, reading and accuracy. A record of daily withdrawals shall be maintained, and monthly totals shall be reported to the PADEP annually and shall be available at any time to the Commission if requested by the Executive Director.

3. The docket holder shall implement to the satisfaction of the PADEP, a continuous program to encourage water conservation in all types of use within the facilities served by this docket approval. The docket holder will report to the PADEP, on the actions taken pursuant to this program and the impact of those actions as requested by the PADEP.

Other Conditions

4. During any month, the combined withdrawal from all well sources shall not exceed 13.392 million gallons. No well shall be pumped above the maximum rate and monthly allocation as indicated below:

WELL NO.	MAXIMUM RATE (GPM)*	MONTHLY ALLOCATION (MGM)
W-2	150	6.696
W-5	100	4.464
W-6	160	8.928

* Based on a 24-Hour Average

5. This approval shall expire on the expiration date set forth below unless prior thereto the docket holder has applied to the Commission to renew or extend this approval.

6. The docket holder is responsible for timely submittal to the DRBC of a docket renewal application on the appropriate application form including the appropriate docket application filing fee (see 18 C.F.R. 401.43) at least 6 months in advance of the docket expiration date set forth below. The docket holder will be subject to late filed renewal surcharges in the event of untimely submittal of its renewal application, whether or not DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. If the docket holder has not applied to renew the docket or the DRBC is unable to reissue the docket before the expiration date below, the terms and conditions of the current docket will remain fully effective and enforceable pending the renewal of the docket.

7. The wells and operational records shall be available at all times for inspection by the DRBC.

8. The wells shall be operated at all times to comply with the requirements of the *WC* and *WQR* of the DRBC.

9. The wells shall be equipped with readily accessible capped ports and minimum ½ inch inner diameter (ID) drop pipes so that water levels may be measured under all conditions.

10. Each new water service connection shall include a water meter in accordance with the DRBC's Resolution No. 87-7 (Revised).

11. No water service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).

12. The docket holder shall implement to the satisfaction of the PADEP, a drought or other water supply emergency plan.

13. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.

14. The docket holder is permitted to provide the water approved in this docket to the areas included in Section A.3. Area Served of this docket. Any expansion beyond those included in Section A.3. Area Served is subject to DRBC review and approval in accordance with Section 3.8 of the *Compact*.

15. The docket holder shall be subject to applicable DRBC regulatory program fees, in accordance with duly adopted DRBC resolutions and/or regulations. (see 18 C.F.R. 401.43).

16. This approval is transferable by request to the DRBC Executive Director provided that the project purpose and area served approved by the Commission in this docket will not be materially altered because of the change in project ownership. The request shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).

17. The docket holder shall request a name change if the name of the entity to which this approval is issued changes its name. The request for name change shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).

18. The issuance of this docket approval shall not create any private or proprietary rights in the water of the Basin, and the Commission reserves the rights to amend, alter or rescind any actions taken hereunder to ensure the proper control, use and management of the water resources of the Basin.

19. If the monitoring required herein or any other relevant data or information demonstrates that the operation of this project is interfering with or otherwise impairing existing uses of ground or surface water, or if the docket holder receives a complaint from an existing ground or surface water user within the zone of influence of the withdrawal alleging such interference or impairment, the permit holder shall immediately notify the Executive Director, and unless excused by the Executive Director, shall investigate the demonstrated or alleged impacts. For purposes of this condition, notification shall mean either (a) electronic transmittal of written notice to the Executive Director via email (using addresses posted on the DRBC website); or (b) written notice to the Executive Director and a telephone call to the Project Review Section at 609-883-9500, ext. 216. (Oral notification must always be accompanied by immediate written notification directed to the Executive Director.) In addition, the docket holder shall provide written notice to all potentially affected water users of the docket holder's responsibilities under this condition. **Any well or surface water supply that is impaired as a result of the docket holder's project withdrawal shall be repaired, replaced or mitigated at the docket holder's expense.** The scope of the options to consider for repair, replacement and/or mitigation shall not be limited solely to those that are owned, operated, or controlled by the project sponsor. An investigation report and/or mitigation plan prepared and certified by a licensed professional engineer and/or a licensed professional geologist shall be submitted to the Executive Director as soon as practicable following notice of the demonstrated or alleged impairment consistent with this paragraph. The Executive Director shall make the final determination regarding the scope and sufficiency of the investigation and the extent of any mitigation measures that may be required. Where ground and surface waters are rendered unavailable, unusable, or unsuitable for the pre-existing use, the Executive Director may direct the docket holder to take interim actions to mitigate such impacts, pending completion of the investigative report and any long-term repair, replacement or mitigation.

20. Prior to allowing connections from any new service areas or any new developments, the docket holder shall either submit and have approved by the Executive Director of the DRBC a Non-Point Source Pollution Control Plan (NPSPCP) in accordance with Section 3.10.3.A.2.e or receive written confirmation from the Executive Director of the DRBC that the new service area complies with a DRBC approved NPSPCP.

21. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.

22. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the *Rules of Practice and Procedure*. In accordance with Section 15.1(p) of the *Delaware River Basin Compact*, cases and controversies arising under the *Compact* are reviewable in the United States district courts.

BY THE COMMISSION

APPROVAL DATE: September 2, 2026

EXPIRATION DATE: September 2, 2036