

7/21/2025 10:37 AM

**DOCKET NO. D-1987-045 CP-7**

**DELAWARE RIVER BASIN COMMISSION**

**Antietam Valley Municipal Authority  
Wastewater Treatment Plant  
St. Lawrence Borough, Berks County, Pennsylvania**

**PROCEEDINGS**

This docket is issued in response to an application submitted to the Delaware River Basin Commission (DRBC or Commission) by Entech Engineering, Inc. on behalf of the docket holder on May 24, 2024 (Application) for renewal of the docket holder's existing wastewater treatment plant (WWTP) and its discharge. The Pennsylvania Department of Environmental Protection (PADEP) issued National Pollutant Discharge Elimination System (NPDES) Permit No. PA0026646 for this discharge. The PADEP issued Water Quality Management (WQM) Permit No. 667S059 for proposed upgrades to the facility.

The application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Berks County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on August 6, 2025.

**A. DESCRIPTION**

1. **Purpose.** The purpose of this docket is to renew approval of the docket holder's existing 1.225 million gallons per day (mgd) WWTP and its discharge. The docket also approves proposed upgrades consisting of converting an existing anaerobic digester to an aerobic digester, upgrading aeration and mixing systems of existing aerobic digester, blowers and diffusers, replacing RAS and WAS pumps and adding one standby pump, and installing one digester decant pump.

2. **Location.** The docket holder's WWTP is located at Butter Lane in St. Lawrence Borough, Berks County, Pennsylvania. The WWTP will continue to discharge treated effluent to Antietam Creek, a tributary of the Schuylkill River, at River Mile 92.47 - 66.1 - 4.4 (Delaware River – Schuylkill River – Antietam Creek).

The location of the WWTP outfall in the Schuylkill River Watershed is as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
001	40° 19' 51"	75° 52' 24"

3. **Area Served.** The docket holder's WWTP will continue to serve portions of St. Lawrence Borough, Mount Penn Borough, Exeter Township and Lower Alsace Township, all within Berks County, Pennsylvania. For the purpose of defining the Area Served, the Type of Discharge and the Service Area sections from the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in Section C. DECISION of this docket.

4. **Design Criteria.** The WWTP will continue to utilize three different processes, including mix activated sludge treatment, contact stabilization treatment and oxidation ditch treatment. Treated effluent from Systems 1 and 2 combine and are treated by System 3, which utilizes an oxidation ditch treatment system, followed by chlorine disinfection. The WWTP is designed for an annual average flow of 1.225 mgd, and a hydraulic design capacity of 2.45 mgd.

5. **Facilities.** The WWTP treatment facilities consist of a headworks featuring grinding, fine screening, comminution and grit removal. System 1 utilizes a complete mix activated sludge treatment process and contains two primary clarifiers, four aeration tanks, two secondary clarifiers, and one anaerobic primary digester (which will be converted to an aerobic digester). System 2 utilizes a contact stabilization process, which includes two aeration tanks, one secondary clarifier and an aerobic digester (which will be upgraded). System 3 utilizes two oxidation ditch channels, two secondary clarifiers, and a chlorine contact tank. Sludge handling at the WWTP consists of a belt filter press in conjunction with the previously mentioned aerobic and anaerobic digester units.

The project facilities are not located in the 100-year floodplain.

Wasted sludge will continue to be hauled off-site for disposal in accordance with the NPDES Permit No. PA0026646.

6. **Water Withdrawals.** The potable water supply in the project service area is provided by wells and intakes owned and operated by Mount Penn Borough Municipal Authority approved via DRBC Docket No. D-1969-161 CP on October 29, 1969.

7. **NPDES Permit / DRBC Effluent Requirements.** NPDES Permit No. PA0026646 issued by the PADEP includes final effluent limitations for the project discharge to surface waters classified by the PADEP as supporting cold water fishes (CWF). EFFLUENT TABLES C-1 & C-2 included in Section C. DECISION condition C.1. of this docket, contain effluent requirements for DRBC parameters that must be met as a condition of this approval. Effluent requirements for Outfall No. 001 are based on a discharge rate of 1.225 mgd.

8. **Relationship to the Comprehensive Plan.** The existing WWTP was included in the Comprehensive Plan by Docket No. D-1968-004 CP-1. The WWTP approval was renewed

and/or modified by the dockets listed below. Issuance of this docket will continue the WWTP and its discharge in the Comprehensive Plan.

DOCKET NO.	DOCKET DESCRIPTION	APPROVAL DATE
D-1968-004 CP-1	Expansion to 1.205 mgd	April 24, 1968
D-1987-045 CP-1	Construction/Re-Rate to 1.225 mgd	September 22, 1987
D-1987-045 CP-2	Hydraulic Capacity Re-rate to 2.45 mgd	September 27, 2006
D-1987-045 CP-3	Approval Renewed	March 3, 2010
D-1987-045 CP-4	Approval Renewed	September 12, 2012
D-1987-045 CP-5	Approval Renewed	December 10, 2014
D-1987-045 CP-6	Approval Renewed	December 11, 2019

## B. FINDINGS

The docket holder applied to renew approval of their existing 1.225 mgd WWTP and its discharge. The docket holder also requests approval for proposed upgrades consisting of converting an existing anaerobic digester to an aerobic digester, upgrading aeration and mixing systems of the existing aerobic digester, blowers and diffusers, replacing RAS and WAS pumps and adding one standby pump, and installing one digester decant pump.

### 2. Other

Near the docket holder's WWTP discharge, the Antietam Creek has an estimated seven-day low flow with a recurrence interval of ten years ( $Q_{7-10}$ ) of 2.59 mgd (4.0 cfs). The ratio of this low flow to the hydraulic design wastewater discharge rate from the 1.225 mgd WWTP is 2.1 to 1.

The nearest surface water intake of record for public water supply is located on the Schuylkill River approximately 14 river miles downstream of the project discharge and is owned and operated by Pottstown Water Authority.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit conform with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge that meets the effluent requirements as set forth in the Commission's *Water Quality Regulations (WQR)*.

## C. DECISION

Effective on the approval date for Docket No. D-1987-045 CP-7 below, the project described in Docket No. D-1987-045 CP-6 is removed from the Comprehensive Plan to the extent that it is not included in Docket No. D-1987-045 CP-7; Docket No. D-1987-045 CP-6 is

terminated and replaced by Docket No. D-1987-045 CP-7; and the project and the appurtenant facilities described in Section A “DESCRIPTION” of this docket shall be included in the Comprehensive Plan. The project and appurtenant facilities as described in Section A of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

### **Monitoring and Reporting**

1. The docket holder shall comply with the requirements contained in the EFFLUENT TABLES below. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email [aemr@drbc.gov](mailto:aemr@drbc.gov) on the **Annual Effluent Monitoring Report Form** located at this web address: <https://www.nj.gov/drbc/programs/project/docket-app-info.html#3>. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations. The following average monthly effluent limits are among those listed in the NPDES Permit and meet or are more stringent than the effluent requirements of the DRBC.

**EFFLUENT TABLE C-1: DRBC Parameters Included in NPDES Permit**

<b>OUTFALL 001 (Antietam Creek)</b>		
<b>PARAMETER</b>	<b>LIMIT</b>	<b>MONITORING</b>
pH (Standard Units)	6 to 9 at all times	As required by NPDES Permit
Total Suspended Solids	30 mg/l	As required by NPDES Permit
Dissolved Oxygen	5.0 mg/l (minimum at all times)	As required by NPDES Permit
CBOD <sub>5</sub> (at 20° C)	25.0 mg/l; 85% minimum removal	As required by NPDES Permit
Ammonia Nitrogen (5-1 to 10-31) (11-1 to 4-30)	2.5 mg/l 7.5 mg/l	As required by NPDES Permit
Total Dissolved Solids*	1,000 mg/l *	Quarterly
Fecal Coliform (5-1 to 9-30) (10-1 to 4-30)	200 colonies per 100 ml as a geo. avg. 2000 colonies per 100 ml as a geo. avg.	As required by NPDES Permit

\* See DECISION Condition C.3

The following monitoring requirements and average monthly effluent limits are for DRBC parameters not listed in the NPDES Permit.

**EFFLUENT TABLE C-2: DRBC Parameters Not Included in NPDES Permit**

<b>OUTFALL 001 (Antietam Creek)</b>		
<b>PARAMETER</b>	<b>LIMIT</b>	<b>MONITORING</b>

OUTFALL 001 (Antietam Creek)		
PARAMETER	LIMIT	MONITORING
CBOD <sub>5</sub> (at 20° C) Influent	Monitor & Report Percent Removal	Monthly

### **Other Conditions**

2. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.

3. The docket holder may request permission from the Executive Director to perform specific conductance monitoring in lieu of TDS monitoring. The request shall be made in writing and shall include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow specific conductance monitoring in lieu of TDS monitoring.

4. In accordance with 18 C.F.R. 401.8. of the Commission's *Rules of Practice and Procedure (RPP)*, if at any future time the Project is changed materially from the Project as described in this docket, it will be deemed to constitute a new and different project for the purposes of Article 11 of the Delaware River Basin Compact and will require Commission amendment of the Comprehensive Plan. In accordance with the same section of the RPP, whenever a change to the Project is made, the sponsor must advise the Executive Director, who will determine whether the change is deemed materially for purposes of this provision.

5. This approval shall expire on the expiration date set forth below unless prior thereto the docket holder has applied to the Commission to renew or extend this approval.

6. The docket holder is responsible for timely submittal to the DRBC of a docket renewal application on the appropriate application form including the appropriate docket application filing fee (see 18 C.F.R. 401.43) at least 6 months in advance of the docket expiration date set forth below. The docket holder will be subject to late filed renewal surcharges in the event of untimely submittal of its renewal application, whether DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. If a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below, the terms and conditions of the current docket will remain fully effective and enforceable pending the grant or denial of the application for docket approval.

7. The docket holder is permitted to treat and discharge wastewater as set forth in the Area Served Section of this docket, which incorporates by reference the Type of Discharge and Service Area sections of the docket holder's Application to the extent consistent with all other conditions of this section. Any expansion beyond that included in Section A.3. Area Served is subject to DRBC review and approval in accordance with Section 3.8 of the Compact.

8. In accordance with the Commission's regulations at 18 C.F.R. Part 440, the docket holder is prohibited from discharging wastewater from high volume hydraulic fracturing ("HVHF") or HVHF-related activities to waters or land within the Basin. The docket holder is further prohibited from discharging hydraulic fracturing wastewater, whether treated or untreated, from sources within or outside the Basin, without obtaining the Commission's prior review and express approval in the form of a revised docket. Violation of this or any condition of this docket approval may result in enforcement, including the risk of financial penalties, pursuant to Section 14.17 of the Delaware River Basin Compact and Section 2.7.8 (18 CFR 401.98) of the Commission's Rules of Practice and Procedure.
9. The facility and operational records shall be available at all times for inspection by the DRBC.
10. The facility shall be operated at all times to comply with the requirements of the Commission's *WQR*.
11. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.
12. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.
13. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.
14. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).
15. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, to ensure proper control, use and management of the water resources of the Basin.
16. The docket holder shall be subject to applicable DRBC regulatory program fees, in accordance with duly adopted DRBC resolutions and/or regulations (see 18 C.F.R. 401.43).
17. This approval is transferable by request to the DRBC Executive Director provided that the project purpose and area served approved by the Commission in this docket will not be materially altered because of the change in project ownership. The request shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).
18. The docket holder shall request a name change of the entity to which this approval is issued if the name of the entity to which this approval is issued changes its name. The request for

name change shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).

**19.** The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.

**20.** Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the *Rules of Practice and Procedure (RPP)*. In accordance with Section 15.1(p) of the *Delaware River Basin Compact*, cases and controversies arising under the *Compact* are reviewable in the United States district courts.

**BY THE COMMISSION**

**APPROVAL DATE:**

**EXPIRATION DATE: March 12, 2030**