This DRAFT Docket has been prepared for the purposes of the scheduled public hearing and may be substantially modified as a result of the public hearing process prior to Commission action.

7/21/2025 10:41 AM

## **DOCKET NO. D-2019-008-2**

### DELAWARE RIVER BASIN COMMISSION

Discharge to a Tributary of Special Protection Waters

Pocono Mountains Industries Wastewater Treatment Plant Coolbaugh Township, Monroe County, Pennsylvania

# **PROCEEDINGS**

This docket is issued in response to an application submitted to the Delaware River Basin Commission (DRBC or Commission) on August 9, 2024 (Application), for renewal of the docket holder's existing wastewater treatment plant (WWTP) and its discharge. The Pennsylvania Department of Environmental Protection (PADEP) issued National Pollutant Discharge Elimination System (NPDES) Permit No. PA0060895 for this discharge.

The application was reviewed for approval under Section 3.8 of the *Delaware River Basin Compact*. The Monroe County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on August 6, 2025.

### A. <u>DESCRIPTION</u>

- 1. <u>Purpose</u>. The purpose of this docket is to renew approval of the docket holder's existing 0.0144 million gallons per day (mgd) WWTP and its discharge.
- **Location**. The docket holder's WWTP is located at the end of Kolb Court off of Corporate Center Drive East, in Coolbaugh Township, Monroe County, Pennsylvania. The WWTP will continue to discharge treated effluent to Red Run, at River Mile 183.7 83.5 11.4 6.4 3.6 (Delaware River Lehigh River Tobyhanna Creek Upper Tuckhannock Creek Red Run) and is located in the drainage area to the Lower Delaware Special Protection Waters (SPW).

The location of the WWTP outfall in the Tobyhanna Creek Watershed is as follows:

OUTFALL NO.	LATITUDE (N)	LONGITUDE (W)
001	41° 8' 34"	75° 21' 51"

- 3. <u>Area Served</u>. The docket holder's WWTP will continue to serve Pocono Mountain Corporate Center in Coolbaugh Township, Monroe County, Pennsylvania. For the purpose of defining the Area Served, the Type of Discharge and the Service Area sections from the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in Section C. DECISION of this docket.
- **4.** <u>Design Criteria</u>. The docket holder's 0.0144 mgd WWTP utilizes an extended aeration / activated sludge treatment process with sand filtration and ultraviolet light (UV) disinfection.
- **5. Facilities.** The WWTP facilities consist of influent comminutor/bar screen, equalization tank, aeration tank, sludge holding tank, clarifier, sand filter, and UV disinfection.

The docket holder's WWTP discharges to waters classified as SPW and is required to have available standby power. The existing WWTP has a generator installed capable of providing standby power.

The docket holder's WWTP is not staffed 24 hours per day and shall have a remote alarm system that continuously monitors plant operations in accordance with the Commission's SPW requirements. The existing WWTP is in the process of implementing an alarm system that continuously monitors the plant. The docket holder is required to install remote alarm systems within 6 months of approval of this docket. (See Section C. DECISION Condition C.2.)

The docket holder has prepared and implemented an emergency management plan (EMP) for the existing WWTP in accordance with Commission SPW requirements.

The project facilities are not located in the 100-year floodplain.

Wasted sludge will continue to be hauled off-site for disposal in accordance with the NPDES Permit No. PA0060895.

- **Mater Withdrawals.** The potable water supply in the project service area is provided by groundwater wells operated by Pennsylvania American Water Company Pocono District. The groundwater withdrawal is described in detail in Docket No. D-1998-016 CP-4, which was approved on March 10, 2021.
- 7. NPDES Permit / DRBC Effluent Requirements. NPDES Permit No. PA0060895 issued by the PADEP includes final effluent limitations for the project discharge to surface waters classified by the PADEP as supporting high quality water cold water fishes (HQ-CWF) and migratory fishes (MF). EFFLUENT TABLES C-1 & C-2 included in Section C. DECISION condition C.1. of this docket, contain effluent requirements for DRBC parameters that must be met as a condition of this approval. Effluent requirements for Outfall No. 001 are based on a discharge rate of 0.0144 mgd.

### **B. FINDINGS**

The docket holder applied to renew approval of their existing 0.0144 mgd WWTP and its discharge.

## 1. Special Protection Waters

In 1992, the DRBC adopted SPW requirements, as part of the DRBC *Water Quality Regulations* (*WQR*), designed to protect existing water quality in applicable areas of the Delaware River Basin. One hundred twenty miles of the Delaware River from Hancock, New York downstream to the Delaware Water Gap has been classified by the DRBC as SPW. This stretch includes the sections of the river federally designated as "Wild and Scenic" in 1978 -- the Upper Delaware Scenic and Recreational River and the Delaware Water Gap National Recreation Area -- as well as an eight-mile reach between Milrift and Milford, Pennsylvania which is not federally designated. The SPW regulations apply to this 120-mile stretch of the river and its drainage area.

On July 16, 2008, the DRBC approved amendments to its *Water Quality Regulations* (*WQR*) that provide increased protection for waters that the Commission classifies as SPW. The portion of the Delaware River and its tributaries within the boundary of the Lower Delaware River Management Plan Area was approved for SPW designation.

The docket holder's WWTP discharges to the drainage area to the Lower Delaware SPW. The docket holder's WWTP discharge is required to comply with the SPW requirements, as outlined in Article 3.10.3A.2. of the *WQR*.

Article 3.10.3A.2.e.1). and 2). of the Commission's WQR states that projects subject to review under Section 3.8 of the Compact that are located in the drainage area of SPW must submit for approval a Non-Point Source Pollution Control Plan (NPSPCP) that controls the new or increased non-point source loads generated within the portion of the docket holder's service area which is also located within the drainage area of SPW. The service area of the docket holder is located in the drainage area to the SPW. Since this project does not entail additional construction and/or expansion of facilities and service area and there are no new or increased non-point source loads associated with this approval, the NPSPCP requirement is not applicable at this time. Accordingly, Section C. DECISION condition C.5. has been included in this docket.

Coolbaugh Township is regulated by the PADEP as a Stormwater Phase II municipality and is permitted by PADEP as such. Coolbaugh Township adopted and implemented a stormwater ordinance in accordance with the PADEP requirements. The PADEP Stormwater Phase II requirements satisfy the NPSPCP requirements of the Commission.

As noted above in A.3. the docket holder's area served is located entirely in Coolbaugh Township. This municipality has enacted and is actively implementing non-point source/stormwater control ordinances adopting the Coolbaugh Township Stormwater Management and Earth Disturbance Ordinance No. 120-2014. Compliance with the Coolbaugh Township Stormwater Management and Earth Disturbance Ordinance No. 120-2014, adopted on

June 17, 2014, generally meets the requirements of Article 3.10.3.A.2.e.1 of the Commission's Water Quality Regulations for the Area Served as described in A.3. above within Coolbaugh Township. Prior to allowing connections from any new service areas or any new developments not in compliance with this Ordinance, the docket holder shall submit and have approved by the Executive Director of the DRBC a Non-Point Source Pollution Control Plan (NPSPCP) in accordance with Section 3.10.3.A.2.e.

## 2. <u>Total Dissolved Solids (TDS)</u>

Based on WWTP effluent data from 2021 through 2023, the TDS concentration in the WWTP effluent exceeded DRBC's basin-wide TDS effluent limit of 1,000 mg/l. The docket holder is required by this docket to submit a work plan for a TDS study to determine the cause of the exceedances. The docket holder shall submit a work plan for the TDS study within 30 days of the docket approval for approval by the DRBC Executive Director (see Section C. DECISION Condition C.3.).

# 3. Other

At the WWTP discharge location, Red Run has an estimated seven-day low flow with a recurrence interval of ten years ( $Q_{7-10}$ ) of less than 0.1 cubic feet per second (cfs) and therefore is classified by the Commission as an intermittent stream.

The nearest surface water intake of record for public water supply is located on the Lehigh River approximately 42 River Miles downstream of the docket holder's WWTP and is operated by the City of Hazleton.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit conform with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge that meets the effluent requirements as set forth in the Commission's *Water Quality Regulations (WQR)*.

# C. <u>DECISION</u>

Effective on the approval date for Docket No. D-2019-008-2 below, the project described in Docket No. D-2019-008-1 is removed to the extent that it is not included in Docket No. D-2019-008-2; Docket No. D-2019-008-1 is terminated and replaced by Docket No. 2019-008-2; and the project and the appurtenant facilities described in Section A "DESCRIPTION" of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions:

## **Monitoring and Reporting**

The docket holder shall comply with the requirements contained in the EFFLUENT TABLES below. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email aemr@drbc.gov on the Annual Effluent **Monitoring** Report Form located at this web address: https://www.nj.gov/drbc/programs/project/docket-app-info.html#3. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations. The following average monthly effluent limits are among those listed in the NPDES Permit and meet or are more stringent than the effluent requirements of the DRBC.

EFFLUENT TABLE C-1: DRBC Parameters Included in NPDES Permit

OUTFALL 001 (Red Run)			
PARAMETER	LIMIT	MONITORING	
pH (Standard Units)	6 to 9 at all times	As required by NPDES Permit	
Total Suspended Solids	30 mg/l	As required by NPDES Permit	
Dissolved Oxygen	5.0 mg/l (minimum at all times)	As required by NPDES Permit	
CBOD <sub>5</sub> (at 20° C)	15 mg/l	As required by NPDES Permit	
Ammonia Nitrogen (5-1 to 10-31) (11-1 to 4-30)	3.0 mg/l 9.0 mg/l	As required by NPDES Permit	
Fecal Coliform (5-1 to 9-30) (10-1 to 4-30)	200 colonies per 100 ml as a geo. avg. 2000 colonies per 100 ml as a geo. avg.	As required by NPDES Permit	
Phosphorus	0.5 mg/l	As required by NPDES Permit	
Total Dissolved Solids*	Monitor & Report	As required by NPDES Permit	
Nitrate + Nitrite as N	Monitor & Report	As required by NPDES Permit	
Total Nitrogen	Monitor & Report	As required by NPDES Permit	
Total Kjeldahl Nitrogen	Monitor & Report	As required by NPDES Permit	

<sup>\*</sup>See Decision Condition C.8.

The following monitoring requirements and average monthly effluent limits are for DRBC parameters not listed in the NPDES Permit.

EFFLUENT TABLE C-2: DRBC Parameters Not Included in NPDES Permit

OUTFALL 001 (Red Run)			
PARAMETER	LIMIT	MONITORING	
CBOD <sub>5</sub> (at 20° C)	Monitor & Report Percent Removal	Monthly	
CBOD <sub>5</sub> (at 20° C) Influent	Monitor & Report	Monthly	

- 2. The docket holder shall install remote alarm controls within 6 months of docket approval. The docket holder shall inform and certify in writing to the Commission that it has complied with this condition by March 10, 2026 (6 months after docket is approved).
- 3. The docket holder shall submit a work plan for a TDS study within 30 days of this docket approval (by October 10, 2025) for approval by the Executive Director.

## **Other Conditions**

- 4. Nothing in this docket constitutes a defense to any penalty action for past conduct of the docket holder or ongoing activity not authorized by this approval. In particular, renewal of this docket does not resolve violations whether in the past or continuing of provisions of the Delaware River Basin *Compact* ("Compact") or any rule, regulation, order or approval duly issued by the Commission or the Executive Director pursuant to the Compact. The Commission reserves its right to take appropriate enforcement action against the docket holder, including but not limited to recovery of financial penalties consistent with Section 14.17 of the Compact, for any and all such prior or continuing violations.
- 5. Prior to allowing connections from any new service areas or any new developments, the docket holder shall either submit and have approved by the Executive Director of the DRBC a NPSPCP in accordance with Section 3.10.3.A.2.e, or receive written confirmation from the Executive Director of the DRBC that the new service area complies with a DRBC-approved NPSPCP.
- 6. Prior to the docket holder initiating any substantial alterations or additions to the existing WWTP as defined in Section 3.10.3A2.a.16) of the Commission's WQR, an application must be submitted and approved by the Commission. Such an application shall be submitted prior to final design to ensure that the Commission can provide the docket holder with draft effluent limitations for SPW specific parameters as guidance for design as to not require duplication of work or cause a substantial expenditure of public funds without Commission approval. The docket holder is encouraged to contact the Commission staff during the planning stages to identify the potential effluent limitations required to meet the no measurable change parameters under SPW.
- 7. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.
- 8. The docket holder may request permission from the Executive Director to perform specific conductance monitoring in lieu of TDS monitoring. The request shall be made in writing and shall include information that supports the effluent specific correlation between TDS and specific

conductance. Upon review, the Executive Director may modify the docket to allow specific conductance monitoring in lieu of TDS monitoring.

- 9. This approval shall expire on the expiration date set forth below unless prior thereto the docket holder has applied to the Commission to renew or extend this approval.
- 10. The docket holder is responsible for timely submittal to the DRBC of a docket renewal application on the appropriate application form including the appropriate docket application filing fee (see 18 C.F.R. 401.43) at least 6 months in advance of the docket expiration date set forth below. The docket holder will be subject to late filed renewal surcharges in the event of untimely submittal of its renewal application, whether DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. If a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below, the terms and conditions of the current docket will remain fully effective and enforceable pending the grant or denial of the application for docket approval.
- 11. The docket holder is permitted to treat and discharge wastewater as set forth in the Area Served Section of this docket, which incorporates by reference the Type of Discharge and Service Area sections of the docket holder's Application to the extent consistent with all other conditions of this section. Any expansion beyond that included in Section A.3. Area Served is subject to DRBC review and approval in accordance with Section 3.8 of the Compact.
- 12. In accordance with the Commission's regulations at 18 C.F.R. Part 440, the docket holder is prohibited from discharging wastewater from high volume hydraulic fracturing ("HVHF") or HVHF-related activities to waters or land within the Basin. The docket holder is further prohibited from discharging hydraulic fracturing wastewater, whether treated or untreated, from sources within or outside the Basin, without obtaining the Commission's prior review and express approval in the form of a revised docket. Violation of this or any condition of this docket approval may result in enforcement, including the risk of financial penalties, pursuant to Section 14.17 of the Delaware River Basin Compact and Section 2.7.8 (18 CFR 401.98) of the Commission's Rules of Practice and Procedure.
- 13. The facility and operational records shall be available at all times for inspection by the DRBC.
- 14. The facility shall be operated at all times to comply with the requirements of the Commission's WQR.
- 15. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.
- 16. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.

- 17. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.
- 18. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).
- 19. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, to ensure proper control, use and management of the water resources of the Basin.
- **20.** The docket holder shall be subject to applicable DRBC regulatory program fees, in accordance with duly adopted DRBC resolutions and/or regulations (see 18 C.F.R. 401.43).
- 21. This approval is transferable by request to the DRBC Executive Director provided that the project purpose and area served approved by the Commission in this docket will not be materially altered because of the change in project ownership. The request shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).
- 22. The docket holder shall request a name change of the entity to which this approval is issued if the name of the entity to which this approval is issued changes its name. The request for name change shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 C.F.R. 401.43).
- 23. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.
- **24.** Prior to allowing connections from any new service areas or any new developments not in compliance with the Ordinances described in Section B.1. above, the docket holder shall submit and have approved by the Executive Director of the DRBC a Non-Point Source Pollution Control Plan (NPSPCP) in accordance with Section 3.10.3.A.2.e.
- 25. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the *Rules of Practice and Procedure (RPP)*. In accordance with Section 15.1(p) of the *Delaware River Basin Compact*, cases and controversies arising under the *Compact* are reviewable in the United States district courts.

BY THE COMMISSION

**APPROVAL DATE:** 

**EXPIRATION DATE: December 31, 2031** 

